




Coordinated Water System Plan
Part IV: Final Executive Summary
Central Connecticut Public Water Supply Management Area
June 4, 2018

Coordinated Water System Plan

Part IV: Final Executive Summary

Central Connecticut Public Water Supply Management Area
June 4, 2018



Prepared for:

CENTRAL REGION WATER UTILITY
COORDINATING COMMITTEE
c/o the Elected Recording Secretary
281 Hazard Avenue, Enfield, CT 06082
<http://www.portal.ct.gov/DPH/Drinking-Water/WUCC/Central-Corridor-Water-Utility-Coordinating-Committee>

Sponsoring Agency:

CONNECTICUT DEPARTMENT OF PUBLIC HEALTH
410 Capitol Avenue
MS #12DWS, P.O. Box 340308
Hartford, CT 06134-0308
(860) 509-7333
<http://www.portal.ct.gov/DPH>

Prepared by:

MILONE & MACBROOM, INC.
99 Realty Drive
Cheshire, Connecticut 06410
(203) 271-1773
www.mminc.com

MMI #1017-05-06



NOTICE TO READERS

This document was prepared under a grant from the United States Environmental Protection Agency (EPA) administered by the Connecticut Department of Public Health (DPH). Points of view or opinions expressed in this document are those of the Central Water Utility Coordinating Committee and do not necessarily represent the official position or policies of the EPA or the Connecticut DPH.

ACKNOWLEDGEMENTS

This document could not be completed without the time and dedication of the Water Utility Coordinating Committee (WUCC) Officers and active WUCC membership, defined as those members who regularly attended Central Connecticut WUCC meetings or provided written comments on the process.

Central WUCC Officers

David Radka, Co-Chair
Director of Water Resources & Planning
Connecticut Water Company
91 West Main Street, Clinton, CT 06413
DRadka@ctwater.com

R. Bartley Halloran, Co-Chair
District Council
Metropolitan District Commission
555 Main Street, Hartford, CT 06142
BHalloran@themdc.com

Brendan Avery, Recording Secretary
Water Treatment Operator
Hazardville Water Company
281 Hazard Avenue, Enfield, CT 06082
BAvery@hazardvillewater.com

Central WUCC Active Members

Member	Member
Aquarion Water Company	Manchester Water & Sewer Department
Avon Water Company	Town of Marlborough
Berlin Water Control Commission	Meriden Water Division
Bristol Water Department	Metropolitan District Commission
Capitol Region Council of Governments	Middletown Water & Sewer Department
Connecticut Water Company	New Britain Water Department
Cromwell Fire District	Portland Water Department
Town of Durham	South Central Connecticut Regional Water Authority
Town of East Haddam	South Central Region Council of Governments
East Hampton Water Pollution Control Authority	Southington Water Department
Town of Haddam	Tolland Water Commission
Hazardville Water Company	Wallingford Water Division
Lower Connecticut River Valley Council of Governments	

Other Meeting Attendees

The Central Connecticut WUCC also appreciates the time and effort of the numerous non-member stakeholders who participated in and have contributed valuable insight to this process:

Stakeholders	Stakeholders
Connecticut Department of Energy & Environmental Protection	Prime AE Group
Connecticut Department of Public Health	Quinnipiac River Watershed Association
Connecticut Office of Policy & Management	RCAP Solutions
Connecticut River Watershed Council	Rivers Alliance of Connecticut
Farmington River Watershed Association	Save Our Water - CT
Members of the Public	University of Connecticut

Document Authors

The following representatives of Milone & MacBroom, Inc. (MMI) have contributed to this document:

Jeanine Armstrong Gouin, P.E., Vice President
David Murphy, P.E., CFM, Associate
Scott J. Bighinatti, MS, CFM, Lead Environmental Scientist
Peter Shea, Lead Environmental Scientist
Mathew Rose, Environmental Scientist
Noah Slovin, CFM, Environmental Scientist
Derek Pronovost, Communications Assistant

TABLE OF CONTENTS

Notice to Readers	i
Acknowledgements	ii
Table of Contents.....	iv
Definitions.....	vi
Abbreviations.....	ix
SUMMARY OF MAJOR FINDINGS AND RECOMMENDATIONS	ES-1
1.0 THE COORDINATED WATER SYSTEM PLANNING PROCESS.....	1
2.0 COMPOSITION OF THE CENTRAL PUBLIC WATER SUPPLY MANAGEMENT AREA	3
3.0 SUMMARY OF THE WATER SUPPLY ASSESSMENT	4
4.0 EXCLUSIVE SERVICE AREA BOUNDARIES.....	6
5.0 POPULATION AND WATER SUPPLY DEMAND.....	10
6.0 POTENTIAL INTERCONNECTIONS, JOINT USE FACILITIES, AND SATELLITE MANAGEMENT	18
7.0 POTENTIAL WATER SUPPLY SOURCES	21
8.0 POTENTIAL IMPACT OF THE COORDINATED WATER SYSTEM PLAN ON OTHER USES OF WATER RESOURCES.....	23

LIST OF TABLES

Table ES-1	Prioritization and Implementation of Non-Capital Improvement Recommendations	ES-6
Table 1	Central PWSMA Towns	3
Table 2	Final Recommended ESA Holders in Central PWSMA	7
Table 3	Historical Population by Town for the Central PWSMA.....	10
Table 4	Population Projections by Town for the Central PWSMA.....	12
Table 5	Existing and Projected ADD, Available Water, and Margin of Safety for Exclusive Service Areas in Central PWSMA by ESA Holder.....	15
Table 6	Summary of Available Water Deficits to Meet MMADD for Community Water Systems...	16
Table 7	Satellite Management Needs and Opportunities of ESA Holders.....	19

TABLE OF CONTENTS (CONTINUED)

LIST OF FIGURES

Figure 1 Population Growth by Town Classification: Central PWSMA 12

LIST OF APPENDED FIGURES

Regional MapAppended Figure 1

LIST OF APPENDICES

Table of Contents for Part I, Part II, and Part III of the Coordinated Water System Plan.....Appendix A

DEFINITIONS

Areawide Supplement – A part of a coordinated water system plan that addresses areawide water system concerns pertaining to the public water supply management area that are not otherwise included in each water company's individual water system plan. The supplement identifies the present and future water system concerns, analyzes alternatives, and sets forth means for meeting those concerns. An areawide supplement consists of a water supply assessment, exclusive service area boundaries, integrated report, and executive summary.

Available Water – Per RCSA Section 25-32d-1a(4), the maximum amount of water a company can dependably supply, taking into account the following reductions applied to safe yield: any limitations imposed by hydraulics, treatment, well pump capabilities, reductions of well yield due to clogging that can be corrected with redevelopment, transmission mains, permit conditions, source construction limitations, approval limitations, or operational considerations; and the safe yield of active sources and water supplied according to contract provided that the contract is not subject to cancellation or suspension, assures the availability of water throughout a period of drought, and that the supply is reliable.

Coordinated Water System Plan – The individual water system plans of each public water system within a public water supply management area, filed pursuant to Section 25-32d of the Connecticut General Statutes, and an areawide supplement to such plans developed pursuant to Connecticut General Statute 25-33h that addresses water system concerns pertaining to the public water supply management area as a whole.

Exclusive Service Area (ESA) – An area where public water is supplied, or will be supplied, by one system. ESA boundaries comprise Part II of the areawide supplement. As part of the ESA assignment process, all existing public water systems automatically receive an ESA designation for their existing service area, be it the parcel(s) they serve or the area around their existing water mains. Public water systems and municipalities were also requested to declare for the ESA for areas currently unserved by public water systems; this is described in more detail in the Coordinated Water System Plan, Part II document published in June 2017.

Exclusive Service Area (ESA) Designation – The combination of the ESA holder and associated ESA boundaries.

Exclusive Service Area (ESA) Holder – A utility or municipality who has been assigned or recommended an ESA that includes areas not presently served by its existing system.

Executive Summary – An abbreviated overview of the coordinated water system plan for the public water supply management area that summarizes the major elements of the coordinated water system plan. The Executive Summary comprises Part IV of the areawide supplement.

Integrated Report – An overview of individual public water systems within the management area that addresses areawide water supply issues, concerns, and needs and promotes cooperation among public water systems. The report comprises Part III of the areawide supplement.

DEFINITIONS (CONTINUED)

Public Water Supply Management Area (PWSMA) – An area for coordinated water supply planning determined by the Commissioner of the Department of Public Health to have similar water supply problems and characteristics.

Public Water System (PWS) – Any private, municipal, or regional utility supplying water for human consumption through pipes or other constructed conveyances to at least 15 service connections or serving an average of at least 25 people daily for at least 60 days per year. Types of regulated public water systems are discussed below:

Community Water System (CWS) – A public water system that regularly supplies water to at least 15 service connections or at least 25 of the same population year-round. Examples include residential subdivisions, cluster-housing projects, homeowners associations, municipalities, tax districts, apartment buildings or complexes, residential and office condominium developments, elderly housing projects, convalescent homes, and trailer or mobile home parks.

Non-Community Water System – A public water system that serves at least 25 persons at least 60 days per year and is not a Community or seasonal water system.

Non-Transient Non-Community (NTNC) Water System – A public water system that regularly supplies water to at least 25 of the same people (such as students or employees) over 6 months per year and is not a Community Water System. Some examples are schools, factories, office buildings, and hospitals that have their own water systems.

Transient Non-Community (TNC) Water System – Any non-community water system that does not meet the definition of a NTNC water system. It is a public water system that provides water in a place such as a gas station convenience store, small restaurant, or campground where people do not remain for long periods of time.

Seasonal Water System – A public water system that operates on a seasonal basis for 6 months of the year or fewer. These are typically regulated as NTNC water systems - unless sufficient service is available to meet the definition of a CWS - and often include campgrounds and shorefront communities.

Safe Yield – The maximum dependable quantity of water per unit of time that may flow or be pumped continuously from a source of supply during a critical dry period without consideration of available water limitations. The safe yield calculation for a source does not take into consideration any potential impacts to the environment.

Satellite Management – Management of a public water supply system by another public water system. Satellite management services may include operation, maintenance, administration, emergency and scheduled repairs, monitoring and reporting, billing, operator training, and the purchase of supplies and equipment.

Satellite System – A non-connected CWS of an existing system. Colloquially, a non-connected community or non-community public water system owned by a public water service provider.

DEFINITIONS (CONTINUED)

Water Supply Assessment – An evaluation of water supply conditions and problems within the public water supply management area. The evaluation is Part I of the areawide supplement.

Water Utility Coordinating Committee (WUCC) – A committee consisting of one representative from each public water system with a source of supply or service area within the PWSMA and one representative from each regional council of government within the PWSMA, elected by majority vote of the chief elected officials of the municipalities that are members of such regional council of government.

ABBREVIATIONS

ADD	Average Daily Demand
AWC	Aquarion Water Company
CAT	Capacity Assessment Tool
cfs	cubic feet per second
CGS	Connecticut General Statute(s)
CIRCA	Connecticut Institute for Resilience and Climate Adaptation
CPCN	Certificate of Public Convenience and Necessity
CRCOG	Capitol Region Council of Governments
CT SDC	Connecticut State Data Center
CWC or CTWC	Connecticut Water Company
CWS or CWSs	Community Water System(s)
CWSP	Coordinated Water System Plan
DEEP	Department of Energy & Environmental Protection
DPH	Department of Public Health
DWQMP	Drinking Water Quality Management Plan
EPA	Environmental Protection Agency
ESA or ESAs	Exclusive Service Area(s)
FOIA	Freedom of Information Act
MCL	Maximum Contaminant Level
MDC	Metropolitan District Commission
mgd	million gallons per day
MMADD	Maximum Month Average Day Demand
MMI	Milone & MacBroom, Inc.
MOS	Margin of Safety
NDDDB	Natural Diversity Database
NTNC	Non-Transient Non-Community
OPM	Office of Policy and Management
POCD or POCDs	Plan(s) of Conservation and Development
PURA	Public Utilities Regulatory Authority
PWS	Public Water System
PWSMA	Public Water Supply Management Area
RCSA	Regulations of Connecticut State Agencies
RiverCOG	Lower Connecticut River Valley Council of Governments
SCCRWA	South Central Connecticut Regional Water Authority
SCRCOG	South Central Region Council of Governments
TNC	Transient Non-Community
WPCA	Water Pollution Control Authority
WSA	Water Supply Assessment
WSP or WSPs	Water Supply Plan(s)
WUCC or WUCCs	Water Utility Coordinating Committee(s)
WWW	Windham Water Works



SUMMARY OF MAJOR FINDINGS AND RECOMMENDATIONS

This document presents the Executive Summary of the coordinated public water system planning process in the Central Public Water Supply Management Area (PWSMA). The region is comprised of 70 towns within which approximately 200 community public water systems and 751 non-community public water systems currently operate. The Central Water Utility Coordinating Committee (the WUCC) convened on June 15, 2016 and has met once per month since that time up to the publication of this document. During this process, the active membership has engaged in discussions involving a variety of topics pertinent to individual public water systems and water supply in the region at large.

In conjunction with the Connecticut Department of Public Health (DPH) and its consultant team, the WUCC completed a Water Supply Assessment (final document published December 2016) and established Recommended Exclusive Service Area Boundaries (final document published June 2017, amendable as necessary). The WUCC has most recently developed a comprehensive *Final Integrated Report* and the subject *Final Executive Summary*. Each document has been formally endorsed and adopted by the WUCC following receipt and consideration of public comments. The table of contents for each of the first three components of the *Coordinated Water System Plan* (CWSP) is included as Appendix A.

Summary of Findings

During the coordinated public water system planning process, the following major findings and recommendations were derived:

Finding #1: Water planning in Connecticut is rapidly advancing through numerous stakeholder efforts. While the changes are expected to be beneficial, utilities will need to make adjustments.

The planning effort for the *State Water Plan* (January 2018) and the CWSP occurred partially concurrently, with the *State Water Plan* benefiting from data collection efforts for the *Water Supply Assessment* (December 2016) and the *Integrated Report* benefiting from the efforts put into the *State Water Plan*. In addition, DPH has commissioned a resiliency study for public water systems being performed by the Connecticut Institute for Resilience and Climate Adaptation (CIRCA) and the University of Connecticut which is expected to be completed later in 2018.

For utilities, participation in these efforts is only the beginning. Many utilities will need to review and make operational changes to their systems (either voluntarily or to comply with regulations) in the near future:

- Public Act 17-211 requires that a large portion of the information in individual water supply plans (WSPs) be un-redacted for public viewing. DPH is requesting that utilities provide both redacted and un-redacted copies of new WSPs that can be made available for public distribution. DPH will request redacted copies of old WSPs as necessary to meet Freedom of Information Act (FOIA) requests;

- A stricter reading of the regulations regarding the calculation of available water for public water systems by DPH has resulted in available water to meet maximum month average day demand (MMADD) for many surface water supplies and for some groundwater supplies and interconnections to be much less than previously recognized, leading to low margin of safety (MOS) being calculated for maximum months “on paper” despite water being available for use. Guidance is necessary to address how the calculation is performed, or certain large systems will need to pursue new source development that may not be necessary;
- The Drinking Water Quality Management Planning (DWQMP) process is an option for several utilities to strengthen watershed protections;
- For certain reservoir systems, compliance with the Streamflow Standards and Regulations will be required in the Central PWSMA by 2030;
- For many utilities, a heightened focus on water conservation and water efficiency will be necessary to reduce future demands in order to mitigate the need for development of new sources;
- Several different committees are considering how drought planning and response are considered in Connecticut, with the potential use of reservoir forecasting models gaining traction with some larger utilities to manage drought; and
- Future capital improvement projects may be more focused on resiliency solutions than on new sources and treatment systems.

The DWQMP process is recommended for several utilities to improve source water protection in their public water supply watersheds.

A number of interconnections are proposed to increase source resiliency in the region. The WUCC should continue efforts to encourage the parties involved to implement emergency interconnections to increase the overall resiliency of public water supply in the region.

The WUCC recognizes that most capital improvement efforts will take place at the individual utility level. WUCC meetings will continue to be a place where issues of regional significance may be discussed.

Finding #2: Regionally, sufficient water supply exists to meet existing and projected average day demands (ADD) through 2060. However, the water is not always in the location of need. Projections of ADD for the community water systems (CWSs) indicate that significant supplies will be needed for two large systems by the 20-year planning period in order to maintain margin of safety of 15 percent (1.15). Certain individual systems will require new sources even sooner to meet MMADD. Based on existing sources and procedures for calculation of available water, CWSs in the region are projecting a supply need of approximately 0.6 million gallons per day (mgd), 1.4 mgd, and 20.5 mgd respectively over the five-year, 20-year, and 50-year planning horizons, primarily to meet MMADD.

The majority of the ADD need has been identified by Connecticut Water Company (CWC) for certain systems in the 5-year planning horizon (2023), with the East Hampton Water Pollution Control Authority (WPCA) potentially needing increased supply in the 20-year planning horizon (2030), and Southington Water Department and Tolland Water Department projecting notable water needs in the 50-year planning horizon (2060). Note that that the long-term projection assumes that the Metropolitan District Commission (MDC) would need to comply with the release requirements of the Streamflow Standards

and Regulations, such that the utility would require 15.5 mgd of new supply in such a scenario. These needs are based on utility projections and the current method for calculating available water for each system.

New supply sources are needed throughout the region. The WUCC encourages each individual system to make supply improvements as needed to meet projected demands. For development of new sources to meet regionally significant needs, the WUCC encourages utilities to collaborate with other parties connected to the regionally interconnected water system in southeastern Connecticut. Several of the areas that may need water are located distant from areas where potential new sources have been identified.

Based on a planning-level inventory of regionally significant supply sources (i.e., generally those capable of providing 1.0 mgd or more unless the improvement is part of a source that is currently able to regionally provide water), a total potential yield of 6 mgd may be available if all identified sources are developed. Additional sources capable of providing less than 1.0 mgd will be needed to supply geographically remote systems that are in need of water. When compared to the projected deficits, potential supply is theoretically capable of meeting demands. However, financial, environmental, and regulatory obstacles are significant. The cost, time, and uncertainty of permitting new supply sources are critical issues facing the public water systems in the region.

It is recognized that a regional approach with respect to water supply source development may be necessary in the future to satisfy demands. Accordingly, the WUCC's evaluation of future supply sources has considered the ability of each potential supply to serve regionally significant needs.

Finding #3: The benefits of passive water conservation efforts envisioned by the State Water Plan would significantly reduce projected demands for many larger public water systems. At a minimum, utilities should review their existing rate structures and modify them as appropriate to encourage water conservation while covering the full cost of providing public water supply.

Top-down water conservation measures were enacted in the plumbing code and by water utilities starting in the 1980s, with many utilities believing that water savings from these efforts have been largely exhausted. However, the proliferation of water-saving devices and the general identification of the ability to reduce water consumption by customers in order to pay a smaller utility bill has resulted in declining demand in many water systems over the past decade. Future passive water conservation savings modeled based on Scenario I of the *State Water Plan* suggest that future demand reductions along this downward trend may be possible.

Based on existing sources and procedures for calculation of available water, with adjustment for passive water conservation measures, CWSs in the region are projecting a supply need of approximately 0.6 mgd, 1.0 mgd, and 3.5 mgd over the three planning horizons, primarily to meet MMADD. The use of targeted water conservation and water efficiency measures and programs for these utilities is expected to further reduce the potential need for new supply sources, although it is recognized that such measures may not be necessary for all public water systems. At a minimum, all utilities are encouraged to review their existing rate structures and modify

For large utilities projecting significant deficits, re-evaluation of projected demands and development of a targeted water conservation and water efficiency program are recommended to reduce future demands and mitigate the need for development of new supply sources.

them where appropriate to encourage water conservation while covering the full cost of providing public water supply.

Finding #4: A number of methods are available to reduce future water needs, including (in order of implementation) updating projections that may be out of date, authorizing reasonable additive factors to be included in available water when calculating MOS for MMADD, implementing targeted water conservation and water efficiency measures, developing interconnections or new sources to be transferred through interconnections, and developing new sources of supply. When development of new sources of supply is necessary in the future, the Central WUCC has several utilities which can be encouraged to continue evaluating potentially regionally significant source of supply options.

The use of available water guidance for reservoir systems, for supplemental supply wells, and for interconnections that applies a maximum month flow rate that is higher than the annual average flow rate would be helpful for making the calculation of available water consistent with real-world applications. One example of potential guidance for reservoir systems was promulgated in the *Integrated Report* based on monthly withdrawal ratios used in the safe yield model. The exercise demonstrated that the CWC-Unionville system would no longer have a deficit to meet MMADD in the 5-year or 20-year planning horizon and that deficits for other systems could be reduced. The projected supply need for CWSs in the region including both passive water conservation measures and potential MMADD guidance for calculating available water to meet MMADD resulted in a reduction in supply need to 0.03 mgd, 0.4 mgd, and 2.9 mgd over the three planning horizons.

While the use of the above example of available water guidance would not eliminate the need for new sources entirely, it does demonstrate how the need for new sources could be deferred to later planning periods. This would allow utilities projecting deficits to reconsider their previous demand projections, develop targeted water conservation and water efficiency programs, and implement short-term supply measures (such as interconnections). Should the CWSP be updated on the 10-year schedule envisioned in the regulations, projected regional needs could be reevaluated prior to the 20-year planning horizon (2030) with such improvements in place.

The WUCC should coordinate with DPH on a methodology for calculation of available water and MOS to meet MMADD that is more reflective of the water actually available to provide more flexibility for the numerous caveats in supply that are unrelated to the potentially most limiting factor in the calculation.

Finding #5: The viability of small CWSs and the density of non-community systems in many areas continue to be concerns. Recent DPH efforts to identify systems with inadequate capacity have been greatly beneficial for both planning and regulatory purposes, and these efforts need to be continued.

The Capacity Assessment Tool (CAT) is being used by DPH to evaluate the technical, managerial, and financial capacity of small CWSs. The vast majority of small CWSs are considered to have overall moderate or high capacity per the CAT. General recommendations were developed for each system considered to have less than an overall high capacity, including conducting internal improvements, selling the system, or interconnecting the system. In particular, DPH has identified small community water systems managed by voluntary associations as being at high risk for having poor managerial and financial capacity, as these systems are often operated by boards or committees with high turnover and limited ability to obtain or maintain funding for capital improvements.

DPH is encouraged to continue updating the CAT for small CWSs and regularly advise ESA holders of low capacity CWSs within their ESA. DPH is encouraged to continue outreach to small CWSs with inadequate capacity, with WUCC meetings as a potential resource. Furthermore, DPH is encouraged to develop Certificate of Public Convenience and Necessity (CPCN) regulations specific to development of non-community water systems. Finally, regular education and development of a reliable funding mechanism for small CWSs are necessary in order to ensure capital improvements can be performed per the schedule for proper asset management.

Many of the smaller CWSs in the region operate with a single source of supply and no backup supply. This leaves these systems vulnerable to interrupted service due to equipment failures, contamination, and other emergencies. Even where these systems have a high CAT score, emergency interconnections would benefit these small systems. However, access to reliable funding is the most critical challenge for improving the capacity of small CWSs.

The numerous non-community systems in the region often lie adjacent to other non-community systems, thereby forming clusters. In many areas, the density of non-community water systems is quite high such that service through a consolidated system is preferred. The WUCC encourages DPH and the Water Planning Council to determine regulations and procedures to support such consolidations, and to secure funding to be distributed to support the required capital expenses for such projects. The WUCC intends to review opportunities for consolidation as new PWS are proposed.

Finding #6: The 2-year planning process has brought together a diverse group of representatives from municipal and state government, public and privately held public water systems, and regional councils of governments. This forum has enabled coordination of planning efforts and an exchange of knowledge and perspectives. Continued regular meetings by the WUCC will continue to encourage regional planning efforts.

Summary of Recommendations

Table ES-1 presents the non-capital improvement strategies developed in the *Integrated Report*. Potential capital improvement projects identified for future consideration by WUCC members include the following:

- Consolidation or interconnections of small CWSs near larger utilities where interconnection is found to be the preferred option for daily supply or for emergency purposes (Section 4.3, Section 5.3);
- Consolidation of CWC-Collinsville and CWC-Unionville systems (Section 5.3);
- Development of new supply source(s) and interconnection to serve proposed East Hampton WPCA system (Section 5.3, Section 7.1, Section 7.2);
- Extension of CWC-Guilford system and consolidation of shoreline systems (including single-wellfield systems) in Old Lyme, with interconnection to East Lyme (Section 5.3, Section 5.4), potentially through development of regionally significant sources of supply (Section 7.1);
- Development of interconnections for Southington Water Department (Section 5.3, Section 5.4);
- Development of interconnection between Middletown Water Department and Connecticut Valley Hospital, which utilizes a single distribution reservoir (Section 5.4);
- Development of an interconnection with WWW, which utilizes a single reservoir (Section 5.4);

TABLE ES-1: Prioritization and Implementation of Non-Capital Improvement Recommendations

Topic Area	Goal	Recommended Strategies for Central WUCC	Lead(s)	Timeframe	
Responsible Planning	Prevent proliferation of water systems when other options are available	1. Encourage WUCC members to petition the WUCC for revision of ESA boundaries where appropriate to prevent creation of unnecessary consecutive water systems across ESA boundaries	WUCC	Ongoing	
		2. As part of the process for providing a recommendation on the development of new water systems, evaluate the proximity of other nearby water systems and the potential for consolidating the proposed water system with an existing water system	WUCC	Ongoing	
		3. Encourage DPH and the Water Planning Council to address, through regulations and/or procedures, the proliferation of multiple water systems in close proximity to one another	WUCC	Immediately	
	Work towards constructive changes to statutes and regulations		4. Explore and provide recommendations regarding appropriate modifications to the definition of available water to allow for reasonable additive factors (contract maximums, supplemental sources, demand ratios from safe yield models, etc.) to be included when calculating MOS for MMADD	WUCC, DPH	Immediately
			5. Explore and provide recommendations to streamline the sale of excess water permit process and eliminate the requirement in certain instances to foster regionalization	WUCC, DPH	By 2023
			6. Review the state minimum design criteria for new public water systems every 5 years to ensure the development of reliable water systems with proper technical, managerial, and financial capacity	WUCC, DPH	1st Review By 2023
			7. Support DPH's efforts to develop regulations to ensure the standardized and consistent development of new non-community water systems	WUCC	Immediately
			8. Consider development of a streamlined CPCN process for small utilities desiring a minimal degree of expansion instead of the 5-percent rule	WUCC, DPH	By 2023
			9. Review data requirements for WSPs, CWSPs, and state water planning needs (e.g. basin-level withdrawal and return flow data) to determine if revisions to the data requirements are necessary to ensure submission of data that is useful for multiple planning purposes	WUCC, DPH, DEEP	By 2030
			10. Re-evaluate the timing of regional capital improvements as the results of system-specific safe yield revisions accounting for full implementation of the Streamflow Standards and Regulations become available	WUCC, Utilities	By 2023
	Develop and use best-available data		11. Update in the CWSP the projected demands as new individual WSPs are completed and incorporate into the regional projections including the refinement of the impacts of the Streamflow Regulations	WUCC, DPH	Ongoing
			12. Provide annual updates to the WUCC on the status of small systems based on the CAT	DPH, WUCC	Ongoing
			13. Keep WUCC informed regarding potentially regionally significant water supply sources	Utilities	Ongoing
			14. Revise water demand projections that may be out of date	Utilities	By 2023
			15. Encourage utilities utilizing local design standards to adopt such standards, provide them in written format to developers at the beginning of the CPCN process, and reference such standards in a development agreement	WUCC	By 2023
			16. Provide Geographic Information System data appropriate for regional planning to COGs, including ESA boundaries and general public water system service locations (such as spatial data presented in the CWSP)	DPH	Immediately, Ongoing
			17. Review and improve accuracy of spatial data regarding the locations of non-community water systems	DPH	By 2023
			18. Consider requiring all public water systems to report water usage on an annual basis	DPH, WUCC	By 2023
			19. Encourage PURA and DPH to develop a risk-based approach to be used to better evaluate the condition of systems and apply projected costs into takeover and ratemaking proceedings	WUCC	By 2030
			20. Require training in asset management and related recordkeeping for small water system owners	DPH	By 2023
	Improve education of small system owners		21. Encourage small system owners to self-evaluate their status and consider implementation of one or more options based on the recommendations in Section 4.3 and have DPH annually report on the status of such actions to the WUCC	DPH, WUCC	Ongoing
			22. Work with small water systems owned and operated by voluntary associations to determine pathways for improving technical, managerial, and financial capacity and have DPH annually report on the status of such actions to the WUCC	DPH, WUCC	Ongoing
			23. Encourage small systems to work with nonprofit organizations such as RCAP Solutions or the ASRWVA to increase managerial capacity such as for asset management and have DPH annually report on the status of such actions to the WUCC	DPH, WUCC	Ongoing
			24. Encourage ESA holders to coordinate and work with the small CWSs within their respective ESAs	WUCC, DPH	Ongoing
			25. Provide education and oversight regarding management of non-community systems	DPH	Ongoing
	Foster and support interagency planning between utilities, COGs, municipalities, and state government		26. Develop strategies to involve small CWSs and non-community water systems in the WUCC planning process	WUCC, DPH	Ongoing
			27. Encourage local municipalities to consider the following in their POCDs: ESAs, future water service extension potential, desired public water service areas, and water management through zoning regulations	COGs	Ongoing
Drought Management	Consider methods to improve enforcement of water use restrictions	28. Work with agencies and committees considering drought management to evaluate the model ordinance and consider legislative authority for water utilities to enforce restrictions under certain conditions	WUCC	By 2023	
	Consider methods to improve timing of activation of drought triggers and water use restrictions	29. Work with agencies and committees considering drought management to evaluate trigger criteria, forecasting models, and other methods to coordinate drought planning and response	WUCC	By 2023	

TABLE ES-1: Prioritization and Implementation of Non-Capital Improvement Recommendations

Topic Area	Goal	Recommended Strategies for Central WUCC	Lead(s)	Timeframe	
Source Protection	Encourage prudent development and conservation of existing large, protected watersheds	30. Implement the DWQMP process (potential candidate utilities include CWC, MDC, SCCRWA, and WWW)	Utilities, DPH	By 2023	
		31. Pursue modification of CGS 8-30g to more strongly consider source water protection concerns in reservoir watersheds and APAs	DPH	By 2023	
		32. Coordinate with local planners during POCD updates to identify areas of development density that may be incompatible with reservoir watersheds and APAs and to coordinate with other watershed towns regarding source protection planning	Utilities, COGs	Ongoing	
	Improve stormwater quality in watersheds and aquifer recharge areas	33. Promote the adoption of best management practices for the use of green infrastructure in stormwater management design and rainwater capture for landscaping	Utilities	By 2023	
		34. Improve collaboration with local plowing contractors, public works staff, and the State Department of Transportation to minimize chloride impacts to public water supply sources	Utilities	By 2023	
Consider methods to improve enforcement capabilities	35. Evaluate and provide recommendations regarding methods of improving enforcement to prevent activities on private property that may lead to reservoir or aquifer contamination	WUCC	By 2023		
Water Conservation	Consider and encourage methods for water systems to utilize to enhance water efficiency	36. Explore and provide recommendations regarding various methods of reducing unaccounted-for water	WUCC	Ongoing	
		37. Explore and provide recommendations regarding the use of alternative methods for tracking water usage, water loss, and waste	WUCC	Ongoing	
		38. Explore and provide recommendations regarding the use of outdoor water use restrictions to be applied seasonally	WUCC	Ongoing	
		39. Encourage utilities to modify rate structures to promote water conservation while covering the full cost to provide water	WUCC	Ongoing	
		40. Annually identify opportunities for the purchase and joint use of water-saving equipment, such as truck-mounted flushing systems which flush mains without blowing off water to waste	WUCC	Ongoing	
	Consider alternative means to supply nonpotable uses	41. Develop and enact targeted water conservation and water efficiency programs	Utilities, DPH	By 2023	
		42. Encourage the use of Class B water for nonpotable uses within service area boundaries	WUCC, DPH	Ongoing	
	Consider legislation to improve water conservation	43. Encourage the use of gray water reuse systems in new developments to reduce demands on potable water (e.g. include on local development review checklist)	WUCC, DPH	Ongoing	
		44. Explore and provide recommendations regarding state and local legislation to further regulate demand-side water conservation	WUCC, DPH	By 2030	
Encourage dissemination of water conservation information	45. Encourage local planners to include discussions in POCDs on the importance of water conservation	COGs, Utilities	Ongoing		
Resiliency	Ensure methods of calculating safe yield are consistent with climate change	46. Review safe yield regulations every 10 years to determine if data inputs (e.g., evaporation rate) and assumptions continue to be valid in light of the effects of climate change on rainfall and runoff patterns, and revise regulations if necessary	WUCC, DPH	1st Review By 2030	
		47. Encourage DEEP/USGS to monitor regional groundwater levels to detect trends that may impact safe yield	WUCC	Ongoing	
	Correct disparities in existing regulations	48. Update the public health code to require new wells to be elevated to the 0.2% annual chance flood elevation	DPH	By 2030	
		Improve resiliency of public water systems	49. Develop redundant infrastructure, backup power, and increase system storage and conduct more comprehensive emergency response planning to improve resiliency	Utilities	Ongoing
			50. Encourage small systems with the potential to develop emergency interconnections to do so	DPH, WUCC	Ongoing
			51. Initiate planning for development of interconnections or new supply sources for systems with only one source of supply (reservoir or wellfield)	WUCC, Utilities	By 2023
			52. Develop procedures and secure permits to promote regional use of supplies during short-term planned and unplanned events resulting in loss of supply (e.g. Intra-Regional Water Supply Response Plan for Southeastern Connecticut)	WUCC, Utilities	Ongoing
		53. Assist systems in conducting asset management planning and developing formal infrastructure replacement programs	DPH	Ongoing	
Develop and use best-available data	54. Re-evaluate reservoir release requirements in light of changing rainfall and runoff patterns as USGS StreamStats is updated	Utilities	Ongoing		
Funding	Improve availability of funding for desirable projects	55. Develop a dedicated source of grant funding to allow for the consolidation of small water systems located in close proximity	DPH	Immediately	
		56. Develop a dedicated source of grant funding to allow for infrastructure projects to improve resiliency, such as allowing existing and new interconnections to operate in two directions where appropriate	DPH	Immediately	
		57. Provide funding assistance for Councils of Government staff to monitor and inform local land use commissions regarding source water protection, ESA boundaries, and regional water supply challenges	DPH, OPM	Immediately	
		58. Conduct regular seminars on financial management and the types of funding available for capital improvement projects	DPH	Ongoing	
		59. Develop a dedicated source of grant funding for small system improvements	DPH	Immediately	
		60. Develop a dedicated source of grant funding for regional water supply solutions	DPH	Ongoing	
		61. Improve the accessibility of DWSRF loans for small water systems, such as through a streamlined process for certain types of improvements	DPH	Immediately	
		62. Encourage DPH and the Water Planning Council to develop a dedicated source of funding to support periodic updates to the regional WUCC data to reflect updated safe yield calculations and individual utility projections	WUCC	Immediately	
	Encourage joint use arrangements to reduce costs	63. Encourage the use of the Intertown Capital Equipment Purchase Incentive Program (for municipal systems) as well as other arrangements to share equipment, resources, and operational staff and increase purchasing power	WUCC	Ongoing	

- Development of emergency interconnections to extend the regionally interconnected water system in the region (utilities to consider interconnections include the Aquarion Water Company (AWC) – Simsbury and Avon Water Company, AWC – Simsbury and Salmon Brook District Water Department, Berlin Water Control Commission and Meriden Water Division, Connecticut Correctional Institute and CWC – Western, Cromwell Fire District and MDC, Hazardville Water Company and CWC – Western, Manchester Water Department and CWC – Western and/or MDC, Middletown Water Department with Berlin Water Control Commission and Cromwell Fire District, Wallingford Water Division and Meriden Water Division (Section 5.4);
- Interconnecting with or consolidating small CWSs or non-community systems along or near the installation route of an interconnection project (Section 5.4); and
- Joint development of new supply sources by multiple utilities (Section 6.1).



1.0 THE COORDINATED WATER SYSTEM PLANNING PROCESS

Connecticut's public water supply planning process was prompted by the state's extended drought in the early 1980s. During the 1985 legislative session, the Connecticut General Assembly passed Public Act 85-535, "*An Act Concerning a Connecticut Plan for Public Water Supply Coordination*," initiating the first statewide water supply planning program. The DPH in consultation with the Public Utilities Regulatory Authority (PURA), the Connecticut Department of Energy and Environmental Protection (DEEP), and Office of Policy and Management (OPM) was given the charge of developing a coordinated approach to long-range water supply planning to assure future supplies. The legislative finding, as reflected in Connecticut General Statutes (CGS) Section 25-33c, states the following: "*In order to maximize efficient and effective development of the state's public water supply systems and to promote public health, safety, and welfare, the DPH shall administer a procedure to coordinate the planning of public water supply systems.*"

Pursuant to Public Act 85-535 and Section 25-33e of the Connecticut General Statutes (CGS), the boundaries of seven PWSMAs were delineated based upon the similarity of water supply issues, population density and distribution, existing sources of public water supply, service areas or franchise areas, existing interconnections between public water systems, municipal and regional planning agency boundaries, natural drainage basins, and similar topographic and geologic characteristics. The boundaries of the seven PWSMAs originally established in 1986 were consolidated in October 2014 to the three regions in existence today.

The CGS require that the Commissioner of DPH convene a WUCC for each PWSMA to implement the areawide water supply planning process. A WUCC consists of one representative from each public water system with a source of water supply or service area within the PWSMA and one representative from each regional planning agency within such area who is elected by majority vote of the chief elected officials of the municipalities that are members of such regional planning agency.

A Coordinated Water System Plan (CWSP) is comprised of the individual WSPs of the public water systems within the PWSMA that serve over 1,000 people or have 250 or more service connections, and an areawide supplement that includes a *Water Supply Assessment (WSA)*, delineation of Exclusive Service Area (ESA) boundaries, an *Integrated Report*, and an *Executive Summary*. The purpose of the CWSP is to do the following:

1. Identify the present and future water system concerns.
2. Analyze alternatives.
3. Set forth a means for meeting the identified needs.

The major components of the CWSP are described below:

Individual Water Supply Plans – Each CWS that serves more than 1,000 people or 250 service connections is required to prepare an individual WSP under Section 25-32d of the Regulations of Connecticut State Agencies (RCSA). The individual WSPs are in various stages of development and DPH approval as WSPs are generally required to be updated every 5 to 9 years. The principal goals of individual water system planning as defined by the DPH are to do the following:

1. Ensure an adequate quantity of pure drinking water now and in the future.
2. Ensure orderly growth of individual water systems.
3. Make efficient use of available resources.

Water Supply Assessment – The first of the four components of the areawide supplement. The purpose of the WSA is to evaluate existing conditions and deficiencies within the PWSMA. The Final WSA was completed and approved by the WUCC, with the final document published in December 2016.

Exclusive Service Area Boundaries – An ESA is an area where public water is supplied by one system. Numerous factors are considered in determining ESA boundaries, including existing service areas; land use plans, zoning regulations, and growth trends; physical limitations to water service; political boundaries; water company rights as established by statute, special act, or administrative decision; system hydraulics, including potential elevations or pressure zones; and ability of a water system to provide a pure and adequate supply of water now and into the future. The *Final Recommended ESA Boundaries* document was completed and approved by the WUCC in June 2017. This document will be amended as necessary by the WUCC per the procedures in its Work Plan as ESA boundary modifications occur.

Integrated Report – The *Integrated Report* is a long-term planning tool for the PWSMA. Various issues are evaluated in the *Integrated Report*, including existing and future projected populations, existing and alternative water supplies, source protection, water conservation, existing and potential interconnections, system ownership and management, satellite management/ownership issues, minimum design standards, financial considerations, potential impacts on other uses of water resources (including water quality, flood management, recreation, hydropower, and aquatic habitat issues), and land acquisition for proposed wells in stratified glaciofluvial deposits. The *Final Integrated Report* was completed and approved by the WUCC in June 2018.

Executive Summary – The *Final Executive Summary*, the subject document, provides an abbreviated overview of the CWSP for the PWSMA. It is a factual and concise summary of the major elements of the CWSP.



2.0 COMPOSITION OF THE PUBLIC WATER SUPPLY MANAGEMENT AREA

The Central Connecticut PWSMA encompasses all of the towns that are included within the boundaries of the Capitol Region Council of Governments (CRCOG), South Central Region Council of Governments (SCRCOG), and the Lower Connecticut River Valley Council of Governments (RiverCOG) regional councils of government. The boundaries of the PWSMA are generally defined by the Massachusetts state boundary to the north; the boundaries of the Western PWSMA and the Eastern PWSMA to the west and east, respectively; and Long Island Sound to the south. The towns within the Central PWSMA are listed in Table 1, with towns along the western and eastern boundaries denoted by an asterisk as these communities may coordinate on water supply issues with towns or utilities in the Western or Eastern PWSMAs. In total, the Central PWSMA comprises 70 towns.

TABLE 1
Central PWSMA Towns

Central PWSMA Towns				
Andover	Durham	Haddam	New Britain	Southington*
Avon*	East Granby	Hamden*	New Haven	Stafford^
Berlin	East Haddam^	Hartford	Newington	Suffield
Bethany*	East Hampton^	Hebron^	North Branford	Tolland
Bloomfield	East Hartford	Killingworth	North Haven	Vernon
Bolton	East Haven	Lyme^	Old Lyme^	Wallingford*
Branford	East Windsor	Madison	Old Saybrook	West Hartford
Canton*	Ellington	Manchester	Orange*	West Haven
Chester	Enfield	Mansfield^	Plainville*	Westbrook
Clinton	Essex	Marlborough^	Portland	Wethersfield
Columbia^	Farmington*	Meriden*	Rocky Hill	Willington^
Coventry^	Glastonbury	Middlefield	Simsbury	Windsor
Cromwell	Granby*	Middletown	Somers	Windsor Locks
Deep River	Guilford	Milford*	South Windsor	Woodbridge*

*Denotes municipality that is on the border with the Western PWSMA

^Denotes municipality that is on the border with the Eastern PWSMA

The Central Connecticut PWSMA consists of 951 public water systems as of September 2017. Refer to Appended Figure 1 for a map depicting the general locations of these systems. Of these:

- 200 are regulated as community water systems (CWSs).
- 222 are regulated as non-transient non-community (NTNC) water systems.
- 529 are regulated as transient non-community (TNC) water systems.

The vast majority of public water systems in the region are small systems serving less than 50 people per day associated with small residential developments and small businesses. A total of 34 CWSs are considered to be “large” systems required to submit WSPs to DPH.



3.0 SUMMARY OF THE WATER SUPPLY ASSESSMENT

The Final WSA for the Central PWSMA was published in December 2016. The document presented an inventory of existing CWSs with respect to historic water quality, system reliability, service and supply adequacy, firefighting capabilities, and major facilities. A brief summary of that document is presented below.

Finished Water Quality

The quality of drinking water supplied by public water systems in Central Connecticut to their customers is generally excellent. The vast majority of violations are monitoring or reporting violations rather than maximum contaminant level (MCL) violations. Additionally, most violations are one-time occurrences. There are some areas where arsenic, uranium, radon, and other constituents are of concern.

System Reliability

System reliability of large public water systems in the Central PWSMA is considered to be generally good. At the time of the WSA (data through 2015), most public water systems serving greater than 1,000 people had multiple sources of supply and/or emergency/backup supplies. Twenty-one out of 34 of these systems currently have interconnections with another system. Additionally, all of the large public systems serving more than 1,000 people had emergency power availability and an average-day MOS that was greater than the recommended 1.15. Only four such systems had a maximum month average-day margin of safety that was less than 1.15. For one of these systems (UConn), a new interconnection source of supply was recently constructed. Four systems had a peak-day margin of safety that was less than 1.15.

DPH has recently implemented a program known as the Capacity Assessment Tool (CAT) for small CWSs that serve fewer than 1,000 people. Of the 129 small community systems in the Central PWSMA that had been evaluated at the time of the WSA, 8 percent of the systems were rated to be lacking adequate capacity, 50 percent were rated to have moderate capacity, and 42 percent were rated to have adequate capacity. The long-term goal of the CAT program is to enable DPH to target specific types of assistance to individual small CWSs.

Existing and Future Sources of Supply

Thirteen of the 34 systems serving more than 1,000 people maintain active reservoir supplies. Only five of these rely solely on reservoir supplies. Most of the public water served through these systems comes from groundwater supplies. Ten systems that currently supply more than 1,000 people have indicated a potential need for developing additional water supplies within the 5-year planning period as reported in their individual WSPs (dates of publication vary). Twenty-three systems identify a potential long-term need (i.e., within the 50-year planning period), which is considered in more detail in the *Integrated Report*. Six reported no short-term or long-term future supply needs.

Fire Protection

All of the towns and cities in Connecticut maintain some form of fire protection for residents and businesses. Some of these municipalities rely in part on community public water systems in the area. The majority of larger systems have adequate pressure and system components to provide some form of fire protection to customers within their supply area. Most of the smaller community systems provide little or no fire protection.

Population and Land Use

Population centers within the Central PWSMA include Hartford and New Haven, with greater than 80,000 people, and Enfield, West Hartford, East Hartford, Manchester, New Britain, Southington, Meriden, Middletown, Wallingford, Hamden, West Haven, and Milford, with populations between 40,000 and 80,000 people. The lowest population areas within the region include Bolton, Andover, Middlefield, Chester, Deep River, and Lyme, with populations of fewer than 5,000 people according to the 2010 Census.

Seventy-eight percent of the land area in the Central PWSMA is undeveloped; 22 percent is developed, with concentrations along the Connecticut River Valley and the shoreline. Growth trends in the region reflect the housing boom of the late 1990s and early 2000s, followed by the Great Recession and postrecession recovery in 2006 to 2015.

Status of Planning

Most water utilities have a WSP that has been approved in the last 5 years, and POCDs have been prepared in all member towns. Most were adopted within the last 10 years. Most community plans, such as zoning regulations and POCDs, also include pertinent information that defines allowable and anticipated uses in watershed areas. These plans often designate land uses in critical areas associated with public supply groundwater wells.

Smaller non-municipally owned community public water systems tend to have less opportunity for inclusion in broader planning objectives. Protection of these smaller systems often depends entirely on ownership of the land surrounding the source and state regulations that have established minimum allowable distances between a point source of pollution and a community groundwater supply.

Issues, Needs, and Deficiencies in the Region

Various issues, needs, and deficiencies were identified for the Central PWSMA in 2016 via data research, correspondence, and discussions with WUCC members, agency staff, and interested parties. Some of the issues that are currently facing the region include the projected need for future supply sources, the need for water supply planning coordination, the reliable quality of groundwater supplies, source protection, vulnerability of single source suppliers, viability of small community public water systems, discontinuity of service, growth trends and impacts, the impact of existing and future anticipated regulations, the need to balance raw and finished water supplies throughout the region, interconnections, and land use compatibility.



4.0 EXCLUSIVE SERVICE AREA BOUNDARIES

ESA boundaries delineate existing and potential service areas for a water system. The authority to assign franchise areas and authorizations to provide water service to water systems rests with the state legislature. Numerous water companies and utilities were granted charters or otherwise authorized by acts of the state legislature beginning in the late 18th century, resulting over time in areas where water service could be provided by more than one utility in the same area. ESA boundaries are designed to eliminate overlapping franchise and charter service areas, to prevent situations where more than one large public water system serves in the same area, and to identify responsible service providers to meet future service needs.

Establishment of boundaries for ESA holders is intended to ensure that safe and adequate drinking water is available to areas of the state where public water supply is needed. ESA designations are established based on the regulatory criteria and are based upon the agreement by a utility or municipality to serve, as necessary, previously identified unserved areas in accordance with applicable state statutes and regulations. Existing service areas (i.e., areas where service is currently being provided) were maintained and automatically received ESA designations via the delineation process. As part of this process, each public water system and municipality in the Central PWSMA was provided the opportunity to request ESA designations beyond their existing system boundaries that cover areas currently unserved by public water supply.

The Central PWSMA inherited the ESA boundary delineations established under CGS Section 25-33g for the former Southeastern Connecticut WUCC, South Central WUCC, and Upper Connecticut River WUCC. The ESA boundary delineations for the former Southeastern Connecticut WUCC were finalized in March 2001 and ultimately approved by DPH, while the remaining ESA boundaries were recommended as part of unapproved CWSPs developed in the late 1980s. Several modifications were approved by the former WUCCs prior to the consolidation of the former regions into the Central PWSMA in 2014. These modifications are incorporated into this document. Future ESA modifications will be processed by the Central WUCC in accordance with the procedures specified in its Work Plan.

Being an ESA holder is a commitment to ownership and service for newly constructed public water supply needs for CWSs (essentially, residential public water supply needs), and, in general, a right of first refusal for non-community water systems (non-residential) public water supply needs. An ESA designation therefore conveys both a right and a responsibility to provide public water service pursuant to applicable state law. Section 3.0 of the *Final Recommended ESA Boundaries* document outlines the rights and responsibilities of ESA holders in more detail.

Although an ESA provider is designated, actual development and service expansion should support the direction set by municipal land use and development goals while being cognizant of the impacts that such land use and development goals have on protecting water resources, timely water service, water quality, economically priced water, and strong professional management of water supplies. Municipalities retain their ability to provide guidance for development within their borders through their local government structure and planning documents, such as municipal plans of development, ordinances, and zoning regulations. When a project is proposed at or near an ESA boundary, such boundary should be modified when such modification is determined to be the appropriate solution for providing public water service to a location.

Table 2 presents the recommended ESA providers by town. Recommended ESA boundaries are delineated in the appended mapping.

TABLE 2
Final Recommended ESA Holders in Central PWSMA

Geographic Area	ESA Holders for Unserved Areas
Andover	AWC for all unserved areas in Andover
Avon	Avon Water Company throughout all but the western portion of town and CWC for the western portion of town
Berlin	Berlin Water Control Commission for areas in eastern, southern, and western Berlin; Kensington Fire District for areas in Kensington Fire District; City of New Britain (New Britain Water Department) near and around its existing service area in northern Berlin; and Worthington Fire District for areas in Worthington Fire District
Bethany	SCCRWA
Bloomfield	MDC
Bolton	Town of Bolton for selected town-owned parcels. CWC for areas north of Route 44 and within 200 feet of the south side of Route 44 and for certain areas along Route 6. Remainder of town unassigned
Branford	SCCRWA
Canton	CWC for all except the northeastern corner and AWC in the northeastern corner of town
Chester	CWC
Clinton	CWC
Columbia	CWC for the area currently served by its Columbia Heights system. AWC for the remainder of town.
Coventry	Town of Coventry for town-owned parcels with existing water systems. CWC for the remainder of Coventry.
Cromwell	Cromwell Fire District
Deep River	CWC
Durham	Town of Durham for all areas generally in the northern portion of Durham and CWC for all areas generally in southern Durham
East Granby	CWC for eastern edge of town; MDC for northwest, north, central, east-central, and southern parts of town; and AWC for southwestern East Granby
East Haddam*	Town of East Haddam with the exception of the area immediately surrounding the CWC Banner Village and CWC Lake Hayward systems to be served by CWC
East Hampton	Town of East Hampton (WPCA) for entire town* with the exception of an area east of Lake Pocotopaug near the CWC Baker Hill Division assigned to CWC* and AWC for the northernmost area in East Hampton
East Hartford	MDC
East Haven	SCCRWA
East Windsor	CWC
Ellington	CWC
Enfield	CWC in western and northern Enfield and the southeastern corner of Enfield; Hazardville Water Company in central, southern, and eastern Enfield
Essex	CWC
Farmington	MDC for a portion of eastern Farmington, City of New Britain (New Britain Water Department) for much of southeastern Farmington, CWC in all of central and western Farmington, and Valley Water Systems for a small area in southeastern Farmington

TABLE 2
Final Recommended ESA Holders in Central PWSMA

Geographic Area	ESA Holders for Unserved Areas
Glastonbury	MDC for most of Glastonbury with the exception of the Town of Manchester (Manchester Water Department) in north-central Glastonbury
Granby	AWC
Guilford	CWC
Haddam	CWC
Hamden	SCCRWA
Hartford	MDC
Hebron*	CWC
Killingworth	CWC
Lyme*	CWC
Madison	CWC
Manchester	Town of Manchester (Manchester Water Department) for all areas, except for a small area on the western border assigned to MDC
Mansfield	Windham Water Works for a specific area near its existing system in southern Mansfield. CWC for the remaining area within the Town of Mansfield. The University of Connecticut will retain its existing service area designation for its Main and Depot campus areas, with no underlying ESA, and agricultural land that is not contiguous with the existing service area at the Main and Depot campuses will remain unassigned.
Marlborough*	Town of Marlborough
Meriden	Meriden Water Division
Middlefield	Town of Middlefield
Middletown	City of Middletown (Middletown Water Department)
Milford	SCCRWA
New Britain	City of New Britain (New Britain Water Department)
New Haven	SCCRWA
Newington	MDC for the majority of town with the exception of two areas in western Newington designated for the City of New Britain (New Britain Water Department). Two areas on the western border were left unassigned.
North Branford	SCCRWA
North Haven	SCCRWA
Old Lyme*	CWC
Old Saybrook	CWC
Orange	SCCRWA
Plainville	Valley Water Systems
Portland	Town of Portland (Portland Water Department)
Rocky Hill	MDC
Simsbury	Avon Water Company for the south-central portion of Simsbury near its existing service area along the Avon boundary and AWC for the remainder of town
Somers	CWC for the northwestern, southwestern, central, southern, and southeastern parts of town, and Hazardville Water Company for the northern and western parts of town
Southington	Town of Southington (Southington Water Department) for all of the town except a small area in northeastern Southington previously assigned to the City of New Britain (New Britain Water Department) near Caretaker Road
South Windsor	CWC for the northern and eastern portions of town, and MDC for essentially the southwestern quarter of town
Stafford	CWC for all unserved areas in Stafford

TABLE 2
Final Recommended ESA Holders in Central PWSMA

Geographic Area	ESA Holders for Unserved Areas
Suffield	CWC
Tolland	CWC for areas in the northwestern portion of town, and the Town of Tolland (Tolland Water Department) for the remainder of Tolland.
Vernon	CWC for nearly all of town, except for a small area assigned to the Town of Manchester (Manchester Water Department) in southern Vernon
Wallingford	Town of Wallingford (Wallingford Water Division)
Westbrook	CWC
West Hartford	MDC
West Haven	SCCRWA
Wethersfield	MDC
Willington	CWC, except for an area of state land in southern Willington, which will remain unassigned
Windsor	MDC
Windsor Locks	CWC for most of town, except for a small area in the southeastern corner designated to MDC
Woodbridge	SCCRWA

*Denotes ESA boundaries approved by DPH that were inherited from former Southeastern WUCC



5.0 POPULATION AND WATER SUPPLY DEMAND

Historical population figures are shown in Table 3 and Figure 1. This data shows consistent growth throughout the region until the 1980s and 1990s. At that time, the urban areas began to lose population, while the suburban and rural towns, for the most part, kept increasing. Urban communities began to gain population once more between 2000 and 2010.

TABLE 3
Historical Population by Town for the Central PWSMA

Town	Classification	1960	1970	1980	1990	2000	2010
Andover	Suburban	1,771	2,099	2,144	2,540	3,036	3,303
Avon	Suburban	5,273	8,352	11,201	13,937	15,832	18,098
Berlin	Suburban	11,250	14,149	15,121	16,787	18,215	19,866
Bethany	Suburban	2,384	3,857	4,330	4,608	5,040	5,563
Bloomfield	Suburban	13,613	18,301	18,608	19,483	19,587	20,486
Bolton	Suburban	2,933	3,691	3,951	4,575	5,017	4,980
Branford	Urban	16,610	20,444	23,363	27,603	28,683	28,026
Canton	Suburban	4,783	6,868	7,635	8,268	8,840	10,292
Chester	Suburban	2,520	2,982	3,068	3,417	3,743	3,994
Clinton	Suburban	4,166	10,267	11,195	12,767	13,094	13,260
Columbia	Suburban	2,163	3,129	3,386	4,510	4,971	5,485
Coventry	Suburban	6,356	8,140	8,895	10,063	11,504	12,435
Cromwell	Urban	6,780	7,400	10,265	12,286	12,871	14,005
Deep River	Suburban	2,968	3,690	3,994	4,332	4,610	4,629
Durham	Suburban	3,096	4,489	5,143	5,732	6,627	7,388
East Granby	Suburban	2,434	3,532	4,102	4,302	4,745	5,148
East Haddam	Suburban	3,637	4,676	5,621	6,676	8,333	9,126
East Hampton	Suburban	5,403	7,078	8,572	10,428	13,352	12,959
East Hartford	Urban	43,977	57,583	52,563	50,452	49,575	51,252
East Haven	Urban	21,388	25,120	25,028	26,144	28,189	29,257
East Windsor	Suburban	7,500	8,513	8,925	10,081	9,818	11,162
Ellington	Suburban	5,580	7,703	9,711	11,197	12,921	15,602
Enfield	Urban	31,464	46,189	42,695	45,532	45,212	44,654
Essex	Suburban	4,057	4,911	5,078	5,904	6,505	6,683
Farmington	Suburban	10,813	14,390	16,407	20,608	23,641	25,340
Glastonbury	Suburban	14,497	20,651	24,327	27,901	31,876	34,427
Granby	Suburban	4,968	6,150	7,956	9,369	10,347	11,282
Guilford	Suburban	7,913	12,033	17,375	19,848	21,398	22,375
Haddam	Suburban	3,466	4,934	6,383	6,769	7,157	8,346
Hamden	Urban	41,056	49,357	51,071	52,434	56,913	60,960
Hartford	Urban	162,178	158,017	136,392	139,739	121,578	124,775
Hebron	Suburban	1,819	3,815	5,453	7,079	8,610	9,686
Killingworth	Suburban	1,098	2,435	3,976	4,814	6,018	6,525
Lyme	Rural	1,183	1,484	1,822	1,949	2,016	2,406
Madison	Suburban	4,567	9,768	14,031	15,485	17,858	18,269
Manchester	Urban	42,102	47,994	49,761	51,618	57,740	58,241
Mansfield	Suburban	14,638	19,994	20,634	21,103	20,720	26,543

TABLE 3
Historical Population by Town for the Central PWSMA

Town	Classification	1960	1970	1980	1990	2000	2010
Marlborough	Suburban	1,961	2,991	4,746	5,513	5,709	6,404
Meriden	Urban	51,850	55,959	57,118	59,479	58,244	60,868
Middlefield	Suburban	3,255	4,132	3,796	3,925	4,203	4,425
Middletown	Urban	33,250	36,924	39,040	42,762	43,167	47,648
Milford	Urban	41,662	50,858	50,898	49,938	52,305	52,759
New Britain	Urban	82,201	83,441	73,840	75,491	71,538	73,206
New Haven	Urban	152,048	137,707	126,109	130,474	123,626	129,779
Newington	Urban	17,664	26,037	28,841	29,208	29,306	30,562
North Branford	Suburban	6,771	10,778	11,554	12,996	13,906	14,407
North Haven	Urban	15,935	22,194	22,080	22,247	23,035	24,093
Old Lyme	Suburban	3,068	4,964	6,159	6,535	7,406	7,603
Old Saybrook	Suburban	5,274	8,468	9,287	9,552	10,367	10,242
Orange	Suburban	8,547	13,524	13,237	12,830	13,233	13,956
Plainville	Urban	13,149	16,733	16,401	17,392	17,328	17,716
Portland	Suburban	7,496	8,812	8,383	8,418	8,732	9,508
Rocky Hill	Urban	7,404	11,103	14,559	16,554	17,966	19,709
Simsbury	Suburban	10,138	17,475	21,161	22,023	23,234	23,511
Somers	Suburban	3,702	6,893	8,473	9,108	10,417	11,444
South Windsor	Suburban	9,460	15,553	17,198	22,090	24,412	25,709
Southington	Urban	22,797	30,946	36,879	38,518	39,728	43,069
Stafford	Suburban	7,476	8,680	9,268	11,091	11,307	12,087
Suffield	Suburban	6,779	8,634	9,294	11,427	13,552	15,735
Tolland	Suburban	2,950	7,857	9,694	11,001	13,146	15,052
Vernon	Urban	16,961	27,237	27,974	29,841	28,063	29,179
Wallingford	Urban	29,920	35,714	37,274	40,822	43,026	45,135
West Hartford	Urban	62,382	68,031	61,301	60,110	63,589	63,268
West Haven	Urban	43,002	52,851	53,184	54,021	52,360	55,564
Westbrook	Suburban	2,399	3,820	5,216	5,414	6,292	6,938
Wethersfield	Urban	20,561	26,662	26,013	25,651	26,271	26,668
Willington	Suburban	2,005	3,755	4,694	5,979	5,959	6,041
Windsor	Suburban	19,467	22,502	25,204	27,817	28,237	29,044
Windsor Locks	Urban	11,411	15,080	12,190	12,358	12,043	12,498
Woodbridge	Suburban	7,673	7,673	7,761	7,924	8,983	8,990

Source: U.S. Census Bureau 1960 through 2010

Figure 5-1: Population Growth by Town
Classification: Central PWSMA




Table 4 presents future projections by town for the Central PWSMA. This data has been published by the Connecticut State Data Center (CT SDC) and interpolated where necessary (process described in the *Integrated Report*) to meet the required planning horizons. Note that actual population growth and decline over these planning periods may be more diffuse in some areas and more concentrated in other areas than presented in this report.

TABLE 4
Population Projections by Town for the Central PWSMA

Town	Classification	2010 Pop.	CT SDC 2015 Pop.	2023 Pop. Proj.	CT SDC 2030 Pop. Proj.	CT SDC 2040 Pop. Proj.	2060 Pop. Proj.
Andover	Suburban	3,303	3,261	3,069	2,864	2,550	2,550
Avon	Suburban	18,098	19,226	20,333	21,585	25,704	30,845
Berlin	Suburban	19,866	20,070	20,311	20,470	20,297	20,297
Bethany	Suburban	5,563	5,686	5,695	5,645	5,415	5,415
Bloomfield	Suburban	20,486	20,499	20,521	20,555	20,152	20,152
Bolton	Suburban	4,980	4,831	4,511	4,212	3,720	3,720
Branford	Urban	28,026	27,080	25,787	24,768	22,605	22,605
Canton	Suburban	10,292	10,672	10,966	11,107	11,461	11,801
Chester	Suburban	3,994	3,982	3,803	3,629	3,313	3,313
Clinton	Suburban	13,260	12,784	11,860	10,942	9,484	9,484
Columbia	Suburban	5,485	5,539	5,471	5,368	5,053	5,053
Coventry	Suburban	12,435	12,419	12,036	11,532	10,605	10,605
Cromwell	Urban	14,005	14,365	14,897	15,397	16,160	17,955
Deep River	Suburban	4,629	4,458	4,114	3,795	3,201	3,201
Durham	Suburban	7,388	7,509	7,394	7,180	6,791	6,791
East Granby	Suburban	5,148	5,252	5,325	5,341	5,306	5,306
East Haddam	Suburban	9,126	9,233	9,063	8,814	8,165	8,165
East Hampton	Suburban	12,959	13,403	13,546	13,049	11,543	11,543
East Hartford	Urban	51,252	52,053	54,147	56,260	58,550	63,415
East Haven	Urban	29,257	29,248	29,409	29,594	28,958	28,958

TABLE 4
Population Projections by Town for the Central PWSMA

Town	Classification	2010 Pop.	CT SDC 2015 Pop.	2023 Pop. Proj.	CT SDC 2030 Pop. Proj.	CT SDC 2040 Pop. Proj.	2060 Pop. Proj.
East Windsor	Suburban	11,162	11,802	13,193	14,459	16,011	18,945
Ellington	Suburban	15,602	16,811	18,582	20,018	21,951	25,011
Enfield	Urban	44,654	43,779	42,779	41,980	40,015	40,015
Essex	Suburban	6,683	6,505	6,094	5,703	5,082	5,082
Farmington	Suburban	25,340	25,398	25,526	25,773	26,150	27,665
Glastonbury	Suburban	34,427	34,920	34,676	34,366	35,939	41,929
Granby	Suburban	11,282	11,333	10,690	10,074	10,051	10,051
Guilford	Suburban	22,375	22,553	22,010	21,463	21,853	24,204
Haddam	Suburban	8,346	8,681	8,825	8,782	8,630	8,630
Hamden	Urban	60,960	61,263	63,808	66,758	70,408	80,623
Hartford	Urban	124,775	124,899	127,205	128,982	126,849	126,849
Hebron	Suburban	9,686	9,660	9,239	8,484	7,889	7,889
Killingworth	Suburban	6,525	6,522	6,102	5,681	4,955	4,955
Lyme	Rural	2,406	2,499	2,607	2,697	2,742	2,742
Madison	Suburban	18,269	18,266	17,003	16,068	16,261	19,513
Manchester	Urban	58,241	60,155	64,436	68,487	73,036	81,697
Mansfield	Suburban	26,543	26,706	27,338	27,800	29,416	33,756
Marlborough	Suburban	6,404	6,357	6,113	5,749	5,217	5,217
Meriden	Urban	60,868	61,835	63,567	65,180	66,146	66,366
Middlefield	Suburban	4,425	4,446	4,417	4,395	4,333	4,333
Middletown	Urban	47,648	48,319	51,105	54,018	57,666	66,644
Milford	Urban	52,759	51,958	50,534	49,331	46,897	46,897
New Britain	Urban	73,206	73,733	76,367	78,909	80,989	83,832
New Haven	Urban	129,779	131,871	137,305	141,795	143,914	143,914
Newington	Urban	30,562	30,804	31,603	32,578	34,158	39,102
North Branford	Suburban	14,407	14,182	13,512	12,858	11,855	11,855
North Haven	Suburban	24,093	24,020	23,691	23,433	23,245	23,245
Old Lyme	Suburban	7,603	7,437	6,998	6,621	6,040	6,040
Old Saybrook	Suburban	10,242	9,789	8,883	8,123	6,987	6,987
Orange	Suburban	13,956	13,844	13,746	13,682	14,075	15,781
Plainville	Urban	17,716	17,689	17,738	17,845	17,652	17,652
Portland	Suburban	9,508	9,695	9,833	9,965	10,145	10,553
Rocky Hill	Urban	19,709	20,450	21,839	23,143	24,926	28,832
Simsbury	Suburban	23,511	23,321	22,217	21,874	23,574	28,289
Somers	Suburban	11,444	11,665	11,661	11,543	11,330	11,330
South Windsor	Suburban	25,709	25,459	24,614	24,018	23,389	23,389
Southington	Urban	43,069	43,597	43,602	43,160	42,639	42,639
Stafford	Suburban	12,087	12,130	12,108	11,968	11,496	11,496
Suffield	Suburban	15,735	16,199	16,721	17,002	17,458	17,527
Tolland	Suburban	15,052	15,244	14,548	13,409	12,295	12,295
Vernon	Urban	29,179	29,485	30,372	31,117	31,375	31,375
Wallingford	Urban	45,135	45,068	44,972	44,988	44,313	44,313
West Hartford	Urban	63,268	64,301	66,196	68,342	72,685	86,103
West Haven	Urban	55,564	56,224	60,368	65,144	73,508	88,210
Westbrook	Suburban	6,938	7,048	7,072	7,059	6,911	6,911

TABLE 4
Population Projections by Town for the Central PWSMA

Town	Classification	2010 Pop.	CT SDC 2015 Pop.	2023 Pop. Proj.	CT SDC 2030 Pop. Proj.	CT SDC 2040 Pop. Proj.	2060 Pop. Proj.
Wethersfield	Urban	26,668	26,690	27,082	27,741	29,129	34,338
Willington	Suburban	6,041	6,397	6,467	6,450	5,937	5,937
Windsor	Suburban	29,044	28,721	28,399	28,225	27,498	27,498
Windsor Locks	Urban	12,498	12,487	12,618	12,766	12,633	12,633
Woodbridge	Suburban	8,990	8,654	8,015	7,497	6,599	6,599
Totals	All	1,719,645	1,732,441	1,756,653	1,779,610	1,803,285	1,918,862
	Rural	2,406	2,499	2,607	2,697	2,742	2,742
	Suburban	574,348	578,569	572,621	565,197	562,087	597,909
	Urban	1,142,891	1,151,373	1,181,425	1,211,716	1,238,456	1,318,212

Source: U.S. Census Bureau 2010; Population Projections published in 2017 by CT SDC

Notes: See Appendix C for interpolation and extrapolation of CT SDC projections.

Service population and public water supply ADD projections for the region were generated based on information supplied by representatives of the public water systems. Demands were analyzed for existing conditions as well as the 5-, 20- and 50-year planning periods in the *Integrated Report*. Table 5 summarizes the projections by each ESA holder in the PWSMA. The supplies and demands considered in Table 5 include small satellite systems within the outer ESA boundary of each ESA holder. For example, CWC systems in Marlborough are included within the data for the Town of Marlborough’s ESA.

The regional margin of safety for ADD is above 1.15 for all planning horizons. However, available supply is not always in the location of need. Several systems are projecting deficits of supply within their ESAs in each planning period. Fortunately, each system in need is already interconnected with other water systems or is located proximal to other water systems such that interconnections are viable, allowing for collaboration regarding supply development to occur and water to potentially be transferred through the regional system to those systems in need.

Table 6 presents the regional deficits to meet MMADD. Three demand scenarios were evaluated in the *Integrated Report*: The projections performed by water utilities for their systems, those projections with passive water conservation applied based on Scenario I in the *State Water Plan*, and the above with available water increased based on potential guidance for meeting MMADD. The majority of new water need has been identified in the CWC – Unionville system (by 2023) and by Southington Water Department (by 2060). The implementation of targeted water conservation and water efficiency measures is expected to be the primary method of meeting future deficits for these systems. The proposed East Hampton WPCA municipal system is also projecting a deficit and would need additional supply by 2030; several potential regional supply options are evaluated in the *Integrated Report*.

Table 6: Summary of Available Water Deficits to Meet MMADD for Community Water Systems (mgd)

Community Water System	Scenario A: Utility Projections			Scenario B: Utility Projections with Passive Water Conservation			Scenario C: Utility Projections with Passive Water Conservation and Available		
	Total New Sources Needed to Meet MOS 1.15 in 2023	Total New Sources Needed to Meet MOS 1.15 in 2030	Total New Sources Needed to Meet MOS 1.15 in 2060	Total New Sources Needed to Meet MOS 1.15 in 2023	Total New Sources Needed to Meet MOS 1.15 in 2030	Total New Sources Needed to Meet MOS 1.15 in 2060	Total New Sources Needed to Meet MOS 1.15 in 2023	Total New Sources Needed to Meet MOS 1.15 in 2030	Total New Sources Needed to Meet MOS 1.15 in 2060
Aquarion Water Company - Birchwood Estates	0.019	0.019	0.019	0.009	0.009	0.009	0.009	0.009	0.009
Cedar Ridge Apartments	0.010	0.010	0.010	0.009	0.008	0.006	0.009	0.008	0.006
CTWC - Northern Reg-Stafford System	-	0.096	-	-	-	-	-	-	-
CTWC - Shoreline Region-Sound View	-	-	0.031	-	-	0.031	-	-	0.031
CTWC - Unionville System	0.587	0.749	1.283	0.532	0.577	0.953	-	-	0.607
East Hampton WPCA - Village Center	-	0.445	0.800	-	0.359	0.629	-	0.359	0.629
Metropolitan District Commission	-	-	15.529	-	-	-	-	-	-
Southington Water Department	-	-	2.664	-	-	1.761	-	-	1.476
Tolland Water Department	-	0.051	0.181	-	-	0.133	-	-	0.133
Woodhaven Apartments	0.014	0.014	0.014	0.013	0.010	0.007	0.013	0.010	0.007
TOTAL	0.631	1.386	20.532	0.563	0.962	3.530	0.031	0.385	2.898

Total available water need accounts for reduction in available water due to streamflow releases.

The projected deficits indicate that new supplies will need to be developed within the various planning horizons, even after accounting for the passive benefits of water conservation and potential available water guidance to reduce “on paper” deficits. As discussed in the *Integrated Report*, mitigating available water deficits is relatively straightforward for some systems, particularly those with minimal deficits. However, the benefits of reducing demand to mitigate the need for additional supply are shown by the limited passive water conservation exercise provided in the *Integrated Report*. Therefore, systems projecting deficits are recommended to reevaluate their demand projections and consider development of a targeted water conservation and water efficiency program to reduce unnecessary water usage on both the supply side and demand side of the system.



6.0 POTENTIAL INTERCONNECTIONS, JOINT USE FACILITIES, AND SATELLITE MANAGEMENT

In the Central PWSMA, several public water systems receive all of their water supply from an interconnection with another system. Those consecutive systems that receive water from a neighboring system include the following:

- From Avon Water Company and MDC: CWC - Collinsville;
- From Berlin Water Control Commission: Worthington Fire District;
- From CWC-Western: Hazardville Water Company – Rye Hill;
- From Manchester Water Department: CWC-Reservoir Heights;
- From MDC: CWC-Chimney Hill;
- From New Britain Water Department: Kensington Fire District; and
- From Tolland Water Department: CWC-Riversedge.

In particular, the New Britain Water Department and Kensington Fire District systems are interconnected and managed to balance supply and demand in a regionally efficient manner. Additional interconnections also exist throughout the region either to provide supplemental supply on an intermittent basis (such as SCCRWA to CWC-Guilford) or for emergency purposes.

While it is recognized that many of the projected deficits in the region are within interconnected systems or systems for which development of interconnections appears viable, existing supplies within the regionally interconnected system are limited. Collaboration between utilities to develop new supply sources (e.g. to meet projected demands in the proposed East Hampton WPCA municipal water system) may be necessary to increase available water supply, with a portion of the new supply allocated between the collaborating utilities and delivered through interconnections.

The regulatory and participatory process involved in creating regional interconnections can be costly and time-consuming. It also requires the cooperation of many municipal and private entities for its success. There are currently no mandates for systems to interconnect or for systems to act as a vehicle for pass-through transmission of water. A lack of cooperation on the part of one or more entities could necessitate the installation of parallel transmission piping. Thus, each system projecting a deficit will continue to need to consider potential new sources of supply other than interconnections to address projected deficits.

Many of the smaller community public water systems in the region (and some of the larger systems) operate with a single source of supply (or wellfield), with no backup supply (or wellfield). This leaves these systems vulnerable to interrupted service due to equipment failures, contamination, and the like. Development of interconnections has been proposed for several of these systems in the *Integrated Report*.

The joint use or ownership of facilities for public water systems in the region is not well documented. Based on local system knowledge, joint use or ownership of major infrastructure such as supply sources, storage, treatment, or water mains is not currently practiced in the region. The sharing of water is more common than the sharing of infrastructure, which WUCC members generally feel should be assigned to

one entity. Development of additional regional interconnections to increase resiliency is recommended, and the development of *Intra-Regional Water Supply Response Plans* to manage transfers of water between utilities may be of interest to streamline response and activation procedures, as well as to potentially authorize limited nonemergency use of the interconnections for planned maintenance events.

Given the forecast water supply deficit in the region, there is a potential for future shared ownership and use of supplies beyond routine interconnections. This type of shared use would require formal agreements among the stakeholders. Large-scale regional interconnections of future water supplies could be fed by a jointly owned supply source although none have been identified to date. This may become more common if water supply development trends towards regional supplies to meet the needs of several systems.

Satellite management can be a cost-effective means of operating a small system because it takes advantage of the "economy of scale" factor that larger water suppliers can offer. This is presented as a potential option in the *Integrated Report* for many of the small CWSs in the region. Furthermore, "outside the box" ideas should continue to be pursued in the future to meet difficult supply challenges. Table 7 presents a summary of satellite management needs and opportunities of major providers in the region.

TABLE 7
Satellite Management Needs and Opportunities of ESA Holders

ESA Holder	Intend to Operate Their Own Satellite Public Water Systems	Potential Need for Contract Operation by Others	Available to Operate Satellite Water Systems for Others	Satellite Systems Unlikely to Occur in ESA
Avon Water Company	X			
Aquarion Water Company	X		X	
Berlin Water Control Commission	X		X	
Cromwell Fire District				X
Connecticut Water Company	X		X	
East Hampton WPCA		X [^]		
ESA Unassigned	X			
Hazardville Water Company	X		X	
Kensington Fire District				X
Manchester Water Department				X
Metropolitan District Commission				X
Meriden Water Division				X
Middletown Water Department				X
New Britain Water Department				X
Portland Water Department		X		
South Central CT Regional Water Authority	X*			
Southington Water Department				X
State Agency Existing Service Area				X
Tolland Water Department		X [^]		
Town of Bolton		X		
Town of Coventry		X		
Town of Durham		X [^]		

TABLE 7
Satellite Management Needs and Opportunities of ESA Holders

ESA Holder	Intend to Operate Their Own Satellite Public Water Systems	Potential Need for Contract Operation by Others	Available to Operate Satellite Water Systems for Others	Satellite Systems Unlikely to Occur in ESA
Town of East Haddam		X [^]		
Town of Lyme		X		
Town of Marlborough		X		
Town of Middlefield		X		
Valley Water Systems				X
Wallingford Water Division				X
Windham Water Works		X [*]		
Worthington Fire District				X

*Water main extensions preferred over satellite system operation for these utilities.

[^]Currently has a contract operator for its systems.



7.0 POTENTIAL WATER SUPPLY SOURCES

A review of individual WSPs was conducted to determine the potential sources of supply being considered by utilities in the region to increase available water in their systems. Most utilities identified one or more options for new supply sources, including potential interconnections, modifications to existing surface water supplies, reactivation of groundwater supplies, reactivation of surface water supplies, development of new surface water diversions, and development of new groundwater wells.

Creation of new supply sources carries a high capital cost and high investment in planning, agreements, permitting, and conceptual design, with successful permitting of a proposed source not guaranteed. As such, the *Integrated Report* recommends the following prioritization of actions regarding new source development:

- For systems demonstrating projected deficits, reevaluate potential demands (particularly for older WSPs);
- Develop a targeted water conservation and efficiency program to further reduce residential, nonresidential, irrigation, unaccounted-for water, and other unnecessary water usage;
- Develop active and/or emergency interconnections between CWSs in the region; and
- Consolidate resources to develop new supply sources and utilize existing interconnections to transfer new water supplies developed in one area of the regionally interconnected water system to other areas in need.

For the purposes of the CWSP, regionally significant supply sources were identified as new sources or activities with the potential to increase available water by 1.0 mgd or more which are proximal to the system in need, and any infrastructure improvements to enhance safe yield associated with sources which already serve regional needs. Furthermore, regionally significant supplies needed to have been advanced beyond the conceptual level in order to be considered regionally significant. For example, a proposal for the development of a new supply source was only considered regionally significant if preliminary testing was performed to estimate potential yield.

Potentially regionally significant actions to increase available supply in the region include meeting projected demands in the proposed East Hampton WPCA municipal water system and meeting shoreline demands in Old Lyme as follows:

- CWC-Guilford: Develop wellfields along Hammonasset River;
- MDC (with East Hampton WPCA): Develop South Glastonbury wellfield; and
- Portland Water Department (with East Hampton WPCA): Develop Strongs Avenue wellfield or construct treatment facility for Portland Reservoir.

The majority of these activities have not sufficiently advanced to having detailed cost estimates suitable for comparison of potential projects on a regional scale, or the cost estimates are relatively out of date. Therefore, prioritization of potential projects by cost and potential yield will be pursued by the WUCC

over the next 5 to 10 years. Utilities are encouraged to continue development of supply sources which may not be regionally significant as further evaluation may reveal that such actions could be applicable at a regional scale.



8.0 POTENTIAL IMPACTS OF THE COORDINATED WATER SYSTEM PLAN ON OTHER USES OF WATER RESOURCES

The discussion in the *Integrated Report* evaluates the potentially regionally significant sources of supply from a “1,000-foot” view to provide some conceptual details regarding the potential impacts of use of these sources on other uses of water resources. Development of future supply sources can potentially have impacts on water quality, minimum streamflows, flood management, recreation, hydropower, listed species and aquatic habitat, riparian rights, and waste load allocations. Each of these issues will require careful evaluation prior to the development of any new supply source. These issues are typically evaluated as part of diversion permit applications for proposed sources of supply although it is recognized that reactivation of registered supply sources would likely not require a diversion permit.

A summary of this evaluation is provided below:

- **Water Quality:** All of the potential surface supply sources will draw on water which has a surface water quality of Class AA or Class A, and all of the proposed groundwater sources lie in areas mapped as GA, indicating suitability for use as a public water supply.
- **Minimum Streamflow:** Minimum streamflows are not expected to be impacted by withdrawals from the Connecticut River aquifer as the proposed withdrawal rates combined are less than 1% of the 7Q10 discharge in the river. Reactivation of Portland Reservoir will require compliance with the Streamflow Standards and Regulations, so downstream flow impacts are expected to be minimal. The potential withdrawals from the Hammonasset River aquifer are significant compared to the 99% duration flow, and therefore the well(s) may only be available for use during winter, spring, and other high-water periods.
- **Flood Management:** Some activities, particularly the creation of new wellfields would need to occur in accordance with local floodplain ordinances and state regulations. A hydraulic analysis will be required for local permitting along the Hammonasset River (and perhaps the Connecticut River, depending on the limit of tidal influence) to demonstrate that any modification of the floodplain will not impact other structures.
- **Recreation:** Potential recreational impact along the Connecticut River is expected to be minimal as instream flow impacts are minimal and the Connecticut River is considered “not supporting” for recreation and fish consumption. Reactivation of the Portland Reservoir would require stricter controls on recreation in the Meshomasic State Forest immediately adjacent to the reservoir in order to prevent swimming and fishing by wading. The overall impact would likely be low. The potential for recreational impacts along the Hammonasset River are more significant given its use for recreational fishing, paddling, and hiking.
- **Hydropower:** None of the streams downstream from any of the proposed actions are used for hydropower.


- Natural Diversity Database (NDDB): Each of the proposed actions lie in areas mapped by the NDDB. The potential to impact listed species would need to be evaluated in more detail as projects are considered.
- Aquatic Habitat Concerns: The occurrence of aquatic habitat impacts would be directly related to proposed withdrawal rates. The impact to aquatic habitat downstream of Portland Reservoir would be minimal as instream flow would be maintained by compliance with the Streamflow Standards and Regulations. Aquatic habitat appears limited in the vicinity of the Connecticut River wellfield, but DEEP notes that the Hammonasset River is considered to be “fully supporting” of aquatic life. Instream flow studies or other assessments, such as a Rapid Bioassessment of invertebrates, may be necessary to determine potential downstream impacts.
- Riparian Rights: Other water users likely exist along most of the streams and brooks envisioned for public water supply use. Some utilize stream and pond access from private properties while others may have agricultural operations or other withdrawals. These would need to be investigated in more detail as projects move forward.
- Waste Load Allocation: With the exception of the Connecticut River, the potential actions lie on watercourses not utilized for treatment of wastewater. Given the minimal instream flow reduction associated with activation of wellfields in the Connecticut River aquifer, impacts to waste load allocation are not anticipated.
- Climate Change: The majority of potential actions are relatively resilient to climate change. The Connecticut River wellfields would be relatively resistant to the effects of climate change and droughts because the watershed size upstream of the proposed wellfields is very large. The size of the drainage basin and the many contributing tributaries will tend to mitigate for flashy droughts which may occur more frequently in the future. This is also true for the Hammonasset River wellfields to a lesser extent. Both wellfields will need to consider the potential for increased flood heights in the future. Development of surface water sources with significant storage (e.g., Portland Reservoir) is also considered to be a relatively resilient project as the storage will offset some of the potential losses due to evapotranspiration, and the effects of climate change can be evaluated over time using the safe yield methodology.



APPENDED FIGURE

Legend

- * NON-COMMUNITY WATER SYSTEM
- Existing Interconnections**
- ACTIVE
- EMERGENCY
- PROPOSED INTERCONNECTION
- PROPOSED SUPPLY SOURCE
- PROPOSED INTERCONNECTION
- ▭ PROPOSED SUPPLY SOURCE AREA
- ▭ COMMUNITY WATER SYSTEMS
- Exclusive Service Area Holders**
- ▭ OTHER COMMUNITY WATER SYSTEM EXCLUSIVE SERVICE AREAS
- ▭ EXCLUSIVE SERVICE AREA ASSIGNED TO TOWN
- ▭ EXCLUSIVE SERVICE AREA ASSIGNED TO LOCAL COMMISSION
- ▭ EXCLUSIVE SERVICE AREA ASSIGNED TO FIRE DISTRICT
- ▭ EXCLUSIVE SERVICE AREA UNASSIGNED
- ▭ STATE AGENCY EXISTING SERVICE AREA
- ▭ AQUARIAN WATER COMPANY
- ▭ AVON WATER COMPANY
- ▭ CONNECTICUT WATER COMPANY
- ▭ HAZARDVILLE WATER COMPANY
- ▭ MANCHESTER WATER DEPARTMENT
- ▭ MERIDEN WATER DIVISION
- ▭ METROPOLITAN DISTRICT COMMISSION
- ▭ MIDDLETOWN WATER DEPARTMENT
- ▭ NEW BRITAIN WATER DEPARTMENT
- ▭ PORTLAND WATER DEPARTMENT
- ▭ SOUTH CENTRAL CONNECTICUT REGIONAL WATER AUTHORITY
- ▭ SOUTHWINGTON WATER DEPARTMENT
- ▭ VALLEY WATER SYSTEMS, INC
- ▭ WALLINGFORD WATER DIVISION
- ▭ WINDHAM WATER WORKS
- ▭ TOWN BOUNDARY
- ▭ PUBLIC WATER SUPPLY WATERSHED
- ▭ DEEP LANDS WHERE ESA BOUNDARIES MAY NOT BE ENFORCEABLE



REGIONAL MAP				SOURCE: CT DPH, CT DEEP, CENTRAL WUCC
CENTRAL PWSMA INTEGRATED REPORT & EXECUTIVE SUMMARY				DATE: MARCH 2, 2018
SIR DESIGNED	SIR DRAWN	JAG CHECKED		
SCALE: 1:96,000			PROJECT NO.: 1017-05-05	
PROJECT NO.: 1017-05-05			APPENDED FIGURE 1	




APPENDIX A

TABLE OF CONTENTS FOR PART I, PART II, AND PART III OF COORDINATED WATER SYSTEM PLAN

Coordinated Water System Plan

Part I: Final Water Supply Assessment

Central Connecticut Public Water Supply Management Area
December 12, 2016



Prepared for:

CENTRAL REGION WATER UTILITY
COORDINATING COMMITTEE
c/o the Elected Recording Secretary
281 Hazard Avenue, Enfield, CT 06082
[http://www.ct.gov/dph/cwp/view.asp?a=3139
&q=576506](http://www.ct.gov/dph/cwp/view.asp?a=3139&q=576506)

Sponsoring Agency:

CONNECTICUT DEPARTMENT OF PUBLIC HEALTH
410 Capitol Avenue
MS #51WAT, P.O. Box 340308
Hartford, CT 06134-0308
(860) 509-7333
<http://www.ct.gov/dph>

Prepared by:

MILONE & MACBROOM, INC.
99 Realty Drive
Cheshire, Connecticut 06410
(203) 271-1773
www.miloneandmacbroom.com

MMI #1017-05-3

TABLE OF CONTENTS

	<u>Page</u>
Notice to Readers	i
Acknowledgements	ii
Table of Contents.....	iv
Definitions.....	viii
Abbreviations.....	xi
EXECUTIVE SUMMARY	ES-1
1.0 INTRODUCTION.....	1-1
1.1 The Coordinated Water System Planning Process.....	1-1
1.2 Components of the Coordinated Water System Plan.....	1-5
1.3 Central Connecticut Public Water Supply Management Area.....	1-6
1.4 Central Connecticut Water Utility Coordinating Committee	1-9
1.5 Information Sources.....	1-10
2.0 EXISTING PUBLIC WATER SYSTEMS.....	2-1
2.1 Composition of the Region	2-1
2.2 Assessment of Water Quality and Source Protection Concerns.....	2-10
2.3 Assessment of System Reliability.....	2-17
2.4 Assessment of Service and Supply Adequacy	2-20
2.5 Assessment of Firefighting Capabilities	2-23
2.6 Assessment of Major Facilities.....	2-26
3.0 ASSESSMENT OF FUTURE WATER SUPPLY SOURCES.....	3-1
3.1 Aquarion Water Company – Simsbury System	3-2
3.2 Avon Water Company.....	3-2
3.3 Berlin Water Control Commission	3-3
3.4 Connecticut Correctional Institute.....	3-3
3.5 Connecticut Valley Hospital	3-3
3.6 Cromwell Fire District.....	3-4
3.7 Connecticut Water Company	3-4
3.8 Hazardville Water Company	3-5
3.9 Kensington Fire District.....	3-5
3.10 Manchester Water Department	3-5
3.11 Meriden Water Division	3-5
3.12 Metropolitan District Commission.....	3-6
3.13 Middletown Water Department	3-6
3.14 New Britain Water Department.....	3-6
3.15 Portland Water Department.....	3-7
3.16 Salmon Brook Water Department	3-7
3.17 South Central Connecticut Regional Water Authority.....	3-7
3.18 Southington Water Department.....	3-8
3.19 Tariffville Fire District.....	3-8

TABLE OF CONTENTS (CONTINUED)

	<u>Page</u>
3.20 Tolland Water Department.....	3-8
3.21 University of Connecticut.....	3-8
3.22 Valley Water Systems.....	3-9
3.23 Wallingford Water Department.....	3-9
3.24 Windham Water Works	3-9
3.25 Worthington Fire District	3-10
4.0 EXISTING SERVICE AREAS AND DONOR BASINS.....	4-1
4.1 Existing Service Areas.....	4-1
4.2 Summary of Source Water and Service Areas	4-6
5.0 POPULATION AND PROJECTED GROWTH	5-1
5.1 Municipal Classifications and Community Water System Population	5-1
5.2 Historical Population.....	5-3
5.3 Municipal Population Projections.....	5-6
5.4 Community Water System Service Population Projections.....	5-10
5.5 Land Uses and Available Land	5-11
5.5.1 Overview of the Central PWSMA	5-11
5.5.2 Land Uses within the Central PWSMA.....	5-12
5.6 Growth Trends	5-14
5.6.1 Housing Trends.....	5-14
5.6.2 Zoning.....	5-17
5.6.3 Conclusions.....	5-24
6.0 STATUS OF WATER SYSTEM PLANNING	6-1
6.1 Individual Water System Planning	6-1
6.2 Municipal Planning.....	6-2
6.3 Land Use Planning and Coordination for Source Protection	6-8
6.3.1 Community Water System Source Protection Efforts.....	6-8
6.3.2 Source Water Assessment Program	6-14
6.3.3 Regional Source Water Protection Efforts	6-15
6.3.4 Connecticut Source Water Collaborative	6-15
6.3.5 Aquifer Protection Area Program.....	6-15
6.3.6 Other Organizations	6-16
6.4 Coordination among Community Water Systems	6-16
7.0 ISSUES, NEEDS, AND DEFICIENCIES IN THE REGION	7-1
7.1 Sources of Supply.....	7-1
7.2 Planning.....	7-3
7.3 Interconnections.....	7-4
7.4 Small Water Systems.....	7-4
7.5 Water Usage.....	7-6
7.6 Final Thoughts.....	7-7

TABLE OF CONTENTS (CONTINUED)

Page

LIST OF TABLES

Table 1-1	Coordinated Water System Plan Components and Schedule.....	1-3
Table 1-2	Central PWSMA Municipalities	1-7
Table 1-3	Summary of Population Served in Central PWSMA by Public Water Systems.....	1-9
Table 1-4	Summary of Comments Received on Preliminary Water Supply Assessment during Public Comment Period	1-10
Table 2-1	Summary of Central PWSMA Public Water System Service Areas by Municipality	2-1
Table 2-2	Summary of Recent Water Quality Violations for Community Systems (2014-2015)...	2-10
Table 2-3	Summary of Water Utility Concerns Regarding Water Quality and Source Protection for Utilities Serving >1,000 People.....	2-14
Table 2-4	Summary of System Reliability Characteristics for Community Water Systems Serving >1,000 People	2-17
Table 2-5	System Demand, Available Yield, and Margin of Safety for Community Water Systems Serving >1,000 People	2-21
Table 2-6	Firefighting Capabilities by Municipality.....	2-23
Table 2-7	Major Facilities of Community Water Systems Serving >1,000 People.....	2-26
Table 2-8	Planned and/or Identified Expansions/Alterations for Community Water Systems Serving >1,000 People	2-28
Table 2-9	List of Existing Interconnections in the Central PWSMA	2-30
Table 2-10	Planned and/or Identified Future Interconnections.....	2-32
Table 2-11	Community Water Systems within 1,000 Feet without Existing or Planned Interconnections.....	2-33
Table 3-1	Potential Future Source of Supply Exploration Planned/Needed for Community Water Systems Serving >1,000 People	3-1
Table 4-1	Summary of Enabling Legislation for Community Water Systems Serving >1,000 People	4-1
Table 4-2	Generalized Summary of Donor Subregional Basins for Community Water Systems Serving > 1,000 People.....	4-6
Table 5-1	Summary of Municipal Characteristics for Central PWSMA.....	5-1
Table 5-2	Municipal Classification for Central PWSMA	5-3
Table 5-3	Historical Population by Municipality for the Central PWSMA	5-4
Table 5-4	Population Projections by Municipality for the Central PWSMA	5-7
Table 5-5	Existing and Future Projected Population of Community Water Systems Serving >1,000 People	5-10
Table 5-6	Land Use Categories in the Central PWSMA.....	5-14
Table 5-7	Housing Inventory Estimates in Central PWSMA Municipalities, 2000-2015.....	5-15
Table 5-8	Generalized Zoning	5-17
Table 5-9	Municipal Buildout Analyses from Plans of Conservation and Development	5-21

TABLE OF CONTENTS (CONTINUED)

	<u>Page</u>
Table 6-1 Individual Water Supply Plan Status.....	6-1
Table 6-2 Summary of Municipal Plans of Conservation and Development	6-3
Table 6-3 Water Supply Comments Addressed in Municipal Plans of Conservation and Development	6-4

LIST OF FIGURES

Figure 1-1 Original PWSMAs	1-2
Figure 1-2 Central Region PWSMA	1-4
Figure 1-3 Population Distribution by Municipality	1-8
Figure 4-1 Small Public Water System Density	4-5
Figure 5-1 Population Growth by Municipality Classification	5-5
Figure 5-2 Population Projections by Classification for Central PWSMA	5-9
Figure 5-3 Central Region Land Cover.....	5-13

LIST OF APPENDED TABLES

Town-By-Town Summary of Public Water Systems and Potential Consolidations for the Central PWSMA.....	Appended Table 1
---	------------------

LIST OF APPENDED FIGURES


Small Community Public Water System Capacity Map	Appended Figure 1
Central PWSMA Overview	Appended Figure 2
Arsenic Concentrations above the Detection Limit in Public Water Supply Wells.....	Appended Figure 3
Combined Uranium Concentrations above the Detection Limit in Public Water Supply Wells	Appended Figure 4

LIST OF APPENDICES

Notifications.....	Appendix A
Central WUCC Member List.....	Appendix B
Summary of System Capabilities and Major Facilities for Community Systems Serving < 1,000 People.....	Appendix C
Summary of Margin of Safety for Community Systems Serving < 1,000 People.....	Appendix D
Public Comments Received on the Preliminary Water Supply Assessment.....	Appendix E
Summary of Capacity Development Assessment Scores.....	Appendix F

Coordinated Water System Plan Part II: Final Recommended Exclusive Service Area Boundaries

Central Public Water Supply Management Area
June 14, 2017



Prepared for:

CENTRAL REGION WATER UTILITY
COORDINATING COMMITTEE
c/o the Elected Recording Secretary
281 Hazard Avenue, Enfield, CT 06082
[http://www.ct.gov/dph/cwp/view.asp?a=3139
&q=576506](http://www.ct.gov/dph/cwp/view.asp?a=3139&q=576506)

Sponsoring Agency:

CONNECTICUT DEPARTMENT OF PUBLIC HEALTH
410 Capitol Avenue
MS #51WAT, P.O. Box 340308
Hartford, CT 06134-0308
(860) 509-7333
<http://www.ct.gov/dph>

Prepared by:

MILONE & MACBROOM, INC.
99 Realty Drive
Cheshire, Connecticut 06410
(203) 271-1773
www.miloneandmacbroom.com

MMI #1017-05-04

TABLE OF CONTENTS

	<u>Page</u>
Notice to Readers	i
Acknowledgements	ii
Table of Contents.....	iv
Definitions.....	vi
Abbreviations.....	viii
1.0 INTRODUCTION.....	1-1
1.1 Overview of Exclusive Service Area Process	1-1
1.2 Composition of the Central Public Water Supply Management Area	1-2
1.3 Enabling Legislation for Exclusive Service Area Holders	1-5
1.4 Public Comments	1-16
2.0 EXCLUSIVE SERVICE AREA DECLARATION PROCESS.....	2-1
2.1 Regulatory Mandate	2-1
2.2 Summary of the Declaration Process.....	2-2
2.2.1 Former Southeastern Connecticut Public Water Supply Management Area.....	2-2
2.2.2 Former South Central Public Water Supply Management Area	2-3
2.2.3 Former Upper Connecticut River Public Water Supply Management Area	2-6
2.2.4 Central Public Water Supply Management Area.....	2-9
2.3 Confirmation of Recommended Boundaries	2-15
2.4 Undesignated Service Areas	2-15
2.5 Consideration of New Exclusive Service Area Holders for Currently Unassigned Areas	2-16
2.5.1 Existing Water Service Area.....	2-16
2.5.2 Land Use Plans, Zoning Regulations, and Growth Trends	2-17
2.5.3 Physical Limitations to Water Service	2-19
2.5.4 Political Boundaries	2-20
2.5.5 Water Company Rights as Established by Statute, Special Act, or Administrative Decisions.....	2-21
2.5.6 System Hydraulics, Including Potential Elevations or Pressure Zones	2-22
2.5.7 Ability to Provide a Pure and Adequate Supply of Water Now and Into the Future ..	2-23
2.6 Potential Cost of Water Service to Residential Customers	2-26
3.0 EXCLUSIVE SERVICE AREA RIGHTS AND RESPONSIBILITIES.....	3-1
3.1 Overview of Rights and Responsibilities	3-1
3.2 Specific Rights and Responsibilities of the Exclusive Service Area Holder	3-2
3.3 Overview of the Certificate of Public Convenience and Necessity Process.....	3-5
3.4 Future Coordination Regarding Exclusive Service Area Boundaries.....	3-8

TABLE OF CONTENTS (CONTINUED)

Page

LIST OF TABLES

Table 1-1	Coordinated Water System Plan Components and Schedule.....	1-4
Table 1-2	Central PWSMA Municipalities	1-4
Table 1-3	Summary of Enabling Legislation for Utilities and Municipalities Claiming Exclusive Service Areas for Areas Currently Unserved by Public Water Supply	1-6
Table 1-4	Summary of Comments Received on Preliminary ESA Document during Public Comment Period	1-16
Table 2-1	Summary of Milestones in the Exclusive Service Area Delineation Process, 1998-2001.....	2-2
Table 2-2	Former Southeastern PWSMA ESAs Inherited by Central PWSMA	2-3
Table 2-3	Summary of Milestones in the ESA Delineation Process, 1988-1989.....	2-4
Table 2-4	Former South Central PWSMA ESA Areas Inherited by Central PWMA	2-4
Table 2-5	Summary of Milestones in the ESA Delineation Process, 1988-1989.....	2-6
Table 2-6	Former Upper Connecticut River PWSMA ESAs Inherited by Central PWSMA	2-7
Table 2-7	Summary of Milestones in the ESA Delineation Process, 2016-2017.....	2-9
Table 2-8	Final Recommended Exclusive Service Area Holders in Central PWSMA.....	2-12
Table 2-9	Potential Annual Cost of Residential Water Service in Currently Unserved Areas, By Town	2-27

LIST OF FIGURES

Figure 1-1	Central Region PWSMA	1-3
------------	----------------------------	-----

LIST OF APPENDED FIGURES


Central PWSMA Overview	Appended Figure 1
Statewide Map of ESA Boundaries	Appended Figure 2

LIST OF APPENDICES

WUCC Correspondence and Supplemental Information.....	Appendix A
Summary of ESA Process for Former Southeastern WUCC	Appendix B
Summary of ESA Process for Former South Central WUCC.....	Appendix C
Summary of ESA Process for Former Upper Connecticut River WUCC	Appendix D
Statements of Confirmation	Appendix E
Public Comments Received on the Preliminary Exclusive Service Area Document	Appendix F

Coordinated Water System Plan Part III: Final Integrated Report

Central Connecticut Public Water Supply Management Area
June 4, 2018



Prepared for:

CENTRAL REGION WATER UTILITY
COORDINATING COMMITTEE
c/o the Elected Recording Secretary
281 Hazard Avenue, Enfield, CT 06082
<http://www.portal.ct.gov/DPH/Drinking-Water/WUCC/Central-Corridor-Water-Utility-Coordinating-Committee>

Sponsoring Agency:

CONNECTICUT DEPARTMENT OF PUBLIC HEALTH
410 Capitol Avenue
MS #12DWS, P.O. Box 340308
Hartford, CT 06134-0308
(860) 509-7333
<http://www.portal.ct.gov/DPH>

Prepared by:

MILONE & MACBROOM, INC.
99 Realty Drive
Cheshire, Connecticut 06410
(203) 271-1773
www.mminc.com

MMI #1017-05

TABLE OF CONTENTS

	<u>Page</u>
Notice to Readers.....	i
Acknowledgements.....	ii
Table of Contents	iv
Definitions	ix
Abbreviations.....	xii
1.0 INTRODUCTION.....	1-1
1.1 Overview of the Integrated Report.....	1-1
1.2 Overview of the Central Public Water Supply Management Area	1-4
1.3 Public Comments	1-5
2.0 CONTEXT AND COORDINATION OF PLANNING	2-1
2.1 Coordination of Planning	2-1
2.1.1 Disjointed Service Areas	2-1
2.1.2 Planning and Coordination among Public Water Systems	2-2
2.1.3 Planning Between Local Governments and Public Water Systems	2-2
2.1.4 Source Water Protection	2-4
2.1.5 Drought Planning and Response.....	2-5
2.2 Water Conservation	2-8
2.3 Impacts of Existing and Future Regulations.....	2-12
2.4 Climate Change and Resiliency	2-16
2.4.1 Climate Change and Effect on Safe Yield	2-16
2.4.2 Resiliency	2-17
2.4.3 Incorporation of Climate Change and Resiliency into Future Projects.....	2-20
3.0 POPULATION, CONSUMPTION, AND AVAILABLE WATER PROJECTIONS	3-1
3.1 Introduction	3-1
3.2 Town Population and Demand Projections	3-2
3.3 Town Public Water Service Population and ADD Projections	3-8
3.4 ESA Holder Public Water Service Population and Average Day Demand Projections.....	3-10
3.5 Public Water System Population and Demand Projections.....	3-14
3.5.1 Existing and Projected Service Population, Demands, and Available Water to meet ADD	3-14
3.5.2 Deficits in Available Water to Meet ADD.....	3-14
3.5.3 Existing and Projected Service Population, Demands, and Available Water to meet MMADD.....	3-17
3.5.4 Deficits in Available Water to Meet MMADD.....	3-17
3.6 Effect of Streamflow Standards and Regulations on Surface Water Supplies.....	3-21
3.7 Potential Solutions to Address Projected Available Water Deficits.....	3-26

TABLE OF CONTENTS (CONTINUED)

	<u>Page</u>
4.0	SATELLITE MANAGEMENT AND SMALL SYSTEM CHALLENGES 4-1
4.1	Satellite Management..... 4-1
4.2	Small System Challenges and Viability..... 4-5
4.3	Recommended Actions for Small Community Water Systems..... 4-8
4.4	Emergency Management, Communications, and Voluntary Associations..... 4-10
5.0	EXISTING AND POTENTIAL FUTURE INTERCONNECTIONS 5-1
5.1	Existing Interconnections in the Region 5-1
5.2	Interconnection Permitting Requirements 5-3
5.2.1	Sale of Excess Water Permits..... 5-3
5.2.2	Diversion Permitting Requirements 5-5
5.2.3	Interconnection Agreement Requirements..... 5-6
5.3	Potential Interconnections to Address Supply Deficits in the Region 5-7
5.3.1	Potential Interconnections to Meet ADD & MMADD through the 5 & 20-Year Planning Periods 5-7
5.3.2	Potential Interconnections to Meet ADD & MMADD through the 50-Year Planning Period 5-10
5.4	Potential Interconnections Recommended to Increase Resiliency in the Region..... 5-12
5.4.1	Interconnections Recommended to Increase Source Resiliency for Large Systems 5-12
5.4.2	Interconnections Recommended to Increase Source Resiliency for Small Systems 5-14
6.0	JOINT USE, MANAGEMENT, OR OWNERSHIP OF SERVICES, EQUIPMENT, AND FACILITIES 6-1
6.1	Existing and Planned Shared or Joint Use Facilities 6-1
6.2	Existing and Planned Joint Use of Services 6-2
6.3	Existing and Planned Joint Use or Ownership of Equipment..... 6-2
7.0	ANALYSIS AND PRIORITIZATION OF POTENTIAL FUTURE WATER SUPPLIES..... 7-1
7.1	Potential Groundwater Sources to Address Supply Deficits..... 7-2
7.1.1	Connecticut River (Basin 4000)..... 7-3
7.1.2	Hammonasset River (Basin 5106)..... 7-4
7.2	Potential Surface Water Sources to Address Supply Deficits 7-4
7.3	Potential Groundwater Sources to Address New Small System Water Demands..... 7-5
7.4	New Supply Development Implementation Strategy 7-5
7.5	Recommendations 7-7
8.0	POTENTIAL IMPACT ON OTHER USES OF WATER RESOURCES 8-1
8.1	Potential Impacts of Groundwater Supply Projects along the Connecticut River 8-1
8.2	Potential Impacts of Groundwater Supply Projects along the Hammonasset River 8-5
8.3	Potential Impacts of Surface Water Supply Projects on Reservoir Brook 8-7
8.4	Potential Impacts of Meeting Daily Needs through Regional Interconnections 8-8
8.5	Potential Impacts of Interconnection Projects for Resiliency..... 8-10

TABLE OF CONTENTS (CONTINUED)

	<u>Page</u>
9.0	MINIMUM DESIGN STANDARDS 9-1
9.1	Overview 9-1
9.2	Local Minimum Design Standards..... 9-1
9.3	Impact on Existing Systems..... 9-3
9.4	Conclusions and Recommendations 9-4
10.0	RELATIONSHIP AND COMPATIBILITY WITH OTHER PLANNING DOCUMENTS 10-1
10.1	Water Supply Plans 10-1
10.2	Local Plans of Conservation and Development 10-1
10.3	Regional Planning Documents 10-2
10.4	Conservation and Development Policies Plan for Connecticut 10-3
10.5	State Water Plan 10-4
11.0	FINANCIAL CONSIDERATIONS 11-1
11.1	Planning Cost Estimates for Implementation of Surface Water Supply Development 11-1
11.2	Planning Cost Estimates for Implementation of Groundwater Supply Development..... 11-2
11.3	Planning Cost Estimates for Implementation of Interconnections..... 11-4
11.4	Financing Issues 11-5
	11.4.1 Financial Operation of Public Water Systems..... 11-5
	11.4.2 Funding of Public Water System Operations and Maintenance..... 11-6
11.5	Potential Funding Sources for Capital Improvement Projects..... 11-7
	11.5.1 Drinking Water State Revolving Fund 11-8
	11.5.2 Small Town Economic Assistance Program 11-9
	11.5.3 United States Department of Agriculture Rural Development Water & Environmental Programs 11-10
	11.5.4 United States Economic Development Administration 11-10
	11.5.5 FEMA Hazard Mitigation Assistance Program 11-10
	11.5.6 Other Agencies..... 11-11
12.0	RECOMMENDATIONS AND PRIORITIZATION 12-1
12.1	Prioritization and Implementation of Recommendations 12-2
12.2	Prioritization and Cost of Capital Improvement Projects 12-2

TABLE OF CONTENTS (CONTINUED)

Page

LIST OF TABLES

Table 1-1	Central PWSMA Towns	1-4
Table 1-2	Summary of Comments Received on the Preliminary Integrated Report and Preliminary Executive Summary during Public Comment Period	1-5
Table 3-1	Summary of Regional Community Water System ADD Projections, Available Water, and MOS.....	3-2
Table 3-2	Population Projections by Town for the Central PWSMA.....	3-3
Table 3-3	Estimated Residential ADD for Total Population by Town for the Central PWSMA	3-6
Table 3-4	Projected Town Population versus Residential Water Service Population.....	3-9
Table 3-5	Existing and Projected ADD for Public Water Systems by Town	3-11
Table 3-6	Existing and Projected Residential Service Population by ESA Holder	3-12
Table 3-7	Existing and Projected ADD for Exclusive Service Areas by ESA Holder	3-13
Table 3-8	Existing and Projected MMADD	3-18
Table 3-9a	System Margin of Safety to Meet MMADD	3-19
Table 3-9b	System Margin of Safety to Meet MMADD with Water Conservation	3-20
Table 3-9c	System Margin of Safety to Meet MMADD with Water Conservation and Available Water Guidance.....	3-22
Table 3-10ab	Reservoir Systems and Potential Available Water Reductions Due to Required Streamflow Releases	3-25
Table 3-10c	Reservoir Systems and Potential Available Water Reductions Due to Required Streamflow Releases with Available Water Guidance.....	3-25
Table 3-11a	Available Water Surplus or Deficit for Reservoir Systems Accounting for Required Streamflow Releases	3-27
Table 3-11b	Available Water Surplus or Deficit for Reservoir Systems Accounting for Required Streamflow Releases and Water Conservation.....	3-27
Table 3-11c	Available Water Surplus or Deficit for Reservoir Systems Accounting for Required Streamflow Releases, Water Conservation, and Available Water Guidance.....	3-27
Table 3-12a	Summary of Available Water Deficits	3-29
Table 3-12b	Summary of Available Water Deficits Including Water Conservation	3-29
Table 3-12c	Summary of Available Water Deficits Including Water Conservation and Potential DPH Available Water Guidance.....	3-30
Table 3-13	Summary of Projected Water Need to Meet MMADD with a MOS of 1.15	3-31
Table 4-1	Entities Willing to Provide Contract Operation Services to Public Water Systems	4-1
Table 4-2	Satellite Management Needs and Opportunities of ESA Providers	4-2

TABLE OF CONTENTS (CONTINUED)

	<u>Page</u>
Table 5-1	List of Active Interconnections in the Central PWSMA Providing Transfer of Water 5-1
Table 5-2	List of Existing Emergency Interconnections in the Central PWSMA..... 5-2
Table 5-3	Sale of Excess Water Permits Issued by DPH 5-4
Table 5-4	Systems with Surplus Available Water Greater than 1.0 mgd through 2030 5-8
Table 5-5	Systems with Surplus Available Water Greater than 1.0 mgd through 2060 5-10
Table 7-1	Potential Sources of Supply for Systems Projecting Significant Supply Deficits 7-2
Table 7-2	Additional Potential Sources of Supply Which Are Regionally Significant 7-2
Table 12-1	Prioritization and Implementation of Non-Capital Improvement Recommendations 12-3

LIST OF FIGURES

Figure 2-1	Resiliency Loss Curve 2-19
Figure 3-1	2017 CT SDC Population Projections for Central PWSMA by Community Type 3-3

LIST OF APPENDED TABLES

Appended Table 1	Existing ADD and Available Water for Community Water Systems
Appended Table 2	5-Year (2023) Projected ADD and Existing Available Water for Community Water Systems
Appended Table 3	20-Year (2030) Projected ADD and Existing Available Water for Community Water Systems
Appended Table 4	50-Year (2060) Projected ADD and Existing Available Water for Community Water Systems

LIST OF APPENDED FIGURES

Regional Map	Appended Figure 1
--------------------	-------------------

LIST OF APPENDICES

Public Comments Received on the Preliminary Integrated Report	Appendix A
Summary of Process Used to Project Public Water Demands.....	Appendix B
Adjustment of CT SDC Municipal Population Projections	Appendix C
Summary of Small Community System Options	Appendix D