

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)	15 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Total Coliform (3100)	15 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
1-6 KNICKERBOCKER LN (2001)	10/1/24 - 12/31/24	12/1-12/31	
	1/1/25 - 3/31/25	3/1-3/31	Complete
	4/1/25 - 6/30/25	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	
40-53 S. COBBLERS CRT (2003)	10/1/24 - 12/31/24	12/1-12/31	
	1/1/25 - 3/31/25	3/1-3/31	Complete
	4/1/25 - 6/30/25	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	
30-39 SOUTH STREET (2004)	10/1/24 - 12/31/24	12/1-12/31	
	1/1/25 - 3/31/25	3/1-3/31	Complete
	4/1/25 - 6/30/25	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	
80-87 QUARRY DOCK RD (2006)	10/1/24 - 12/31/24	12/1-12/31	
	1/1/25 - 3/31/25	3/1-3/31	Complete
	4/1/25 - 6/30/25	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	

Lead And Copper (PBCU)		60 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete
	1/1/25 - 6/30/25		
	7/1/25 - 12/31/25		

Physical Parameters (PPS)		15 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: BRIDE BROOK ENTRY POINT-WELLS 2A,3A & 3B (WSF ID: 00704)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-BRIDE BROOK (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-BRIDE BROOK (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: BRIDE BROOK ENTRY POINT-WELLS 2A,3A & 3B (WSF ID: 00704)

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-BRIDE BROOK (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-BRIDE BROOK (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-BRIDE BROOK (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: WELL 4A WTP ENTRY POINT (WSF ID: 00705)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Tritium (4102)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Strontium-90 (4174)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: WELL 4A WTP ENTRY POINT (WSF ID: 00705)

Strontium-90 (4174) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 4A (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: WELL 5A WTP ENTRY POINT (WSF ID: 00706)

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: WELL 5A WTP ENTRY POINT (WSF ID: 00706)

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WELL 5 (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

Water System Facility: ENTRY POINT WELL 1A & WELL 6 (WSF ID: 00707)

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL 1A AND WELL 6 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL 1A AND WELL 6 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL 1A AND WELL 6 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL 1A AND WELL 6 (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL 1A AND WELL 6 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL 1A AND WELL 6 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		6,119					

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: ENTRY POINT WELL 1A & WELL 6 (WSF ID: 00707)

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL 1A AND WELL 6 (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: WELL 3A (WSF ID: 1417)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3A (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: WELL 4A (WSF ID: 1839)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4A DODGE POND (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: WELL 6 (WSF ID: 1962)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		6,119					

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: **WELL 6 (WSF ID: 1962)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 1A (WSF ID: 49234)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1A (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 2A (WSF ID: 56403)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2A (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		6,119					

Towns Served: EAST LYME

Monitoring Requirements

Water System Facility: **WELL 2A (WSF ID: 56403)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 3B (WSF ID: 57523)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3B BRIDE BROOKS (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **BRIDE BROOK ENTRY POINT-WELLS 2A,3A & 3B (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility: BRIDE BROOK ENTRY POINT-WELLS 2A,3A & 3B (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.8 MG/L	2
Start Date: 11/1/2024			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
Orthophosphate	<spaces> ()	Maximum: 1.5 MG/L	2
Start Date: 11/1/2024			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility: BRIDE BROOK ENTRY POINT-WELLS 2A,3A & 3B (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility: WELL 4A WTP ENTRY POINT (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility: **WELL 4A WTP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility: **WELL 5A WTP ENTRY POINT (WSFID: 00706)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2012		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				
Towns Served: EAST LYME							
Water System Facility: WELL 5A WTP ENTRY POINT (WSFID: 00706)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH			Daily		
Start Date: 1/1/2005		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		3/1/2025 - 3/31/2025					
		4/1/2025 - 4/30/2025					
Water System Facility: ENTRY POINT WELL 1A & WELL 6 (WSFID: 00707)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 1/1/2022		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		12/1/2024 - 12/31/2024					
		1/1/2025 - 1/31/2025					
		2/1/2025 - 2/28/2025					
		3/1/2025 - 3/31/2025					
		4/1/2025 - 4/30/2025					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L			Daily		
Start Date: 5/1/2023		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		12/1/2024 - 12/31/2024					
		1/1/2025 - 1/31/2025					
		2/1/2025 - 2/28/2025					
		3/1/2025 - 3/31/2025					
		4/1/2025 - 4/30/2025					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L			Daily		
Start Date: 5/1/2023		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		12/1/2024 - 12/31/2024			Y		
		1/1/2025 - 1/31/2025			Y		
		2/1/2025 - 2/28/2025			Y		
		3/1/2025 - 3/31/2025			Y		
		4/1/2025 - 4/30/2025					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Manganese	Other (OTHR)	Maximum: 0.3 MG/L			2		
Start Date: 7/1/2022		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		12/1/2024 - 12/31/2024					
		1/1/2025 - 1/31/2025					
		2/1/2025 - 2/28/2025					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility: ENTRY POINT WELL 1A & WELL 6 (WSFID: 00707)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Manganese	Other (OTHR)	Maximum: 0.3 MG/L	2
Start Date: 7/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.8 MG/L	2
Start Date: 11/1/2024		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Orthophosphate	<spaces> ()	Maximum: 1.5 MG/L	2
Start Date: 11/1/2024		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 7/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2013	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	5/1/2025
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	009	BAYREUTHERS BOAT	A	Y		Y	
		010	GUYS OIL	A	Y			
		011	BLACK POINT REALTY	I	Y			
		012	NIANTIC CENTER SCH	A	Y			
		013	12 ROXBURY RD (PWD)	A	Y			
		014	FIREHOUSE (B PT RD)	A	Y			
		015	108 PENN AVE	A	Y			
		016	VILLAGE DR	A	Y			
		017	JEAN DR	A	Y			
		018	DEERFIELD KING ARTH	A	Y			
		019	BLK POINT BEACH CLUB	A	Y			
		020	FIELD SERVICES BLDG	A	Y			
		1001	8 NELSON DR	A		3		
		1002	21 HUNTLEY CT	A		3		
		1003	30 PATTAGANSETT DR	A	Y	3		
		1004	5 WEST RD	A		3		
		1005	2 GREEN TREE DR	A		3		
		1006	36 ROMAGNA RD	A		3		
		1007	6 RAMBLE AVE	A		3		
		1008	4 MONTICELLO DE	A		3		
		1009	7 VILLAGE DR	A		1		
		1101	15 PINE ST	A		3		
		1102	18 HUNTLEY CT	A		3		
		1103	18 SUNNIESIDE DR	A		3		
		1104	3 MAYFIELD TERR	A		3		
		1105	88 SMITH AVE	A		3		
		1106	11 LAKEVIEW AVE	A		3		
		1107	16 DAMON HGTS	A		3		
		1108	14 CAVASIN DR	A		3		
		1109	61 OAKWOOD RD	A		3		
		1110	15 SLEEPY HOLLOW	A		3		
		1111	71 SO WASHINGTON	A		3		
		1112	5 SO LEE	A		3		
		1113	8 JOANNE ST	A		3		
		1114	13 PARK PL	A		3		
		1115	24 SMITH AVE	A		3		
		1116	88 GIANTS NECK	A		3		
		1117	15 SURRY LA	A		3		
		1118	12 CAVSIN DR	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		1119	15 MERRYWOOD DR	A		3		
		1120	17 ROMAGNA RD	A		3		
		1121	10 CYPRESS WAY	A		3		
		1122	17 FILOSI RD	A		3		
		1123	3 BRAINARD RD	A		3		
		1124	41 RIVERVIEW RD	A		3		
		1125	42 SMITH AVE	A		3		
		1126	9 BLACK POINT RD	A		3		
		1127	110 BAYVIEW RD	A		3		
		1128	10 OLD OAK LA	A		3		
		1129	1 SO PINE ST	A		3		
		1130	69 SMITH ST	A		3		
		1131	34 BROADWAY	A		3		
		1132	7 SAUNDERS DR	A		3		
		1133	184 WEST MAIN ST	A		3		
		1134	14 VILLAGE DR	A		1		
		1135	12 NELSON DR	A		3		
		1136	20 VILLAGE DR	A		1		
		1137	30 VILLAGE DR	A		3		
		1138	32 VILLAGE DR	A		1		
		1139	34 VILLAGE DR	A		1		
		1140	36 VILLAGE DR	A		1		
		1141	38 VILLAGE DR	A		1		
		1142	40 VILLAGE DR	A		1		
		1143	47 MAYFIELD TERRACE	A		3		
		1144	45 MAYFIELD TERRACE	A		3		
		1145	41 MAYFIELD TERRACE	A		3		
		1146	36 MAYFIELD TERRACE	A		3		
		1147	44 MAYFIELD TERRACE	A		3		
		1148	20 MAYFIELD TERRACE	A		3		
		1149	19 MAYFIELD TERRACE	A		3		
		1150	16 SLEEPY HOLLOW ROA	A		1		
		1151	40 SLEEPY HOLLOW ROA	A		1		
		1152	47 SLEEPY HOLLOW ROA	A		1		
		1153	117 SLEEPY HOLLOW RO	A		3		
		1154	115 SLEEPY HOLLOW RO	A		3		
		1155	21 FILOSI ROAD	A		3		
		1156	57 SPRING ROCK RD	A		3		
		1157	55 SPRING ROCK RD	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		1158	53 SPRING ROCK RD	A		3		
		1159	49 SPRING ROCK RD	A		3		
		1160	47 SPRING ROCK RD	A		3		
		1161	7 SPRING ROCK RD	A		3		
		1162	5 SPRING ROCK RD	A		3		
		1163	3 SPRING ROCK RD	A		3		
		1164	12 SPRING ROCK RD	A		3		
		1165	14 SPRING ROCK RD	A		3		
		1166	15 SPRING ROCK RD	A		3		
		1167	44 SPRING ROCK RD	A		3		
		1168	7 JEAN DRIVE	A		1		
		1169	15 JEAN DRIVE	A		1		
		1170	4 JEAN DRIVE	A		3		
		1171	22 MACKINNON PL	A		3		
		1172	26 MACKINNON PL	A		3		
		1173	8 JEAN DRIVE	A		3		
		1174	8 MORRIS LN	A		3		
		1175	11 MORRIS LN	A		3		
		1176	25 MACKINNON PL	A		3		
		1177	8 SEEBECK RD	A		3		
		1178	9 SEEBECK RD	A		3		
		1179	5 SEEBECK RD	A		3		
		1180	15 MORRIS LN	A		1		
		1181	9 MORRIS LN	A		1		
		1182	8 MACKINNON PL	A		1		
		1183	12 MACKINNON PL	A		1		
		1184	20 MACKINNON PL	A		3		
		1185	24 MACKINNON PL	A		3		
		1186	11 SEEBECK RD	A		1		
		1187	7 SEEBECK RD	A		1		
		1188	2 MORRIS LN	A		1		
		1189	7 MORRIS LN	A		1		
		1190	16 MACKINNON PL	A		1		
		1191	28 MACKINNON PL	A		1		
		1192	13 MACKINNON PL	A		1		
		1193	5 MACKINNON PL	A		1		
		1194	63 SLEEP HOLLOW RD	A		1		
		1195	18 WILDWOOD DR	A		1		
		1196	13 JEAN DRIVE	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		2001	1-6 KNICKERBOCKER LN	A				Y
		2002	1-6 RED FOX ROAD	A				
		2003	40-53 S. COBBLERS CR	A				Y
		2004	30-39 SOUTH STREET	A				Y
		2005	14-24 LEGENDARY ROAD	A				
		2006	80-87 QUARRY DOCK RD	A				Y
		3001	3 ACORN DRIVE	A		1		
		3002	6 ACORN DRIVE	A		1		
		3003	9 ALSCOT DRIVE	A		1		
		3004	11 ALSCOT DRIVE	A		1		
		3005	14 ATTAWAN AVENUE	A		1		
		3006	76 BAY VIEW ROAD	A		1		
		3007	114 BAY VIEW ROAD	A		1		
		3008	50 BILLOW ROAD	A		1		
		3009	15 BRAINARD ROAD	A		1		
		3010	17 BRAINARD ROAD	A		1		
		3011	8 BUSH HILL DRIVE	A		1		
		3012	10 BUSH HILL DRIVE	A		1		
		3013	12 BUSH HILL DRIVE	A		1		
		3014	35 CENTER STREET	A		1		
		3015	12 CHAPMAN DRIVE	A		1		
		3016	16 CHAPMAN DRIVE	A		1		
		3017	17 CHAPMAN DRIVE	A		1		
		3018	18 CHAPMAN DRIVE	A		1		
		3019	20 CHAPMAN DRIVE	A		1		
		3020	22 CHAPMAN DRIVE	A		1		
		3021	6 CHERYL COURT	A		1		
		3022	10 CHERYL COURT	A		1		
		3023	152 CHESTERFIELD RD	A		1		
		3024	168 CHESTERFIELD RD	A		1		
		3025	172 CHESTERFIELD RD	A		1		
		3026	176 CHESTERFIELD RD	A		1		
		3027	180 CHESTERFIELD RD	A		1		
		3028	184 CHESTERFIELD RD	A		1		
		3029	294 CHESTERFIELD RD	A		1		
		3030	24 CLARK STREET	A		1		
		3031	10 CYPRESS WAY	A		1		
		3032	108A EAST PATT RD	A		1		
		3033	108B EAST PATT RD	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		3034	108C EAST PATT ROAD	A		1		
		3035	108D EAST PATT ROAD	A		1		
		3036	81 FAIRHAVEN ROAD	A		1		
		3037	87 FLANDERS ROAD	A		1		
		3038	93 FLANDERS ROAD	A		1		
		3039	155 FLANDERS ROAD	A		1		
		3040	30 GIANTS NECK ROAD	A		1		
		3041	118 GIANTS NECK ROAD	A		1		
		3042	8 HERSTER DRIVE	A		1		
		3043	10 HERSTER DRIVE	A		1		
		3044	10 JEAN DRIVE	A		1		
		3045	14 JEAN DRIVE	A		1		
		3046	34 LOVERS LANE	A		1		
		3047	37 LOVERS LANE	A		1		
		3048	63 LOVERS LAN	A		1		
		3049	69 LOVERS LAN	A		1		
		3050	10 N BRIDEBROOK RD	A		1		
		3051	246 N BRIDEBROOK RD	A		1		
		3052	252 N BRIDEBROOK RD	A		1		
		3053	266 N BRIDEBROOK RD	A		1		
		3054	273 N BRIDEBROOK RD	A		1		
		3055	275 N BRIDEBROOK RD	A		1		
		3056	279 N BRIDEBROOK RD	A		1		
		3057	281 N BRIDEBROOK RD	A		1		
		3058	29 OAKWOOD ROAD	A		1		
		3059	50 OAKWOOD ROAD	A		1		
		3060	51 OAKWOOD ROAD	A		1		
		3061	57 OAKWOOD ROAD	A		1		
		3062	93 OAKWOOD ROAD	A		1		
		3063	104 OAKWOOD ROAD	A		1		
		3064	41 OSWEGATCH HLS RD	A		1		
		3065	53 OSWEGATCH HLS RD	A		1		
		3066	210 PENN AVE	A		1		
		3067	46 QUARRY DOCK ROAD	A		1		
		3068	82 QUARRY DOCK ROAD	A		1		
		3069	2 RIVERVIEW ROAD	A		1		
		3070	18 RIVERVIEW ROAD	A		1		
		3071	31 RIVERVIEW ROAD	A		1		
		3072	8 SAPIA DRIVE	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		3073	22 SAPIA DRIVE	A		1		
		3074	27 SHORE ROAD	A		1		
		3075	46 SHORE ROAD	A		1		
		3076	103 SLEEPY HOLLOW RD	A		1		
		3077	11 SMITH AVENUE	A		1		
		3078	71 SOCIETY ROAD	A		1		
		3079	83 SOCIETY ROAD	A		1		
		3080	14 SUNRISE TRAIL	A		1		
		3081	16 SUNRISE TRAIL	A		1		
		3082	24 SUNRISE TRAIL	A		1		
		3083	25 SUNRISE TRAIL	A		1		
		3084	37 SUNRISE TRAIL	A		1		
		3085	32 UPPER PATT # 1	A		1		
		3086	32 UPPER PATT # 2	A		1		
		3087	32 UPPER PATT # 3	A		1		
		3088	32 UPPER PATT # 4	A		1		
		3089	32 UPPER PATT # 5	A		1		
		3090	32 UPPER PATT # 6	A		1		
		3091	32 UPPER PATT # 7	A		1		
		3092	32 UPPER PATT # 8	A		1		
		3093	32 UPPER PATT # 9	A		1		
		3094	32 UPPER PATT # 10	A		1		
		3095	97 W MAIN ST # 2	A		1		
		3096	97 W MAIN ST # 3	A		1		
		3097	97 W MAIN ST # 4	A		1		
		3098	97 W MAIN ST # 5	A		1		
		3099	97 W MAIN ST # 6	A		1		
		3100	97 W MAIN ST #7	A		1		
		3101	97 W MAIN ST # 8	A		1		
		3102	97 W MAIN ST # 9	A		1		
		3103	101 W MAIN ST # 1	A		1		
		3104	101 W MAIN ST # 2	A		1		
		3105	101 W MAIN ST # 3	A		1		
		3106	101 W MAIN ST # 4	A		1		
		3107	101 W MAIN ST # 5	A		1		
		3108	101 W MAIN ST # 6	A		1		
		3109	101 W MAIN ST # 7	A		1		
		3110	101 W MAIN ST # 8	A		1		
		3111	103 W MAIN ST # 9	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			6,119				

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		3112	49 WEST PATT RD	A		1		
		3113	6 WILBUR LANE	A		1		
		3114	16 WILDWOOD DR	A		1		
		3115	17 WILDWOOD DR	A		1		
		3116	5 WYNN CIRCLE	A		1		
		4	GENERIC DISTRIBUTION	A	Y			
		901	BLACK PT SEWER PS	A			Y	
		902	CAMP RELL	A			Y	
		903	NIANTIC SEWER PS	A			Y	
		904	BUSH HILL HYD	A			Y	
		905	L.B. HAYNES SCHOOL	A			Y	
		906	COREY LA	A			Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00704	BRIDE BROOK ENTRY POINT- WELLS 2A,3A & 3B	3	EP-BRIDE BROOK	A				
00705	WELL 4A WTP ENTRY POINT	3	EP-WELL 4A	A				
00706	WELL 5A WTP ENTRY POINT	3	EP-WELL 5	A				
00707	ENTRY POINT WELL 1A & WELL 6	3	ENTRY POINT WELL 1A	A				
00708	DARROW POND ENTRY POINT							
1417	WELL 3A	2	WELL 3A	A				
1839	WELL 4A	2	WELL 4A DODGE POND	A				
1962	WELL 6	2	WELL 6	A				
49234	WELL 1A	2	WELL 1A	A				
50077	SLEEP HOLLOW ELDERLY HOUSING TANK							
50079	SLEEPY HOLLOW PUMP STATION							
51321	WELL 1A & WELL 6 WTP							
52044	ORCHARD WOODS TANK							
52046	ORCHARD WOODS PUMP STATION							
52136	ROXBURY ROAD STORAGE TANK							
52138	BOSTON POST ROAD STORAGE TANK							
52140	DEERFIELD AKA KING ARTHUR PUMP STATION							
52142	CEDAR BROOK PUMP STATION							
52144	CHAPMAN WOODS PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		6,119					

Towns Served: EAST LYME

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
52146	CHAPMAN WOOD HYDROPNEUMATIC STORAGE TANK							
52148	VILLAGE DRIVE PUMP STATION							
52152	ANCIENT HIGHWAY PUMP STATION							
52154	ANCIENT HWY HYDROPNEUMATIC STORAGE TANK							
52156	MACKINNON PLACE PUMP STATION							
52160	SUNRISE TRAIL PUMP STATION							
52164	JEAN DRIVE PUMP STATION							
52166	JEAN DRIVE HYDROPNEUMATIC STORAGE TANK							
56403	WELL 2A	2	WELL 2A	A				
57523	WELL 3B	2	WELL 3B BRIDE BROOKS	A				
58948	INTERCONNECTION - CT0950011 - NEW LONDON							
58949	BUTLERTOWN ROAD TANK							
58951	EAST LYME PUMP STATION							
58953	NEW LONDON PUMP STATION							
58970	DEERFIELD HYDROPNEUMATIC STORAGE TANK							
58972	CEDAR BROOK HYDROPNEUMATIC STORAGE TANK							
59628	GATEWAY COMMONS PUMP STATION							
62868	WELL 5A	2	WELL 5A	A				
629	WELL 4A WTP							
630	WELL 5A WTP							
67	BRIDE BROOK - WELLS 2A,3A, & 3B TP							

Certified Operator Information

Water System Facility: WELL 5A WTP (WSF ID: 630)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ALFIERI, MARK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		6,119					

Towns Served: EAST LYME

Certified Operator Information

Water System Facility: WELL 5A WTP (WSF ID: 630)			
Facility Classification: CLASS 3 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2027
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
NORTH, BENJAMIN M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2025
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: CLASS 2 DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)	
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2025
LARSON, ALLEN L.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
NORTH, BENJAMIN M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2025
Water System Facility: BRIDE BROOK - WELLS 2A,3A, & 3B TP (WSF ID: 67)			
Facility Classification: CLASS 3 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2027
ALFIERI, MARK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
LARSON, ALLEN L.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2025
NORTH, BENJAMIN M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2025
Water System Facility: WELL 4A WTP (WSF ID: 629)			
Facility Classification: CLASS 2 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2027
ALFIERI, MARK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
NORTH, BENJAMIN M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2025
Water System Facility: WELL 1A & WELL 6 WTP (WSF ID: 51321)			
Facility Classification: CLASS 2 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2027
ALFIERI, MARK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
LARSON, ALLEN L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2025

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0450011	EAST LYME WATER & SEWER COMMISSION	C	15,245	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		6,119					

Towns Served: EAST LYME

Certified Operator Information

Water System Facility: **WELL 1A & WELL 6 WTP (WSF ID: 51321)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
NORTH, BENJAMIN M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2025

Contact Information

Name		Organization			Job Title	
Mr. Benjamin M. North		East Lyme Water And Sewer				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
108 Pennsylvania Ave		P. O. Box 519		Niantic	CT	06357
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-691-4108				860-405-6473	bnorth@eltownhall.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Name		Organization			Job Title	
Mr. Kevin A. Seery		Town of East Lyme			First Selectman	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
PO Box 519				Niantic	CT	06357
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-691-4110					kseery@eltownhall.com	

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule