

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
Asbestos (1094)	3 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
INTERLAKEN INN (00710)	1/1/21 - 12/31/29		Complete
NOBLE HORIZONS- SALI (00782)	1/1/21 - 12/31/29		Complete
OLD ASYLUM RD SS (00783)	1/1/21 - 12/31/29		Complete
Total Haloacetic Acids (2456)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
INTERLAKEN INN (00710)	10/1/24 - 12/31/24	12/1-12/7	Complete
	1/1/25 - 3/31/25	3/1-3/7	Complete
	4/1/25 - 6/30/25	6/1-6/7	
	7/1/25 - 9/30/25	9/1-9/7	
	10/1/25 - 12/31/25	12/1-12/7	
Total Trihalomethanes (2950)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
OLD ASYLUM RD SS (00783)	10/1/24 - 12/31/24	12/1-12/7	Complete
	1/1/25 - 3/31/25	3/1-3/7	Complete
	4/1/25 - 6/30/25	6/1-6/7	
	7/1/25 - 9/30/25	9/1-9/7	
	10/1/25 - 12/31/25	12/1-12/7	
Total Coliform (3100)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU)		10 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 6/30/23	6/1-6/30			
Lead And Copper (PBCU)		20 routine (RT) per six months			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25				
	7/1/25 - 12/31/25				
Physical Parameters (PPS)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
Water Quality Parameters Orthophosphate, Total Alkalinity, T (WQP8)		4 routine (RT) per six months			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25				
	7/1/25 - 12/31/25				
Water System Facility: LAKEVILLE RES WTP ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/25				
Uranium (4006)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/25				
Combined Radium-226/228 (4010)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/25				
Inorganic Chemicals (IOCS)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: LAKEVILLE RES WTP ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per six years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Water System Facility: LAKEVILLE WELLFIELD TP ENTRY POINT (WSF ID: 00701)			
Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/17 - 12/31/25		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/17 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/17 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: LAKEVILLE WELLFIELD TP ENTRY POINT (WSF ID: 00701)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/26 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - LAKEVILLE TP (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: SALISBURY WELLFIELD TP ENTRY POINT (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		
	1/1/26 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: SALISBURY WELLFIELD TP ENTRY POINT (WSF ID: 00702)

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: SALISBURY WELL B (WSF ID: 1253)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SALISBURY WELL B (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: SALISBURY WELL A (WSF ID: 1254)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SALISBURY WELL A (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: SALISBURY WELL C (WSF ID: 1255)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SALISBURY WELL C (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: SALISBURY WELL D (WSF ID: 1256)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: **SALISBURY WELL D (WSF ID: 1256)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SALISBURY WELL D (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **LAKEVILLE RESERVOIR #2 (WSF ID: 2007)**

Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKEVILLE RESERVOIR (1)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKEVILLE RESERVOIR (1)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKEVILLE RESERVOIR (1)	10/1/24 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: LAKEVILLE RESERVOIR #2 (WSF ID: 2007)

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKEVILLE RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKEVILLE RESERVOIR (1)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKEVILLE RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: LAKEVILLE SURFACE WATER TREATMENT PLANT (WSF ID: 241)

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - LAKEVILLE TP (5)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: LAKEVILLE RES WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 8/2/2024			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
Orthophosphate	<spaces> ()	Maximum: 1.75 MG/L	2
Start Date: 8/2/2024			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily
Start Date: 7/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Water System Facility: LAKEVILLE RES WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.5 MG/L	2
Start Date: 8/2/2024			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Water System Facility: LAKEVILLE WELLFIELD TP ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	4
Start Date: 1/1/2015			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Water System Facility: SALISBURY WELLFIELD TP ENTRY POINT (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2 MG/L	2
Start Date: 7/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Water System Facility: SALISBURY WELLFIELD TP ENTRY POINT (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1 MG/L	2
Start Date: 7/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily
Start Date: 7/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 2 MG/L	2
Start Date: 7/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Phosphate (as PO4)	<spaces> ()	Maximum: 4 MG/L	2
Start Date: 7/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Water System Facility: LAKEVILLE SURFACE WATER TREATMENT PLANT (WSFID: 241)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		

Water System Facility: LAKEVILLE WELLFIELD TREATMENT PLANT (WSFID: 243)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Continuous
Start Date: 10/1/2014			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
WATERSHED SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00500	SUPERNATANT/DECANT SAMPLE TAP	1	SAMPLE TAP	A				
00501	SUPERNATANT/RAW COMBO SAMPLE TAP	1	SAMPLE TAP	A				
00502	LAKEVILLE WELLFIELD RAW SAMPLE TAP	2	RAW	A				
00503	SALISBURY WELLS A/B RAW SAMPLE TAP	2	RAW	A				
00504	SALISBURY WELLS C/D RAW SAMPLE TAP	2	RAW	A				
00600	DISTRIBUTION SYSTEM	00710	INTERLAKEN INN	A	Y		Y	Y
		00711	DECKERS LAUNDRY	I	Y			
		00712	WELLS HILL PNEUMATIC	A	Y			
		00750	LAKEVILLE W.C. OFFIC	A	Y			
		00781	SALISBURY TOWN HALL	A	Y			
		00782	NOBLE HORIZONS- SALI	A	Y		Y	
		00783	OLD ASYLUM RD SS	A	Y		Y	Y
		00784	LAKEVILLE OFFICE	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB5408	22 LINCOLN CITY SALI	A		1		
		PB5414	29 CANTERBURY LA LV	A		3		
		PB5435	87 CANAAN RD #3 D	A		1		
		PB5436	87 CANAAN RD #3F	A		1		
		PB5440	3L CANAAN SALIS	A		1		
		PB5447	1 FOWLER SALIS	A		3		
		PB5456	16 WOODLAND LV	A		1		
		PB5465	74 WOODLAND LV	A		3		
		PB5469	22 ROBIN HILL LA LV	A		3		
		PB5473	32 YONDER WY LV	A		3		
		PB5477	36 RED BIRD LA LV	A		3		
		PB5482	75 ROBIN HILL LV	A		3		
		PB5486	31 ROBIN HILL LV	A		3		
		PB5497	37 HILLCREST LV	A		1		
		PB5627	4G CANAAN SALIS	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB5629	70 LINCOLN CITY SALI	A		1		
		PB5632	2 FARNUM LV	A		3		
		PB7529	2 FARNUM ROAD	A		3		
		PB8496	76-A LINCOLN CITY	A		1		
		PB8497	8 BELL DR	A		1		
		PB8498	15 BELGO RD	A		1		
		PB8499	15 ECHO ST	A		1		
		PB8500	21 HORSE SHOE LN	A		1		
		PB8501	23 OLD CNE RD	A		1		
		PB8502	24 PERRY ST	A		1		
		PB8503	24 EAST ST	A		1		
		PB8504	40 SALMON KILL RD	A		1		
		PB8505	45 LIBRARY ST	A		1		
		PB8506	103 RESERVOIR RD	A		1		
		PB8507	124 MAIN ST	A		1		
		PB8508	131 MAIN STREET	A		1		
		PB8509	165 SHARON RD	A		1		
		PB8510	357 WELLS HILL RD	A		1		
		PB8511	369 WELLS HILL RD	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	LAKEVILLE RES WTP ENTRY POINT	3	ENTRY POINT	A				
00701	LAKEVILLE WELLFIELD TP ENTRY POINT	3	ENTRY POINT - LAKEVI	A				
00702	SALISBURY WELLFIELD TP ENTRY POINT	3	ENTRY POINT	A				
1250	LAKEVILLE WELL #1	2	LAKEVILLE WELL #1	A				
1251	LAKEVILLE WELL #2A	2	LAKEVILLE WELL #2A	A				
1252	LAKEVILLE WELL #3	2	LAKEVILLE WELL #3	A				
1253	SALISBURY WELL B	2	SALISBURY WELL B	A				
1254	SALISBURY WELL A	2	SALISBURY WELL A	A				
1255	SALISBURY WELL C	2	SALISBURY WELL C	A				
1256	SALISBURY WELL D	2	SALISBURY WELL D	A				
2007	LAKEVILLE RESERVOIR #2	1	LAKEVILLE RESERVOIR	A				
2008	LAKEVILLE RESERVOIR #3	1	RESERVOIR	A				
241	LAKEVILLE SURFACE WATER TREATMENT PLANT	5	CFE - LAKEVILLE TP	A				
242	SALISBURY WELLFIELD TREATMENT PLANT							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
243	LAKEVILLE WELLFIELD TREATMENT PLANT							
30079	LAKEVILLE RESERVOIR #2 INTAKE							
59371	PETTEE ST PUMP STATION							
59373	BUNKER HILL (SALISBURY) TANK							
59377	LAKEVILLE SWTP TANK							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
GAGNON, MATTHEW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
HUMES, DANIEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2025
MIRTO, STEPHEN A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2026

Water System Facility: LAKEVILLE SURFACE WATER TREATMENT PLANT (WSF ID: 241)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GEDDES, HOLLY	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
HUMES, DANIEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2025
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
MIRTO, STEPHEN A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026

Water System Facility: SALISBURY WELLFIELD TREATMENT PLANT (WSF ID: 242)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GEDDES, HOLLY	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Certified Operator Information

Water System Facility: SALISBURY WELLFIELD TREATMENT PLANT (WSF ID: 242)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PASSECK, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
HUMES, DANIEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2025
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
MIRTO, STEPHEN A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2026

Water System Facility: LAKEVILLE WELLFIELD TREATMENT PLANT (WSF ID: 243)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GEDDES, HOLLY	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027
HUMES, DANIEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
GAGNON, MATTHEW	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
MIRTO, STEPHEN A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026

Contact Information

Name		Organization			Job Title	
Mr. Robert J. Ulrich		Aquarion Water Company of Ct			Vp-Supply & Utility	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Aquarion Water Company of Ct		505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com	
Contact Role(s): Administrative Contact, Legal Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220011	AQUARION-SALISBURY	C	1,932	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						1,045	

Towns Served: SALISBURY

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220061	SALISBURY SCHOOL	C	520	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
251 CANAAN ROAD			30				
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
KITCHEN SINK (SSW003)	1/1/24 - 12/31/24	7/1-7/31	Complete		
	1/1/25 - 12/31/25	7/1-7/31			
	1/1/26 - 12/31/26	7/1-7/31			
Lead And Copper (PBCU)		10 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30			
	1/1/26 - 12/31/28	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220061	SALISBURY SCHOOL	C	520	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
251 CANAAN ROAD			30				

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220061	SALISBURY SCHOOL	C	520	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
251 CANAAN ROAD			30				
Towns Served: SALISBURY							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)			
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.24 MG/L	Continuous
Start Date: 8/1/2021		Compliance History:	Operating Limit
	Monitoring Period	Compliance Status:	Monitoring Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		SSW001	ENTRY TO DIST.	I				
		SSW002	LANGDON MAIN	A				
		SSW003	KITCHEN SINK	A	Y			Y
		SSW004	SEWER PLANT SINK	A				Y
		SSW005	CLASS OF 1995 HOUSE	A	Y			
		SSW006	CARR S KIT SINK	A	Y	2		
		SSW007	BELIN KITCHEN SINK	A	Y	2		
		SSW008	PRIESTMAN DORM	A	Y	3		
		SSW009	FIRE PUMP HOUSE	A	Y	N		
		SSW010	WARD DORM	A	Y	N		
		SSW011	CHILDS HOUSE U1	A	Y	N		
		SSW012	CHILDS HOUSE U2	A	Y	N		
		SSW013	CHILDS HOUSE V1	A	Y	N		
SSW014	CHILDS HOUSE V2	A	Y	N				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220061	SALISBURY SCHOOL	C	520	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
251 CANAAN ROAD			30				
Towns Served: SALISBURY							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SSW015	MYERS GYM	A	Y	2		
		SSW016	INFIRMARY	A	Y	3		
		SSW017	WACHTMEISTER M/S	A	Y	N		
		SSW018	HEADMASTER HOUSE	A	Y	1		
		SSW019	FLOOD ATHLETIC CTR	A	Y	N		
		SSW020	PAYSON DORM	A	Y	2		
		SSW021	CENTENNIAL LIBRARY	A	Y	N		
		SSW022	CHAPEL	A	Y	2		
		SSW023	QUAILE DORM	A	Y	2		
		SSW024	RENNELL HOUSE	A	Y	2		
		SSW025	FARMHOUSE A	A	Y	N		
		SSW026	FARMHOUSE B	A	Y	N		
		SSW027	FARMHOUSE C	A	Y	N		
		SSW028	FARMHOUSE D	A	Y	N		
		SSW029	KEUR HOUSE	A	Y	2		
		SSW030	PUGH HOUSE	A	Y	N		
		SSW031	MOUNTAINVIEW HOUSE	A	Y	1		
		SSW032	TAPPERT HOUSE	A	Y	2		
		SSW033	STAFF QUARTERS	A	Y	2		
		SSW034	WESTERLY HOUSE	A	Y	1		
		SSW035	TRUSTEE HOUSE	A	Y	N		
		SSW036	MEADOWVIEW HOUSE	A	Y	1		
		SSW037	TURF FIELD RESTROOM	A	Y	N		
		SSW038	MAINTENANCE OFFICE	A	Y	N		Y
		SSW039	MAINTENANCE SHOP	A	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21	WELL 2	2	WELL 2	A				
22	WELL 1	2	WELL 1	A				
36517	TREATMENT PLANT							
55116	ATMOSPHERIC STORAGE TANK							
59394	PUMP STATION							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 36517)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1220061	SALISBURY SCHOOL	C	520	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
251 CANAAN ROAD			30				
Towns Served: SALISBURY							

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 36517)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BOYER, WILLIAM F.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2025

Contact Information

Name		Organization			Job Title		
Mr. Bill Boyer		Salisbury School			Dir Bldgs/Grnds/Safe		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
251 Canaan Rd					Salisbury	CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-435-5752		860-435-5750		860-435-5759	wboyer@salisburyschool.org		

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title		
Mr. Vafa Vahid		Salisbury School			Cfo		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
251 Canaan Road					Salisbury	CT	06068
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-435-5709		860-435-5750		860-435-5759	vvahid@salisburyschool.org		

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1221031	CHATFIELD HILL ASSN., INC.	C	68	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15				

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per six years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/20 - 12/31/25				
	1/1/26 - 12/31/31				
Uranium (4006)		1 routine (RT) per six years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/20 - 12/31/25				
	1/1/26 - 12/31/31				
Combined Radium-226/228 (4010)		1 routine (RT) per six years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/20 - 12/31/25				
	1/1/26 - 12/31/31				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1221031	CHATFIELD HILL ASSN., INC.	C	68	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15				

Towns Served: SALISBURY

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION EXEMPTION	3/1/2029	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CHA001	14 CHATFIELD HILL DR	A	Y	N	Y	
		CHA002	20 CHATFIELD HILL DR	A	Y	3		
		CHA003	31 CHATFIELD HILL DR	A	Y	3		
		CHA004	32 CHATFIELD HILL DR	A	Y	N		
		CHA005	37 CHATFIELD HILL DR	A	Y	3		
		CHA006	41 CHATFIELD HILL DR	A	Y	3		
		CHA007	48 CHATFIELD HILL DR	A	Y	3		
		CHA008	45 CHATFIELD HILL DR	A	Y	3		
		CHA009	49 CHATFIELD HILL DR	A	Y	3		
		CHA010	51 CHATFIELD HILL DR	A	Y	3		
		CHA011	53 CHATFIELD HILL DR	A	Y	3		
		CHA012	55 CHATFIELD HILL DR	A	Y	3		
		CHA014	15 CHATFIELD HILL DR	A	Y	3		
		CHA015	60 CHATFIELD HILL DR	A	Y	3		
		CHA016	308 MILLERTON RD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1221031	CHATFIELD HILL ASSN., INC.	C	68	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		15					

Towns Served: SALISBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
		CHA013	WELL HOUSE	A				
15	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HELMING, TRAVIS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025

Contact Information

Name	Organization	Job Title
Chatfield Hill Assn., Inc.		

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
			CT	06000

Emergency Contact	Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
	860-435-2112					

Contact Role(s): **Owner**

Name	Organization	Job Title
Mr. John Hoffman	Chatfield Hill Association	Secretary

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
37 Chatfield Drive		Lakeville	CT	06039

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-435-8139					johnwhoffman@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule