

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>	<b>180 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/19 - 11/30/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		
<b>Chlorine Residual (1012)</b>	<b>183 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	12/1/19 - 12/31/19		Complete
<b>Orthophosphate (1044)</b>	<b>50 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/19 - 12/31/19		
	1/1/20 - 6/30/20		
	7/1/20 - 12/31/20		
<b>Asbestos (1094)</b>	<b>6 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
FIRESTONE (00111)	1/1/12 - 12/31/20		
	1/1/21 - 12/31/29		
SAVE THE CHILDREN (00139)	1/1/12 - 12/31/20		
	1/1/21 - 12/31/29		
TRUMBULL POLICE (00216)	1/1/12 - 12/31/20		
	1/1/21 - 12/31/29		
WHITE HILLS PUMP STATION (00221)	1/1/12 - 12/31/20		
	1/1/21 - 12/31/29		
PASTORS WALK (00222)	1/1/12 - 12/31/20		
	1/1/21 - 12/31/29		
WEST BRANCH RD SS (00357)	1/1/12 - 12/31/20		
	1/1/21 - 12/31/29		
<b>Total Coliform (3100)</b>	<b>3 repeat (RP) per period</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/7/19 - 9/12/19		Complete
	9/7/19 - 9/12/19		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/24/19 - 9/29/19		Complete
	9/24/19 - 9/29/19		Complete
	10/2/19 - 10/7/19		Complete
	12/6/19 - 12/11/19		Complete

<b>Total Coliform (3100)</b>		<b>180 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>12 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNTINGTON RD FS (00016)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
TEXACO-HOWE AVE (00029)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
RADD LAUNDROMAT (00030)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
LORDSHIP FS (00032)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

**Water System Facility:** DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>12 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
LORD CHAMBERLAIN NC (00037)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
JACKMAN FS (00210)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
TRUMBULL POLICE (00216)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
GULF HUNTINGTON (00218)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
WHITE HILLS PUMP STATION (00221)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
PASTORS WALK (00222)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
GETTY MOHEGAN RD (01161)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>12 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/20 - 9/30/20	8/1-8/31	
MADISON LIBRARY SS (01175)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	

<b>Lead And Copper (PBCU)</b>		<b>50 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	

<b>Physical Parameters (PPS)</b>		<b>180 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

<b>Water Quality Parameters (WQPD)</b>		<b>50 routine (RT) per six months</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/19 - 12/31/19		
	1/1/20 - 6/30/20		
	7/1/20 - 12/31/20		

Water System Facility: **TRAP FALLS WTP ENTRY POINT (WSF ID: 00700)**

<b>Orthophosphate (1044)</b>		<b>1 routine (RT) per two weeks</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TRAP FALLS (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Complete
	11/15/19 - 11/28/19		Complete
	11/29/19 - 12/12/19		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: TRAP FALLS WTP ENTRY POINT (WSF ID: 00700)

<b>Orthophosphate (1044)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	12/13/19 - 12/26/19		Complete
	12/27/19 - 1/9/20		
	1/10/20 - 1/23/20		
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		
<b>pH (1925)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TRAP FALLS (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Complete
	11/15/19 - 11/28/19		Complete
	11/29/19 - 12/12/19		Complete
	12/13/19 - 12/26/19		Complete
	12/27/19 - 1/9/20		
	1/10/20 - 1/23/20		
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TRAP FALLS (3)	1/1/17 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TRAP FALLS (3)	1/1/17 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TRAP FALLS (3)	1/1/17 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TRAP FALLS (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: TRAP FALLS WTP ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - TRAP FALLS (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - TRAP FALLS (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		

Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - TRAP FALLS (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		

Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - TRAP FALLS (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: EASTON WTP ENTRY POINT (WSF ID: 00701)

Orthophosphate (1044)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - EASTON (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Complete
	11/15/19 - 11/28/19		Complete
	11/29/19 - 12/12/19		Complete
	12/13/19 - 12/26/19		Complete
	12/27/19 - 1/9/20		
	1/10/20 - 1/23/20		
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
3/6/20 - 3/19/20			

pH (1925)		1 routine (RT) per two weeks	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - EASTON (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Complete
	11/15/19 - 11/28/19		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **EASTON WTP ENTRY POINT (WSF ID: 00701)**

<b>pH (1925)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	11/29/19 - 12/12/19		Complete
	12/13/19 - 12/26/19		Complete
	12/27/19 - 1/9/20		
	1/10/20 - 1/23/20		
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/17 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/17 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/17 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **EASTON WTP ENTRY POINT (WSF ID: 00701)**

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EASTON (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: **HEMLOCKS WTP ENTRY POINT (WSF ID: 00702)**

<b>Orthophosphate (1044)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Complete
	11/15/19 - 11/28/19		Complete
	11/29/19 - 12/12/19		Complete
	12/13/19 - 12/26/19		Complete
	12/27/19 - 1/9/20		
	1/10/20 - 1/23/20		
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		

<b>pH (1925)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Complete
	11/15/19 - 11/28/19		Complete
	11/29/19 - 12/12/19		Complete
	12/13/19 - 12/26/19		Complete
	12/27/19 - 1/9/20		
	1/10/20 - 1/23/20		
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/17 - 12/31/25		

<b>Uranium (4006)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **HEMLOCKS WTP ENTRY POINT (WSF ID: 00702)**

<b>Uranium (4006)</b>			<b>1 routine (RT) per nine years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/17 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>			<b>1 routine (RT) per nine years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/17 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>			<b>2 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>			<b>2 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		
<b>Organic Chemicals (VOCS)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HEMLOCKS (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Water System Facility: <b>WESTPORT WELLFIELD TP ENTRY POINT (WSF ID: 00704)</b>			
<b>Orthophosphate (1044)</b>			<b>1 routine (RT) per two weeks</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Out of Service
	11/15/19 - 11/28/19		Out of Service
	11/29/19 - 12/12/19		Out of Service
	12/13/19 - 12/26/19		Out of Service
	12/27/19 - 1/9/20		Out of Service

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: WESTPORT WELLFIELD TP ENTRY POINT (WSF ID: 00704)

<b>Orthophosphate (1044)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/10/20 - 1/23/20		Out of Service
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		
<b>pH (1925)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Out of Service
	11/15/19 - 11/28/19		Out of Service
	11/29/19 - 12/12/19		Out of Service
	12/13/19 - 12/26/19		Out of Service
	12/27/19 - 1/9/20		Out of Service
	1/10/20 - 1/23/20		Out of Service
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/17 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/17 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/17 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

**Water System Facility: WESTPORT WELLFIELD TP ENTRY POINT (WSF ID: 00704)**

<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

**Water System Facility: COLEYTOWN WELLFIELD TP ENTRY POINT (WSF ID: 00705)**

<b>Orthophosphate (1044)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WESTPORT (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Out of Service
	11/15/19 - 11/28/19		Out of Service
	11/29/19 - 12/12/19		Out of Service
	12/13/19 - 12/26/19		Out of Service
	12/27/19 - 1/9/20		Out of Service
	1/10/20 - 1/23/20		Out of Service
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		

<b>pH (1925)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	10/4/19 - 10/17/19		Complete
	10/18/19 - 10/31/19		Complete
	11/1/19 - 11/14/19		Out of Service
	11/15/19 - 11/28/19		Out of Service
	11/29/19 - 12/12/19		Out of Service
	12/13/19 - 12/26/19		Out of Service
	12/27/19 - 1/9/20		Out of Service

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	
Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON							

### Monitoring Requirements

**Water System Facility: COLEYTOWN WELLFIELD TP ENTRY POINT (WSF ID: 00705)**

<b>pH (1925)</b>	<b>1 routine (RT) per two weeks</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/10/20 - 1/23/20		Out of Service
	1/24/20 - 2/6/20		
	2/7/20 - 2/20/20		
	2/21/20 - 3/5/20		
	3/6/20 - 3/19/20		
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/17 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/17 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/17 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLEYTOWN (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

**Water System Facility: TRAP FALLS WATER TREATMENT PLANT (WSF ID: 14)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **TRAP FALLS WATER TREATMENT PLANT (WSF ID: 14)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT - TRAP FALLS (5)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **EASTON WATER TREATMENT PLANT (WSF ID: 15)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT - EASTON TP (5)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **HEMLOCKS RESERVOIR (WSF ID: 2009)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HEMLOCKS RESERVOIR (1)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **HEMLOCKS RESERVOIR (WSF ID: 2009)**

<b>Total Alkalinity (1927)</b>		<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
HEMLOCKS RESERVOIR (1)	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20		Complete	
	4/1/20 - 4/30/20		Complete	
	5/1/20 - 5/31/20		Complete	
	6/1/20 - 6/30/20		Complete	
	7/1/20 - 7/31/20		Complete	
8/1/20 - 8/31/20		Complete		
9/1/20 - 9/30/20		Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
HEMLOCKS RESERVOIR (1)	7/1/19 - 9/30/19		Complete	
	10/1/19 - 12/31/19		Complete	
	1/1/20 - 3/31/20		Complete	
	4/1/20 - 6/30/20		Complete	
	7/1/20 - 9/30/20		Complete	
<b>Surface Water Inorganic Chemicals (RIOCI)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
HEMLOCKS RESERVOIR (1)	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20		Complete	
	1/1/21 - 12/31/21		Complete	
<b>Surface Water Color and Turbidity (RPPS)</b>		<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
HEMLOCKS RESERVOIR (1)	7/1/19 - 9/30/19		Complete	
	10/1/19 - 12/31/19		Complete	
	1/1/20 - 3/31/20		Complete	
	4/1/20 - 6/30/20		Complete	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

<b>Water System Facility: HEMLOCKS RESERVOIR (WSF ID: 2009)</b>						
<b>Surface Water Color and Turbidity (RPPS)</b>			<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>			
	7/1/20 - 9/30/20					
<b>Surface Water Pesticides (RSOC)</b>			<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>			
HEMLOCKS RESERVOIR (1)	1/1/19 - 12/31/19		Complete			
	1/1/20 - 12/31/20					
	1/1/21 - 12/31/21					
<b>Water System Facility: EASTON LAKE RESERVOIR (WSF ID: 2013)</b>						
<b>Total Alkalinity (1927)</b>			<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>			
EASTON LAKE RES (1)	10/1/19 - 10/31/19		Complete			
	11/1/19 - 11/30/19		Complete			
	12/1/19 - 12/31/19		Complete			
	1/1/20 - 1/31/20		Complete			
	2/1/20 - 2/29/20		Complete			
	3/1/20 - 3/31/20					
	4/1/20 - 4/30/20					
	5/1/20 - 5/31/20					
	6/1/20 - 6/30/20					
	7/1/20 - 7/31/20					
	8/1/20 - 8/31/20					
	9/1/20 - 9/30/20					
<b>Total Organic Carbon (2920)</b>			<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>			
EASTON LAKE RES (1)	10/1/19 - 10/31/19		Complete			
	11/1/19 - 11/30/19		Complete			
	12/1/19 - 12/31/19		Complete			
	1/1/20 - 1/31/20		Complete			
	2/1/20 - 2/29/20		Complete			
	3/1/20 - 3/31/20					
	4/1/20 - 4/30/20					
	5/1/20 - 5/31/20					
	6/1/20 - 6/30/20					
	7/1/20 - 7/31/20					
	8/1/20 - 8/31/20					
	9/1/20 - 9/30/20					
<b>Total Coliform (3100)</b>			<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: **EASTON LAKE RESERVOIR (WSF ID: 2013)**

<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EASTON LAKE RES (1)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

<b>Surface Water Inorganic Chemicals (RIOC)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EASTON LAKE RES (1)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

<b>Surface Water Color and Turbidity (RPPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EASTON LAKE RES (1)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

<b>Surface Water Pesticides (RSOC)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EASTON LAKE RES (1)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: **TRAP FALLS RESERVOIR (WSF ID: 2016)**

<b>Total Alkalinity (1927)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TRAP FALLS RESERVOIR (1)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Monitoring Requirements

Water System Facility: TRAP FALLS RESERVOIR (WSF ID: 2016)

<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TRAP FALLS RESERVOIR (1)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TRAP FALLS RESERVOIR (1)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
<b>Surface Water Inorganic Chemicals (RIOCI)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TRAP FALLS RESERVOIR (1)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Surface Water Color and Turbidity (RPPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TRAP FALLS RESERVOIR (1)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
<b>Surface Water Pesticides (RSOC)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TRAP FALLS RESERVOIR (1)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: HEMLOCKS WATER TREATMENT PLANT (WSF ID: 21)

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	
Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON							

## Monitoring Requirements

Water System Facility: <b>HEMLOCKS WATER TREATMENT PLANT (WSF ID: 21)</b>				
<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
COMBINED FILTER EFFLUENT - HEMLOCKS TP (5)	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20			
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: <b>TRAP FALLS WTP ENTRY POINT (WSFID: 00700)</b>				
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily	
<b>Start Date:</b> 9/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y	
		11/1/2019 - 11/30/2019	Y	
		12/1/2019 - 12/31/2019	Y	
		1/1/2020 - 1/31/2020	Y	
		2/1/2020 - 2/29/2020		
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily	
<b>Start Date:</b> 9/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y	
		11/1/2019 - 11/30/2019	Y	
		12/1/2019 - 12/31/2019	Y	
		1/1/2020 - 1/31/2020	Y	
		2/1/2020 - 2/29/2020		
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2	
<b>Start Date:</b> 9/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

**Water System Facility: TRAP FALLS WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 9/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020	Y	
	2/1/2020 - 2/29/2020		

**Water System Facility: EASTON WTP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
<b>Start Date:</b> 9/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020	Y	
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 9/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020	Y	
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 9/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020	Y	
	2/1/2020 - 2/29/2020		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

**Water System Facility: HEMLOCKS WTP ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
<b>Start Date:</b> 9/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020	Y	
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 9/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020	Y	
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 9/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020	Y	
	2/1/2020 - 2/29/2020		

**Water System Facility: WESTPORT WELLFIELD TP ENTRY POINT (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.9 MG/L	Continuous
<b>Start Date:</b> 9/1/2013			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	Offline 11/1/2019 - 11/30/2019	n/a	Y
	Offline 12/1/2019 - 12/31/2019	n/a	Y
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

**Water System Facility: WESTPORT WELLFIELD TP ENTRY POINT (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
<b>Start Date:</b> 7/1/2003			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
	Offline	11/1/2019 - 11/30/2019	n/a
	Offline	12/1/2019 - 12/31/2019	n/a
	Offline	1/1/2020 - 1/31/2020	n/a
		2/1/2020 - 2/29/2020	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 7/1/2003			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
	Offline	11/1/2019 - 11/30/2019	n/a
	Offline	12/1/2019 - 12/31/2019	n/a
	Offline	1/1/2020 - 1/31/2020	n/a
		2/1/2020 - 2/29/2020	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 7/1/2003			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
	Offline	11/1/2019 - 11/30/2019	n/a
	Offline	12/1/2019 - 12/31/2019	n/a
	Offline	1/1/2020 - 1/31/2020	n/a
		2/1/2020 - 2/29/2020	Y

**Water System Facility: COLEYTOWN WELLFIELD TP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: .75 MG/L	Continuous
<b>Start Date:</b> 7/1/2013			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
	Offline	11/1/2019 - 11/30/2019	n/a
	Offline	12/1/2019 - 12/31/2019	n/a
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

**Water System Facility: COLEYTOWN WELLFIELD TP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride <b>Start Date:</b> 7/1/2003	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	Offline 11/1/2019 - 11/30/2019	n/a	Y
	Offline 12/1/2019 - 12/31/2019	n/a	Y
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH <b>Start Date:</b> 7/1/2003	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	Offline 11/1/2019 - 11/30/2019	n/a	Y
	Offline 12/1/2019 - 12/31/2019	n/a	Y
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4) <b>Start Date:</b> 7/1/2003	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	Offline 11/1/2019 - 11/30/2019	n/a	Y
	Offline 12/1/2019 - 12/31/2019	n/a	Y
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

**Water System Facility: TRAP FALLS WATER TREATMENT PLANT (WSFID: 14)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine <b>Start Date:</b> 1/1/2002	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

**Water System Facility: TRAP FALLS WATER TREATMENT PLANT (WSFID: 14)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

**Water System Facility: EASTON WATER TREATMENT PLANT (WSFID: 15)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	Y
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	Y
		2/1/2020 - 2/29/2020	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

## Water System Facility: EASTON WATER TREATMENT PLANT (WSFID: 15)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	Y
		2/1/2020 - 2/29/2020	

## Water System Facility: HEMLOCKS WATER TREATMENT PLANT (WSFID: 21)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2020	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
00500	TRAP FALLS WASH WATER RETURN	1	SAMPLE TAP	A					
00501	TRAP FALLS WW RETURN/RAW MIX	1	SAMPLE TAP	A					
00502	EASTON WASH WATER RETURN	1	SAMPLE TAP	A					
00503	EASTON WW RETURN/RAW MIX	1	SAMPLE TAP	A					
00504	HEMLOCKS WASH WATER RETURN	1	SAMPLE TAP	A					
00505	HEMLOCKS WW RETURN/RAW MIX	1	SAMPLE TAP	A					
00506	COLEYTOWN WELLFIELD RAW SAMPLE TAP	00351	COLEY WELLS RAW TAP	A					
		2	RAW	A					
00507	HOUSATONIC WELLFIELD RAW SAMPLE TAP	2	RAW	A					
00508	WESTPORT WELLFIELD RAW SAMPLE TAP	2	RAW	A					
00600	DISTRIBUTION SYSTEM	4	149 Boston Ave Two F	A	Y				
		00014	IRVING B&B	A	Y				
		00016	HUNTINGTON RD FS	A	Y			Y	Y
		00016D	HUNTINGTON RD FS - D	A	Y				
		00016U	HUNTINGTON RD FS - U	A	Y				
		00019	BRINSMADE PS	A	Y				
		00022	UNITED METHODIST HO	A	Y				
		00024	CUMBERLAND FARMS	A	Y				
		00025	TRAP FALLS TANK	A	Y				Y
		00029	TEXACO-HOWE AVE	A	Y				Y
		00030	RADD LAUNDROMAT	A	Y				Y
		00031	CITGO STRATFORD AVE	I	Y				
		00032	LORDSHIP FS	A	Y				Y
		00032D	LORDSHIP F.S. - DOWN	A	Y				
00032U	LORDSHIP F.S. - UPST	A	Y						
00035	TEXACO WHITE PLAINS	A	Y						
00037	LORD CHAMBERLAIN NC	A	Y				Y		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0150011	AQUARION WATER CO OF CT-MAIN SYSTEM	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		00038	ST CATHERINE CHURCH	A	Y			
		00039	GULF MAIN STREET	I	Y			
		00111	FIRESTONE	A	Y		Y	Y
		00112	VILLA CAR WASH	A	Y			Y
		00113	KELLY TIRES	I	Y			
		00115	WOOD AVE FS	A	Y			
		00116	EVERS FS	A	Y			
		00117	SOUTHPORT FS	A	Y			
		00118	GETTY POST ROAD	A	Y			
		00120	CLARENCE ST POLICE	I	Y			
		00121	SUNOCO GRASMERE	A	Y			
		00122	RUSSELL CHEVROLET	A	Y			
		00123	CONGRESS FS	A	Y			
		00125	ROUTE 33 PS	A	Y			Y
		00125D	RT. 33 P.S. - DOWNST	A	Y			
		00125U	RT. 33 P.S. - UPSTRE	A	Y			
		00126	BELDEN HILL PS	A	Y			Y
		00126D	BELDEN HILL P.S. - D	A	Y			
		00126U	BELDEN HILL P.S. - U	A	Y			
		00128	MOBIL TUNXIS	I	Y			
		00134	BROOKSIDE PS	A	Y			Y
		00135	MERRIT PARKWAY INN	A	Y			Y
		00137	PARK AVE MARKET	A	Y			
		00139	SAVE THE CHILDREN	A	Y		Y	
		00210	JACKMAN FS	A	Y			Y
		00210D	JACKMAN F.S. - DOWNS	A	Y			
		00210U	JACKMAN F.S. - UPSTR	A	Y			
		00211	MOBIL STRATFIELD	A	Y			Y
		00211D	MOBIL STRATFIELD - D	A	Y			
		00211U	MOBIL STRATFIELD - U	A	Y			
		00212	JEFFERSON PS	A	Y			Y
		00212D	JEFFERSON P.S. - DOW	A	Y			
		00212U	JEFFERSON P.S. - UPS	A	Y			
		00213	MONROE PS	A	Y			Y
		00214	MADISON FIRE STATION	I				
		00216	TRUMBULL POLICE	A	Y		Y	Y
		00218	GULF HUNTINGTON	A	Y			Y
		00220	BIRCHBANK PS	A	Y			Y

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		00221	WHITE HILLS PUMP STA	A	Y		Y	Y
		00222	PASTORS WALK	A	Y		Y	Y
		00222D	PASTOR'S WALK - DOWN	A	Y			
		00222U	PASTOR'S WALK - UPST	A	Y			
		00228	MEANS BROOK HL	A	Y			Y
		00229	BEECHMONT FS	A	Y			
		00231	BUCK HILL P.S.	A	Y			Y
		00232	NORTH END SEN CTR	I	Y			
		00236	EDISON RD SS	A	Y			Y
		00237	TRUMBULL ANIMAL HOS	A	Y			
		00238	BIRCHBANK SAMPLE STA	A	Y			
		00239	AWC MONROE OFFICE	A	Y			Y
		00239D	AQUARION WQM 200 MON	A	Y			
		00239U	AQUARION WQM 200 MON	A	Y			
		00343	CANNONDALE P.S.	A	Y			Y
		00343D	CANNONDALE PS - DOWN	A	Y			
		00343U	CANNONDALE PS - UPST	A	Y			
		00344	MEADOWRIDGE TNK PS	A	Y			Y
		00357	WEST BRANCH RD SS	A	Y		Y	Y
		01130	GAMBRO MADISON AV	A	Y			
		01130D	DA VITA DIALYSIS - M	A	Y			
		01130U	DA VITA DIALYSIS - M	A	Y			
		01135	GAMBRO BPT AVE	A	Y			
		01149	AWC OPERATIONS CTR	A	Y			Y
		01158	NORTH ST PS WSTPORT	A	Y			Y
		01159	SUNOCO MADISON AVE	A	Y			
		01160	ELVIRAS DELI WPT	A	Y			
		01161	GETTY MOHEGAN RD	A	Y			Y
		01161D	GETTY GAS MOHEGAN RD	A	Y			
		01161U	GETTY GAS MOHEGAN RD	A	Y			
		01162	SHELTON POLICE	A	Y			
		01163	SHELTON PARTY WORL	I	Y			
		01164	BPT - HEALTH DEPT	I	Y			
		01165	OPTIMUS HEALTH-BPT	A	Y	N		
		01166	TWO FOLD LAUNDRY	A	Y			
		01167	CURRAN VOLKSWAGEN	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	
Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		01168	FITNESS 4000	I	Y			Y
		01169	COMPARE FOODS	A	Y			
		01170	BUDDHIST TEMPLE	A	Y			
		01171	NEWFIELD LIBRARY BPT	A	Y			
		01172	LIBRARY 2455 MADISON	A	Y			Y
		01172D	LIBRARY 2455 MADISON	A	Y			
		01172U	LIBRARY 2455 MADISON	A	Y			
		01173	BRIDGEPORT FD	A	Y			
		01174	1 CANAL ST WSPT	A	Y			Y
		01175	MADISON LIBRARY SS	A	Y			Y
		01179	1 CANAL ST WSPT	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MS1	140 MAIN STREET, MON	A	Y			
		PB102	205 FULLING MLL FFLD	A		1		
		PB104	32 BRIDGET FFLD	A		1		
		PB108	83 GRIST MLL SOPORT	A		1		
		PB112	20 BEAGLING HL FFLD	A		1		
		PB115	13 FAR MILL MONROE	A		1		
		PB117	42 HIGHFIELD MONROE	A		1		
		PB119	80 FIELDROCK MONROE	A		1		
		PB120	19 FAR MILL MONROE	A		1		
		PB131	147 CROSS HL MONROE	A		1		
		PB134	30 NELSON BR MONROE	A		1		
		PB139	87 RUGBY SHELTON	A		1		
		PB143	63 PR WENONAH SHEL	A		1		
		PB144	2 JODIE SHELTON	A		1		
		PB147	32 MULBERRY SHELTON	A		1		
		PB148	27 BIG HORN SHELTON	A		1		
		PB156	52 GINA STFD	A		1		
		PB157	395 OAK RIDGE STFD	A		1		
		PB159	120 FAIRCHILD STFD	A		1		
		PB161	930 BEAVER DAM STFD	A		1		
		PB163	400 BRINSMAYD STFD	A		1		
		PB164	1053 CUTSPRING STFD	A		1		
		PB165	260 ASHWOOD STFD	A		1		
		PB168	88 CALHOUN TRUMBULL	A		1		
		PB172	10 DOE HOLLOW TRUMBL	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		PB173	51 OCTOBER TRUMBULL	A		1		
		PB176	3 IVYWOOD TRUMBULL	A		1		
		PB208	98 PRICE BPT	A		1		
		PB218	291 WOODSTOCK STFD	A		1		
		PB225	37 EAST STREET	A		1		
		PB235	896 NICHOLS STFD	A		1		
		PB238	56 VAN STFD	A		1		
		PB239	16 BROOKLAWN PKWY	A	Y	1		
		PB245	301 ROWLAND FFLD	A		1		
		PB259	2020 HUNTINGTON TRUM	A		1		
		PB261	1997 HUNTINGTON TRUM	A		1		
		PB262	2078 HUNTINGTON TRU	A		3		
		PB265	232 NORTH ST	A		1		
		PB268	46 BENSON FFLD	A		1		
		PB269	54 BROOKFIELD FFLD	A		1		
		PB284	26 ESSEX FFLD	A		1		
		PB286	258 FAIRVIEW FFLD	A		1		
		PB291	178 JACKMAN FFLD	A		1		
		PB314	121 CHALMERS BPT	A		1		
		PB326	7 MEADOWVIEW DRIVE	A	Y	1		
		PB327	6 TODDS WAY WSPT	A		3		
		PB341	84 ELLIOTT STFD	A		1		
		PB343	66 NEWTOWN STFD	A		1		
		PB345	PB345 - 42 PAULINE S	A		1		
		PB357	605 BROOKLAWN FFLD	A		1		
		PB359	239 COLONY FFLD	A		1		
		PB360	17 EASTLAWN FFLD	A		1		
		PB363	289 FAIRVIEW FFLD	A		1		
		PB368	43 BROOKVIEW FFLD	A		1		
		PB374	72 NEWMAN FFLD	A		1		
		PB420	316 ORCHARD HL FFLD	A		1		
		PB5844	111 EUERLE STREET	A	Y	3		
		PB6287	61 ARDEN TRUM	A		1		
		PB6315	24 CRESCENT STREET	A	Y	1		
		PB6323	72 UNIVERSITY DR	A	Y	3		
		PB6335	4582 MADISON AVE	A	Y	3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB6336	855 STRATFORD RD	A	Y	3		
		PB6849	501 BIRRPIGJS FF;D	A	Y	3		
		PB6886	1999 N BENSON FFLD	A	Y	1		
		PB6887	9 SPRUCEWOOD WSPT	A	Y	3		
		PB7515	68 LADY SLIPPER DRIV	A	Y	3		
		PB7516	31 HORSE STABLE	A	Y	3		
		PB7517	20 ELDERBERRY LANE	A	Y	3		
		PB8445	70 ALDINE AVE. BPT	A		1		
		PB8446	193 BRADLEY ST. BPT	A		1		
		PB8449	291 GODDARD AVE. BPT	A		1		
		PB8450	101 INDIAN AVE. BPT	A		1		
		PB8452	404 MCKINLEY AVE. BP	A		1		
		PB8453	235 GOLDENROD AVE. B	A		1		
		PB8457	210 WHITNEY AVE. BPT	A		1		
		PB8458	96 INWOOD RD. FFLD	A		1		
		PB8459	46 SENIOR PL. FFLD	A		1		
		PB8461	58 WOODSIDE CIR. FFL	A		1		
		PB8462	650 JUDD ST. FFLD	A		1		
		PB8463	6 THOMSON ST. FFLD	A		1		
		PB8465	42 MERTON ST. FFLD	A		1		
		PB8468	580 REEF RD. FFLD	A		1		
		PB8469	60 CAMBRIDGE ST. FFL	A		1		
		PB8470	147 HUNTINGTON ST SH	A		1		
		PB8472	46 SHAW ST. STRFD	A		1		
		PB8473	46 KETCHAM RD. STRFD	A	Y	1		
		PB8474	155 CUTSPRING RD. ST	A	Y	1		
		PB8475	381 LAUGHLIN RD. ST	A		1		
		PB8476	970 LONGBROOK AVE. S	A		1		
		PB8477	256 LORDSHIP RD. STR	A		1		
		PB8481	106 HILLSPOINT RD. W	A		1		
		PB8482	76 RIVERSIDE AVE. WS	A		1		
		PB86	135 CLOVERHILL BPT	A		1		
		PB8605	1456 NICHOLS AVE STR	A		3		
		PB8612	34 LAUREL GLEN DR. S	A		3		
		PB91	1229 WOOD BPT	A		1		
		PB91 -	PB91 - 1229 WOOD AVE	A	Y			
		PB98	165 POLK BPT	A		1		
		PB98 -	PB98 - 165 POLK ST B	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	TRAP FALLS WTP ENTRY POINT	3	EP - TRAP FALLS	A				
00701	EASTON WTP ENTRY POINT	3	EP - EASTON	A				
00702	HEMLOCKS WTP ENTRY POINT	3	EP - HEMLOCKS	A				
00704	WESTPORT WELLFIELD TP ENTRY POINT	3	EP - WESTPORT	A				
00705	COLEYTOWN WELLFIELD TP ENTRY POINT	3	EP - COLEYTOWN	A				
14	TRAP FALLS WATER TREATMENT PLANT	3	ENTRY POINT - TRAP F	A				
		5	COMBINED FILTER EFFL	A				
1428	WESTPORT WELL #3	2	WESTPORT WELL #3	A				
1430	WESTPORT WELL #4	2	WESTPORT WELL #4	A				
1431	WESTPORT WELL #5	2	WESTPORT WELL #5	A				
1432	COLEYTOWN WELL #1	2	COLEYTOWN WELL #1	A				
1433	COLEYTOWN WELL #2	2	COLEYTOWN WELL #2	A				
15	EASTON WATER TREATMENT PLANT	3	ENTRY POINT - EASTON	A				
		5	COMBINED FILTER EFFL	A				
16	WESTPORT WELLFIELD TREATMENT PLANT							
1641	WESTPORT WELL #7	2	WESTPORT WELL #7	A				
17	COLEYTOWN WELLFIELD TREATMENT PLANT							
2009	HEMLOCKS RESERVOIR	1	HEMLOCKS RESERVOIR	A				
2010	ASPETUCK RESERVOIR	1	RESERVOIR	A				
2011	SAUGATUCK RESERVOIR	1	RESERVOIR	A				
2012	MOREHOUSE BROOK DIVERSION	1	RESERVOIR	A				
2013	EASTON LAKE RESERVOIR	1	EASTON LAKE RES	A				
2014	WEST PEQUONNOCK DIVERSION	1	RESERVOIR	A				
2015	BOYS HALFWAY RIVER DIVERSION	1	RESERVOIR	A				
2016	TRAP FALLS RESERVOIR	1	TRAP FALLS RESERVOIR	A				
2017	MEANS BROOK RESERVOIR	1	RESERVOIR	A				
2018	FAR MILL RESERVOIR	1	RESERVOIR	A				
21	HEMLOCKS WATER TREATMENT PLANT	3	ENTRY POINT - HEMLOC	A				
		5	COMBINED FILTER EFFL	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
30015	TRAP FALLS RESERVOIR INTAKE							
30016	HEMLOCKS RESERVOIR INTAKE							
30017	EASTON LAKE RESERVOIR INTAKE							
46179	INTERCONNECTION - CT1180011 - BRANCHVILLE							
48560	INTERCONNECTION - CT1350011 - HOYT							
49055	WILTON ROAD PUMP STATION							
50043	INTERCONNECTION - CT1030011 - ROUTE 7							
50059	INTERCONNECTION - CT1030011 - MURRAY							
53332	MEANS BROOK PUMP STATION							
53334	WHITE HILLS PUMP STATION							
53336	WHITE HILLS STORAGE TANK							
53338	MONROE CENTRE STORAGE TANK							
53340	MONROE CENTRE PUMP STATION							
53342	PASTORS WALK STORAGE TANK							
53344	PASTORS WALK PUMP STATION							
53346	NORTH AVENUE PUMP STATION							
53348	NORTH AVENUE STORAGE TANK							
53350	BELDEN HILL PUMP STATION							
53352	BELDEN HILL STORAGE TANK - EAST							
53354	BELDEN HILL STORAGE TANK - WEST							
53356	CANNONDALE BOOSTER STATION							
53358	MEADOW RIDGE PUMP STATION							
53360	MEADOW RIDGE STORAGE TANK							
53362	TRAP FALLS WTP STORAGE TANK							
53364	NICHOLS PUMP STATION							
53366	NICHOLS ELEVATED STORAGE TANK							
53368	BRINSMADE PUMP STATION							
53370	BRINSMADE STORAGE TANK							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

**Towns Served:** BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
53372	ORONOQUE PUMP STATION							
53374	TUNXIS HILL PUMP STATION							
53376	BROOKSIDE PUMP STATION							
53378	GREENFIELD ELEVATED STORAGE TANK							
53380	SAMP MORTAR PUMP STATION							
53382	BUCK HILL PUMP STATION							
53384	TASHUA HILLS PUMP STATION							
53386	TASHUA HILLS STORAGE TANK							
53388	JEFFERSON STREET PUMP STATION							
53390	FAIRCHILD WHEELER ELEVATED STORAGE TANK							
53392	PINE STREET ELEVATED STORAGE TANK							
53394	EASTON STORAGE TANK - NORTH							
53396	EASTON STORAGE TANK - SOUTH							
53398	EASTON WTP RAW WATER PUMP STATION							
53402	TRAP FALLS WTP CLEARWELL							
53404	490 TRAP FALLS PUMP STATION							
53412	HEMLOCKS WTP CLEARWELL							
53414	HEMLOCKS WTP STORAGE TANK							
53416	HEMLOCKS WTP RAW WATER PUMP STATION							
53418	HEMLOCKS WTP HIGH LIFT PUMP STATION							
59992	MATTHEWS BOOSTER PUMP STATION							
61393	INTERCONNECTION - CT1030011 - SAUGATUCK							
61396	INTERCONNECTION - CT1030011 - WINFIELD							
61408	INTERCONNECTION - CT1350011 - WESTPORT							

### Certified Operator Information

--

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	C	351,756	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LOTT, LESTER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2021
HILDRED, JR., ALAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
TORRES, JR., MIGUEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
ANDERSON, JOHN K.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
CHAPMAN, RICHARD A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
ULBRICK, FRED	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2022
CARSWELL, JEFF	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
FABSO, CHARLES P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
BURKE, JONATHAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2022
MALANCA, DANTE A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2023
GARDNER, GREGORY L.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
METZ, ERIC J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022

**Water System Facility: TRAP FALLS WATER TREATMENT PLANT (WSF ID: 14)**

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FABSO, CHARLES P.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
TORRES, JR., MIGUEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
CHAPMAN, RICHARD A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2022
CAVERLY, DONISE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2021
LIBERANTE, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
GORMAN, TERRENCE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2021
MALANCA, DANTE A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2023
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020

**Water System Facility: EASTON WATER TREATMENT PLANT (WSF ID: 15)**

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WELSH, JOE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
LIBERANTE, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
MALANCA, DANTE A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2023

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0150011</b>	<b>AQUARION WATER CO OF CT-MAIN SYSTEM</b>	<b>C</b>	351,756	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						107,938	

Towns Served: BEACON FALLS, BRIDGEPORT, DARIEN, EASTON, FAIRFIELD, GREENWICH, MONROE, NEW CANAAN, NEWTOWN, NORWALK, REDDING, RIDGEFIELD, SEYMOUR, SHELTON, STAMFORD, STRATFORD, TRUMBULL, WESTON, WESTPORT, WILTON

## Certified Operator Information

**Water System Facility: EASTON WATER TREATMENT PLANT (WSF ID: 15)**

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020

**Water System Facility: WESTPORT WELLFIELD TREATMENT PLANT (WSF ID: 16)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TORRES, JR., MIGUEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2022

**Water System Facility: COLEYTOWN WELLFIELD TREATMENT PLANT (WSF ID: 17)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TORRES, JR., MIGUEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020

**Water System Facility: HEMLOCKS WATER TREATMENT PLANT (WSF ID: 21)**

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BYRON, ROY	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
SCALES, GEORGE M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
WELSH, JOE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
FAUSTIN, JOSEPH	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2022

## Contact Information

Name		Organization			Job Title			
<b>Mr. John P. Walsh</b>		Aquarion Water Company			Vice President			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
835 Main Street			Mail Stop 700			Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com			

**Contact Role(s):** Administrative Contact, Legal Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**