

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320292</b>	<b>COVENTRY HIGH &amp; NATHAN HALE SCHOOLS</b>	NTNC	1,252	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
78 RIPLEY HILL ROAD			1				

Towns Served: COVENTRY

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>2 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/20	6/1-9/30			
	1/1/21 - 12/31/21	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>2 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
<b>Water System Facility: ENTRY POINT - WELLS 1, 2, &amp; 3 (WSF ID: 00701)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0320292	COVENTRY HIGH & NATHAN HALE SCHOOLS	NTNC	1,252	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
78 RIPLEY HILL ROAD			1				

Towns Served: COVENTRY

## Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 1, 2, & 3 (WSF ID: 00701)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, & 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, & 3 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, & 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, & 3 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	1	CHS KITCHEN SINK	P		3		
		10	CNH 8TH GR HALL COOL	P		3		
		2	CHS CAFE FOUNTAIN	P		3		
		3	CHS LEC HALL FOUNT	P		3		
		4	DISTRIBUTION SYSTEM	A	Y			
		4-C	CHS SCI HALL FOUNT	P	Y	3		
		5	AUD/PE WATER COOL	P		3		
		6	CONNECTOR WTR COOL	P		3		
		7	CNH KITCHEN SINK	P		3		
		8	CNH CAFE SINK	P		3		
9	CNH FRONT HALL COOL	P		3				
	DOWNSTREAM WITHIN 5 SERVICE CON			A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320292</b>	<b>COVENTRY HIGH &amp; NATHAN HALE SCHOOLS</b>	NTNC	1,252	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
78 RIPLEY HILL ROAD			1				
Towns Served: COVENTRY							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		P	GIRL BATH NEAR LECT	P	Y			
		T	NURSES OFFICE_CNH	P	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELLS 1, 2, & 3	3	EP - WELLS 1, 2, & 3	A				
55911	WELL 1	2	WELL 1	A				
55914	WELL 2	2	WELL 2	A				
55916	WELL 3	2	WELL 3	A				
55918	TREATMENT PLANT							
55920	ATMOSPHERIC TANK							
55922	PRESSURE TANK							
55924	PUMP STATION							

## Certified Operator Information

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification:</b> CLASS 1 DISTRIBUTION SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021 6/30/2020
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022 6/30/2020
<b>Water System Facility: TREATMENT PLANT (WSF ID: 55918)</b>			
<b>Facility Classification:</b> CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021 6/30/2020

## Contact Information

Name		Organization			Job Title			
<b>Mr. William Trudelle</b>		Coventry Board of Education			Facilities Director			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
78 Ripley Hill Road						Coventry	CT	06238
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-742-4568				860-234-1960	wtrudelle@coventryct.org			
Contact Role(s):		<b>Administrative Contact, Legal Contact</b>						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
<b>CT0320292</b>	<b>COVENTRY HIGH &amp; NATHAN HALE SCHOOLS</b>	NTNC	1,252	L	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
78 RIPLEY HILL ROAD		1				
Towns Served: COVENTRY						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320302</b>	<b>COVENTRY GRAMMAR SCHOOL</b>	NTNC	558	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3453 MAIN STREET			1				

Towns Served: COVENTRY

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/20	6/1-9/30			
	1/1/21 - 12/31/21	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: <b>ENTRY POINT - WELLS 1 AND 2 (WSF ID: 00700)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 1 AND 2 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 1 AND 2 (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20		Complete		
	1/1/21 - 12/31/21				
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 1 AND 2 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320302</b>	<b>COVENTRY GRAMMAR SCHOOL</b>	NTNC	558	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3453 MAIN STREET			1				

Towns Served: COVENTRY

## Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLS 1 AND 2 (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1 AND 2 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	1	KITCHEN SINK	P		3		
		10	9C DRINKING FOUNTAIN	P		3		
		2	3A DRINKING FOUNTAIN	P		3		
		3	8A DRINKING FOUNTAIN	P		3		
		4	DISTRIBUTION SYSTEM	A	Y			
		4-B	1B DRINKING FOUNTAIN	P		3		
		5	5B DRINKING FOUNTAIN	P		3		
		6	CONNECTOR WTR CLR	P		3		
		7	LIBRARY OFFICE SINK	P		3		
		8	C WING WORKROOM	P		3		
		9	C WING WATER COOLER	P		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		P	GIRL BATH NEAR MEDIA	P	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELLS 1 AND 2	3	EP - WELLS 1 AND 2	A				
56059	WELL 1	2	WELL 1	A				
56061	WELL 2	2	WELL 2	A				
56063	ATMOSPHERIC TANK							
56065	BLADDER TANK							
56067	PUMP STATION							

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320302</b>	<b>COVENTRY GRAMMAR SCHOOL</b>	NTNC	558	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3453 MAIN STREET			1				
Towns Served: COVENTRY							

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

## Contact Information

Name		Organization			Job Title		
<b>Mr. Paul Noel</b>		Coventry Public Schools			Director Plant & Fac		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
1700 Main Street					Coventry	CT	06238-1654
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-742-4525		860-742-5505			pnoel@coventryct.org		

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
<b>Mr. William Trudelle</b>		Coventry Board of Education			Facilities Director		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
78 Ripley Hill Road					Coventry	CT	06238
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-742-4568				860-234-1960	wtrudelle@coventryct.org		

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320312</b>	<b>GEORGE HERSEY ROBERTSON SCHOOL</b>	NTNC	573	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
227 CROSS STREET			2				
Towns Served: COVENTRY							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/20	6/1-9/30			
	1/1/21 - 12/31/21	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: <b>ENTRY POINT - WELLS 2 &amp; 3 (WSF ID: 00701)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 2 & 3 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 2 & 3 (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20		Complete		
	1/1/21 - 12/31/21				
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 2 & 3 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320312</b>	<b>GEORGE HERSEY ROBERTSON SCHOOL</b>	NTNC	573	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
227 CROSS STREET			2				
Towns Served: COVENTRY							

## Monitoring Requirements

**Water System Facility: ENTRY POINT - WELLS 2 & 3 (WSF ID: 00701)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 3 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	1	KITCHEN SINK	P		3		
		10	RM 116 CLASSRM SINK	P		3		
		2	GYM LBY WATER COOLR	P		3		
		3	FRNT HALL WTR COOL	P		3		
		4	DISTRIBUTION SYSTEM	A	Y			
		4-S	STAFF LOUNGE SINK	P	Y	3		
		5	RM 216 CLASSRM SINK	P		3		
		6	RM 214 CLASSRM SINK	P		3		
		7	4TH GR HALL WTR CLR	P		3		
		8	5TH GR HALL WTR CLR	P		3		
		9	RM 113 CLASSRM SINK	P		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELLS 2 & 3	3	EP - WELLS 2 & 3	A				
10168	WELL 2	2	WELL 2	A				
55898	WELL 3	2	WELL 3	A				
55901	ATMOSPHERIC TANK							
55905	PRESSURE TANK							
55908	PUMP STATION							

## Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification: SMALL WATER SYSTEM**

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2022

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320312</b>	<b>GEORGE HERSEY ROBERTSON SCHOOL</b>	NTNC	573	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
227 CROSS STREET			2				
Towns Served: COVENTRY							

## Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
Facility Classification: SMALL WATER SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

## Contact Information

Name		Organization			Job Title		
<b>Mr. Paul Noel</b>		Coventry Public Schools			Director Plant & Fac		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
1700 Main Street					Coventry	CT	06238-1654
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-742-4525		860-742-5505			pnoel@coventryct.org		

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
<b>Mr. William Trudelle</b>		Coventry Board of Education			Facilities Director		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
78 Ripley Hill Road					Coventry	CT	06238
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-742-4568				860-234-1960	wtrudelle@coventryct.org		

Contact Role(s): **Administrative Contact**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
  2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
  3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0321172</b>	<b>MEADOWBROOK SHOPPING CENTER</b>	NTNC	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1657 BOSTON TURNPIKE				2			
Towns Served: COVENTRY							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/22	6/1-9/30			
	1/1/23 - 12/31/25	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Di(2-Ethylhexyl) - Phthalate (2039)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0321172</b>	<b>MEADOWBROOK SHOPPING CENTER</b>	NTNC	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1657 BOSTON TURNPIKE				2			
Towns Served: COVENTRY							

## Monitoring Requirements

Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>							
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
<b>Organic Chemicals (VOCS)</b>				<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/19 - 12/31/19				Complete	
		1/1/20 - 12/31/20					
		1/1/21 - 12/31/21					

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2021	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10169	WELL #1	2	WELL #1	A				

## Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
Facility Classification: SMALL WATER SYSTEM			
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	<b>Certification Expiration</b>
STAVENS, JOEL	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR	6/30/2020

## Contact Information

Name		Organization			Job Title		
<b>Mr. Matthew Miner</b>		Coventry Meadowbrook Center LI			Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
1721 Boston Turnpike					Coventry	CT	06238
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0321172</b>	<b>MEADOWBROOK SHOPPING CENTER</b>	NTNC	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1657 BOSTON TURNPIKE				2			
Towns Served: COVENTRY							
860-742-7361				860-202-5926			
Contact Role(s):	<b>Administrative Contact, Legal Contact, Owner</b>						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320154</b>	<b>PRINCE OF PEACE LUTHERAN CHURCH</b>	NTNC	34	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 NORTH RIVER ROAD				1			
Towns Served: COVENTRY							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/22	6/1-9/30			
	1/1/23 - 12/31/25	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Nitrate (1040)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Nitrite (1041)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/20 - 12/31/20		Complete		
	1/1/21 - 12/31/21				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/21				
	1/1/22 - 12/31/24				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320154</b>	<b>PRINCE OF PEACE LUTHERAN CHURCH</b>	NTNC	34	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 NORTH RIVER ROAD				1			
Towns Served: COVENTRY							

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 6/30/19	1/1-6/30	Complete
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION EXEMPTION	3/1/2012	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW001	KITCHEN SINK	A	Y	2	Y	Y
		MW002	KITCHEN SINK #2	A	Y	2	Y	Y
		MW003	MENS ROOM	A	Y	2	Y	Y
		MW004	WOMENS ROOM	A	Y	2	Y	Y
		MW005	SLOP SINK	A	Y	2	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10905	WELL	2	WELL	A				
50390	WELL-X-TROL BLADDER STORAGE							

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021
LAFRAMBOISE, JEFFREY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0320154</b>	<b>PRINCE OF PEACE LUTHERAN CHURCH</b>	NTNC	34	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
10 NORTH RIVER ROAD				1			
Towns Served: COVENTRY							

### Contact Information

Name			Organization			Job Title			
<b>Ms. Susan I. Driscoll</b>			Prince of Peace Luth. Church			Director/Treasurer			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
10 North River Road						Coventry		CT	06238
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-742-7548				860-487-1957					

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0321193	COVENTRY KIDS CENTER	NTNC	80	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1548 MAIN STREET			1				
Towns Served: COVENTRY							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Asbestos (1094) 1 routine (RT) per nine years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		

**Total Coliform (3100) 1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

**Lead And Copper (PBCU) 5 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	

**Physical Parameters (PPS) 1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

**Inorganic Chemicals (IOCS) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

**Nitrate And Nitrite (NOX) 1 routine (RT) per year**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

**Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

**Organic Chemicals (VOCS) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
------------------------------------	-------------------	-------------------	-------------------

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0321193</b>	<b>COVENTRY KIDS CENTER</b>	NTNC	80	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1548 MAIN STREET			1				
Towns Served: COVENTRY							

## Monitoring Requirements

<b>Water System Facility: ENTRY POINT (WSF ID: 00700)</b>			
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION EXEMPTION	3/1/2018	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW003	KITCHEN	A	Y	N		
		MW013-L	KIDS BATHROOM LEFT	A	Y	N		
		MW013-R	KIDS BATHROOM RIGHT	A	Y	N		
		MW017	ADULT BATHROOM	I	Y			
		MW017-A	ADULT BATHROOM	A	Y	N	Y	Y
		MW017-S	BATHROOM SINK	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10959	WELL #1	2	WELL	A				

## Certified Operator Information

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification:</b> SMALL WATER SYSTEM			
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021
LAFRAMBOISE, JEFFREY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020

## Contact Information

Name			Organization			Job Title			
Ms. Carolyn B. Dulac			Coventry Kids Center			Owner/Director			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1548 Main Street						Coventry		CT	06238
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-742-7890		860-742-6300		860-424-2217	carolyn@coventrykids.com				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0321193</b>	<b>COVENTRY KIDS CENTER</b>	NTNC	80	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1548 MAIN STREET			1				
Towns Served: COVENTRY							
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**