

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0470052</b>	<b>BASSDALE PLAZA - WELL #1</b>	NTNC	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
150 NORTH ROAD			4				
Towns Served: EAST WINDSOR							

### Monitoring Requirements

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>							
<b>Asbestos (1094)</b>			<b>1 routine (RT) per nine years</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		1/1/11 - 12/31/19				Complete	
		1/1/20 - 12/31/28					
<b>Total Coliform (3100)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		7/1/19 - 9/30/19				Complete	
		10/1/19 - 12/31/19				Complete	
		1/1/20 - 3/31/20					
		4/1/20 - 6/30/20					
		7/1/20 - 9/30/20					
<b>Lead And Copper (PBCU)</b>			<b>5 routine (RT) per year</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		1/1/19 - 12/31/19		6/1-9/30		Complete	
		1/1/20 - 12/31/20		6/1-9/30			
		1/1/21 - 12/31/21		6/1-9/30			
<b>Physical Parameters (PPS)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points		7/1/19 - 9/30/19				Complete	
		10/1/19 - 12/31/19				Complete	
		1/1/20 - 3/31/20					
		4/1/20 - 6/30/20					
		7/1/20 - 9/30/20					
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>							
<b>Inorganic Chemicals (IOCS)</b>			<b>1 routine (RT) per three years</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/18 - 12/31/20					
		1/1/21 - 12/31/23					
<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/19 - 12/31/19				Complete	
		1/1/20 - 12/31/20					
		1/1/21 - 12/31/21					
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>			<b>1 routine (RT) per three years</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/18 - 12/31/20					
		1/1/21 - 12/31/23					
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>			<b>1 routine (RT) per three years</b>				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/18 - 12/31/20					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0470052</b>	<b>BASSDALE PLAZA - WELL #1</b>	NTNC	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
150 NORTH ROAD			4				

Towns Served: EAST WINDSOR

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

**Pesticides, Herbicides and PCBs-Phase V (SOC5)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/21 - 12/31/23		

**Organic Chemicals (VOCS)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
RESPOND TO SANITARY SURVEY	4/20/2014	
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	7/19/2014	
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	7/19/2014	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2014	
CROSS CONNECTION SURVEY REPORT	3/1/2015	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2015	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2017	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
CROSS CONNECTION EXEMPTION	3/1/2019	
RESPOND TO SANITARY SURVEY	3/13/2019	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2019	

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Turbidity M&R Violation	4/1/19 - 6/30/19	3	9/19/2020		9/29/2020	
pH M&R Violation	4/1/19 - 6/30/19	3	9/19/2020		9/29/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>		<i>Asbestos WQP 2 DBPR</i>		<i>Stage</i>
					<i>Y</i>	<i>Asbestos</i>	<i>WQP 2</i>	<i>DBPR</i>		
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A						
59018	WELL 2	2	WELL 2	A						
59028	HYDROPNEUMATIC TANK									

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0470052</b>	<b>BASSDALE PLAZA - WELL #1</b>	NTNC	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
150 NORTH ROAD			4				

Towns Served: EAST WINDSOR

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
SCHNEIDER, KEITH	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2020

## Contact Information

Name		Organization		Job Title		
<b>Ms. Caroline Bass</b>				Property Manager		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
50 West 72St St		Apt 309		New York	NY	10023
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
646-703-2053					caroline.bass@corcoran.com	

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0473023</b>	<b>SOPHIAS PLAZA II/III</b>	NTNC	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
122 PROSPECT HILL ROAD				1			
Towns Served: EAST WINDSOR							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/20	6/1-9/30			
	1/1/21 - 12/31/21	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Water System Facility: ENTRY POINT (WSF ID: 00700)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0473023</b>	<b>SOPHIAS PLAZA II/III</b>	NTNC	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
122 PROSPECT HILL ROAD				1			
Towns Served: EAST WINDSOR							

## Monitoring Requirements

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>			<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

<b>Organic Chemicals (VOCS)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2017	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y	1		
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
		SP1	UNIT 1 - PLAZA II	A	Y	1		
		SP2	UNIT 2 - PLAZA II	A	Y	1		
		SP3	UNIT 7 - PLAZA II	A	Y	1		
		SP4	COT-BLDGIII	A	Y	1		
		SP5	MO-BLDGIII	A	Y	1		
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10857	WELL #1	2	WELL #1	A				

## Certified Operator Information

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification: SMALL WATER SYSTEM</b>			
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
TARTSINIS, DESPINA C.	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR CONDITIONAL	6/30/2020

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0473023</b>	<b>SOPHIAS PLAZA II/III</b>	NTNC	40	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
122 PROSPECT HILL ROAD				1				
Towns Served: EAST WINDSOR								
Contact Information								
Name				Organization		Job Title		
<b>Ms. Despina C. Tartsinis</b>				Sofia's Plazas				
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
122 Prospect Hill Road			C/O Management Office			East Windsor	CT	06088
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-623-9581				860-559-3748	sofiasplazas@gmail.com			
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>								
<b>Please note the following:</b>								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**