

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0480062</b>	<b>CRYSTAL LAKE SCHOOL</b>	NTNC	275	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 SOUTH ROAD				2			
Towns Served: ELLINGTON							

### Monitoring Requirements

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>							
<b>Asbestos (1094)</b>			<b>1 routine (RT) per nine years</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete				
	1/1/20 - 12/31/28						
<b>Total Coliform (3100)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete				
	10/1/19 - 12/31/19		Complete				
	1/1/20 - 3/31/20		Complete				
	4/1/20 - 6/30/20						
	7/1/20 - 9/30/20						
<b>Lead And Copper (PBCU)</b>			<b>10 routine (RT) per six months</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/19 - 12/31/19		Complete				
	1/1/20 - 6/30/20						
	7/1/20 - 12/31/20						
<b>Physical Parameters (PPS)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete				
	10/1/19 - 12/31/19		Complete				
	1/1/20 - 3/31/20		Complete				
	4/1/20 - 6/30/20						
	7/1/20 - 9/30/20						
<b>Water System Facility: ENTRY POINT - WELLS 1, 2, &amp; 3 (WSF ID: 00701)</b>							
<b>Dibromochloropropane (DBCP) (2931)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
ENTRY POINT (3)	7/1/19 - 9/30/19		Complete				
	10/1/19 - 12/31/19		Complete				
EP - WELLS 1, 2, & 3 (3)	4/1/20 - 6/30/20						
	7/1/20 - 9/30/20						
<b>Inorganic Chemicals (IOCS)</b>			<b>1 routine (RT) per three years</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
EP - WELLS 1, 2, & 3 (3)	1/1/17 - 12/31/19		Complete				
	1/1/20 - 12/31/22						
	1/1/23 - 12/31/25						
<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
EP - WELLS 1, 2, & 3 (3)	1/1/19 - 12/31/19		Complete				
	1/1/20 - 12/31/20		Complete				
	1/1/21 - 12/31/21						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0480062</b>	<b>CRYSTAL LAKE SCHOOL</b>	NTNC	275	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 SOUTH ROAD				2			
Towns Served: ELLINGTON							

## Monitoring Requirements

<b>Water System Facility: ENTRY POINT - WELLS 1, 2, &amp; 3 (WSF ID: 00701)</b>			
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, & 3 (3)	1/1/17 - 12/31/19	1/1-12/31	Waiver
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, & 3 (3)	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, & 3 (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

<b>Water System Facility: ENTRY POINT - WELLS 1, 2, &amp; 3 (WSFID: 00701)</b>			
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.7 PH	Daily
<b>Start Date:</b> 7/1/2018		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	
		11/1/2019 - 11/30/2019	
		12/1/2019 - 12/31/2019	
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.3 PH	Daily
<b>Start Date:</b> 7/1/2018		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019	
		11/1/2019 - 11/30/2019	
		12/1/2019 - 12/31/2019	
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CCTS 6: PWS MONITOR AFTER OCCT INSTALL		
CROSS CONNECTION EXEMPTION	3/1/2019	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0480062</b>	<b>CRYSTAL LAKE SCHOOL</b>	NTNC	275	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 SOUTH ROAD				2			
Towns Served: ELLINGTON							

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	6/30/2020	6/20/2018

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CLS001	NURSE'S FRONT SINK	A	Y	N		
		CLS002	NURSE'S BACK SINK	A	Y	N		
		CLS003	KITCHEN PREP SINK L	A	Y	N		
		CLS004	FOUNTAIN NEAR CAFE	A		N		
		CLS005	STAFF LOUNGE	A	Y	N		
		CLS006	FOUNTAIN ROOM # 157	A	Y	N		
		CLS007	FOUNTAIN ROOM # 153	A	Y	N		
		CLS008	FOUNTAIN OUTSIDE 153	A		N		
		CLS009	CAFÉ WATER FOUNTAIN	A		N		
		CLS010	GYM WATER FOUNTAIN	A		N		
		CLS011	ROOM 168 FOUNTAIN	A		N		
		CLS012	ROOM 180 FOUNTAIN	A		N		
		CLS013	ROOM 160 FOUNTAIN	A		N		
		CLS014	FOUNTAIN NEAR NURSE	A		N		
		CLS015	FOUNTAIN ACROSS 157	A		N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW001	NURSES OFFICE	I	Y			
		MW002	KITCHEN	I	Y			
		MW003	BOYS LAV	I	Y			
		MW004	BOYS LOCKER RM	I	Y			
		MW005	GIRLS LOCKER RM	I	Y			
		MW006	CLASS ROOM #3	I	Y			
		MW007	CLASS ROOM #7	I	Y			
		MW008	CLASS ROOM #8	I	Y			
		MW009	CLASS ROOM #9	I	Y			
		MW010	CLASS ROOM #10	I	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELLS 1, 2, & 3	3	EP - WELLS 1, 2, & 3	A				
53968	WEST WELL 2	2	WEST WELL 2	A				
53970	EAST WELL 3	2	EAST WELL 3	A				
53972	TREATMENT PLANT - WELLS 2 & 3							
53975	ATMOSPHERIC TANK							
53977	PRESSURE TANK							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0480062</b>	<b>CRYSTAL LAKE SCHOOL</b>	NTNC	275	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 SOUTH ROAD				2			
Towns Served: ELLINGTON							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Rule Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
53979	PUMP STATION						

## Certified Operator Information

Water System Facility: **TREATMENT PLANT - WELLS 2 & 3 (WSF ID: 53972)**

### Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021

## Contact Information

Name		Organization			Job Title	
<b>Dr. Scott Nicol</b>		Ellington Public Schools			Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
47 Main Street		P.O. Box 179		Ellington	CT	06029
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-896-2300	117	860-896-2312			snicol@ellingtonschools.net	

Contact Role(s): **Legal Contact**

Name		Organization			Job Title	
<b>Ms. Rebecca Gonzalez</b>		Ellington Public Schools			Director, Facilities	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
P. O. Box 179		47 Main Street		Ellington	CT	06029
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-324-5344		860-870-6250		860-324-5344	rgonzalez@ellingtonschools.net	

Contact Role(s): **Administrative Contact**

### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0481033</b>	<b>BOLLES MOTORS INC</b>	NTNC	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
84 WEST ROAD, ELLINGTON				1			
Towns Served: ELLINGTON							

### Monitoring Requirements

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>							
<b>Asbestos (1094)</b>			<b>1 routine (RT) per nine years</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
DISTRIBUTION (4)	1/1/18 - 12/31/26						
<b>Total Coliform (3100)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete				
	10/1/19 - 12/31/19		Complete				
	1/1/20 - 3/31/20						
	4/1/20 - 6/30/20						
	7/1/20 - 9/30/20						
<b>Lead And Copper (PBCU)</b>			<b>5 routine (RT) per six months</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
DISTRIBUTION (4)	7/1/19 - 12/31/19		Complete				
	1/1/20 - 6/30/20						
	7/1/20 - 12/31/20						
<b>Physical Parameters (PPS)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
DISTRIBUTION (4)	7/1/19 - 9/30/19		Complete				
	10/1/19 - 12/31/19		Complete				
	1/1/20 - 3/31/20						
	4/1/20 - 6/30/20						
	7/1/20 - 9/30/20						
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>							
<b>Inorganic Chemicals (IOCS)</b>			<b>1 routine (RT) per three years</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
ENTRY POINT (3)	1/1/18 - 12/31/20		Complete				
	1/1/21 - 12/31/23						
<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete				
	1/1/20 - 12/31/20						
	1/1/21 - 12/31/21						
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>			<b>1 (RT) per three years</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
ENTRY POINT (3)	1/1/20 - 12/31/22	1/1-12/31	Waiver				
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>			<b>1 routine (RT) per three years</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
ENTRY POINT (3)	1/1/23 - 12/31/25						
<b>Organic Chemicals (VOCS)</b>			<b>1 routine (RT) per quarter</b>				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0481033</b>	<b>BOLLES MOTORS INC</b>	NTNC	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
84 WEST ROAD, ELLINGTON				1			
Towns Served: ELLINGTON							

## Monitoring Requirements

Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>			
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2019	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/30/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	004	MENS ROOM SHOW ROOM	A	Y	2		
		006	MENS ROOM SERVICE DE	A		2		
		4	DISTRIBUTION	A	Y			
		DOWNSTREAM	5 SERVICE CONNECTION	A	Y			
		UPSTREAM	5 SERVICE CONNECTION	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
61078	WELL	2	WELL	A				

## Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification:</b>			<b>Certification Expiration</b>
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	
MARTIN, VALARIE	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR	9/30/2021

## Contact Information

Name		Organization			Job Title		
<b>Mr. Brian E. Bolles</b>		Bolles Motors Inc			General Manager		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
84 West Road					Ellington	CT	06029
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-875-2595	107	860-875-3038			BollesMotorsGM@BollesMotors.com		
Contact Role(s):		<b>Administrative Contact, Legal Contact, Owner</b>					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0481033</b>	<b>BOLLES MOTORS INC</b>	NTNC	40	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
84 WEST ROAD, ELLINGTON				1				
Towns Served: ELLINGTON								
Name			Organization		Job Title			
<b>Ms. Darlene Russell</b>			Bolles Motors Inc		Office Manager			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
84 West Road						Ellington	CT	06029
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-875-2595	105	860-875-3038		860-306-2426	bollesmotorsgm@bollesmotors.com			
Contact Role(s): <b>Legal Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**