

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		15 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20			
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
Asbestos (1094)		3 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		Complete	
	1/1/21 - 12/31/29			
Total Coliform (3100)		15 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20			
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
921 FARMINGTON (WWTP) (42001)	7/1/19 - 9/30/19	7/1-7/31	Complete	
	10/1/19 - 12/31/19	10/1-10/31	Complete	
	1/1/20 - 3/31/20	1/1-1/31	Complete	
	4/1/20 - 6/30/20	4/1-4/30		
1820 NEW BRITAIN AVE (43001A)	7/1/20 - 9/30/20	7/1-7/31		
	7/1/19 - 9/30/19	7/1-7/31	Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/19 - 12/31/19	10/1-10/31	Complete
	1/1/20 - 3/31/20	1/1-1/31	Complete
	4/1/20 - 6/30/20	4/1-4/30	
	7/1/20 - 9/30/20	7/1-7/31	
258 MAIN ST FARMG (4752A)	7/1/19 - 9/30/19	7/1-7/31	Complete
	10/1/19 - 12/31/19	10/1-10/31	Complete
	1/1/20 - 3/31/20	1/1-1/31	Complete
	4/1/20 - 6/30/20	4/1-4/30	
	7/1/20 - 9/30/20	7/1-7/31	
RT10 PS WATERVILLE (4753)	7/1/19 - 9/30/19	7/1-7/31	Complete
	10/1/19 - 12/31/19	10/1-10/31	Complete
	1/1/20 - 3/31/20	1/1-1/31	Complete
	4/1/20 - 6/30/20	4/1-4/30	
	7/1/20 - 9/30/20	7/1-7/31	

Lead And Copper (PBCU)		30 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete
	1/1/20 - 12/31/22	6/1-9/30	
	1/1/23 - 12/31/25	6/1-9/30	

Physical Parameters (PPS)		15 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **ENTRY POINT - WELLCTSS (WSF ID: 00703)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLCTSS (WSF ID: 00703)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL CTS (3)	1/1/19 - 12/31/19		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLCTSS (WSF ID: 00703)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	1/1/20 - 12/31/20			
	1/1/21 - 12/31/21			

Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			

Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - WELL CTS (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			

Organic Chemicals (VOCS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - WELL CTS (3)	7/1/19 - 9/30/19		Out of Service	
	10/1/19 - 12/31/19		Out of Service	
	1/1/20 - 3/31/20			
	4/1/20 - 6/30/20			
	7/1/20 - 9/30/20			

Water System Facility: ENTRY POINT - WELLP (WSF ID: 00705)

Net Gross Alpha (4000)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - WELL P (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			

Uranium (4006)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - WELL P (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			

Combined Radium-226/228 (4010)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - WELL P (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - WELL P (3)	1/1/18 - 12/31/20			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLP (WSF ID: 00705)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL P (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL P (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL P (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL P (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: **ENTRY POINT - WELLS 1, 2, 3, 4 & 5 (WSF ID: 00707)**

Dieldrin (2070)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLS 1, 2, 3, 4 & 5 (WSF ID: 00707)**

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: **ENTRY POINT - FIP WELL #3 (WSF ID: 00708)**

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - FIP WELL #3 (3)	7/1/19 - 9/30/19		Out of Service
	10/1/19 - 12/31/19		Out of Service
	1/1/20 - 3/31/20		
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - FIP WELL #3 (3)	1/1/19 - 12/31/19		Out of Service
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Monitoring Requirements

Water System Facility: ENTRY POINT - FIP WELL #3 (WSF ID: 00708)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - FIP WELL #3 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - FIP WELL #3 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Organic Chemicals (VOCS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - FIP WELL #3 (3)	7/1/19 - 9/30/19		Out of Service		
	10/1/19 - 12/31/19		Out of Service		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				

Water System Facility: ENTRY POINT - FIP WELL #4 (WSF ID: 00709)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - FIP WELL #4 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - FIP WELL #4 (3)	1/1/19 - 12/31/19		Out of Service		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - FIP WELL #4 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Organic Chemicals (VOCS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - FIP WELL #4 (3)	7/1/19 - 9/30/19		Out of Service		
	10/1/19 - 12/31/19		Out of Service		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **PONDWOOD WELL (WSF ID: 1028)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PONDWOOD WELL (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **FIP WELL #3 (WSF ID: 10829)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
FIP WELL #3 (2)	10/1/19 - 10/31/19		Out of Service
	11/1/19 - 11/30/19		Out of Service
	12/1/19 - 12/31/19		Out of Service
	1/1/20 - 1/31/20		Out of Service
	2/1/20 - 2/29/20		Out of Service
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **FIP WELL #4 (WSF ID: 10830)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
FIP WELL #4 (2)	10/1/19 - 10/31/19		Out of Service
	11/1/19 - 11/30/19		Out of Service
	12/1/19 - 12/31/19		Out of Service
	1/1/20 - 1/31/20		Out of Service
	2/1/20 - 2/29/20		Out of Service
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **FIP WELL #4 (WSF ID: 10830)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **C HOUSE WELL 2 (WSF ID: 1298)**

Dieldrin (2070)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
C HOUSE WELL 2 (2)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
C HOUSE WELL 2 (2)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
C HOUSE WELL 2 (2)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Water System Facility: **C HOUSE WELL 1 (WSF ID: 1299)**

Dieldrin (2070)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
C HOUSE WELL 1 (2)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
C HOUSE WELL 1 (2)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
C HOUSE WELL 1 (2)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Monitoring Requirements

Water System Facility: **C HOUSE WELL 1 (WSF ID: 1299)**

Pesticides, Herbicides and PCBs-Phase V (SOC5) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Water System Facility: **CT SAND & STONE WELL #1 (WSF ID: 1452)**

E. Coli (3014) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CT. SAND AND STONE W (2)	10/1/19 - 10/31/19		Out of Service
	11/1/19 - 11/30/19		Out of Service
	12/1/19 - 12/31/19		Out of Service
	1/1/20 - 1/31/20		Out of Service
	2/1/20 - 2/29/20		Out of Service
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLCTSS (WSFID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		10/1/2019 - 10/31/2019	
		11/1/2019 - 11/30/2019	
		12/1/2019 - 12/31/2019	
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 5/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		10/1/2019 - 10/31/2019	
		11/1/2019 - 11/30/2019	
		12/1/2019 - 12/31/2019	
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							
Water System Facility: ENTRY POINT - WELLP (WSFID: 00705)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 5/1/2003		Compliance History:	Operating Limit	Monitoring			
		Monitoring Period	Compliance Status:	Compliance Status:			
		10/1/2019 - 10/31/2019					
		11/1/2019 - 11/30/2019					
		12/1/2019 - 12/31/2019					
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Water System Facility: ENTRY POINT - WELLS 1, 2, 3, 4 & 5 (WSFID: 00707)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.50 MG/L			Daily		
Start Date: 7/1/2018		Compliance History:	Operating Limit	Monitoring			
		Monitoring Period	Compliance Status:	Compliance Status:			
		10/1/2019 - 10/31/2019	Y				
		11/1/2019 - 11/30/2019	N				
		12/1/2019 - 12/31/2019	Y				
		1/1/2020 - 1/31/2020	Y				
		2/1/2020 - 2/29/2020					
Water System Facility: ENTRY POINT - FIP WELL #3 (WSFID: 00708)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 1/1/2006		Compliance History:	Operating Limit	Monitoring			
		Monitoring Period	Compliance Status:	Compliance Status:			
		10/1/2019 - 10/31/2019					
		11/1/2019 - 11/30/2019					
		12/1/2019 - 12/31/2019					
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE		5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Water System Facility: ENTRY POINT - FIP WELL #4 (WSFID: 00709)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2006	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019		
	11/1/2019 - 11/30/2019		
	12/1/2019 - 12/31/2019		
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2016	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		42001	921 FARMINGTON (WWTP)	A				Y
		43001	1814 NEW BRITAIN AVE	I				Y
		43001A	1820 NEW BRITAIN AVE	A				Y
		47401	11 DEEPWOOD RD	A		3		
		47402	9 CUTLER LANE	A		1		
		47403	3 LARCHWOOD WEST	A		N		
		47404	33 FIELD STONE	A		1		
		47405	9 STONEGATE	A		N		
		47406	5 NEWBURY COURT	A		N		
		47407	4 VIRGINIA LANE	A		N		
		47409	5 BURKE CROSSING	A		N		
		47410	11 VIRGINIA LANE	A		N		
		47411	62 OAKRIDGE	A		N		
		47412	11 TALLWOOD	A		1		
		47413	11 LARCHWOOD WEST	A		N		
		47414	4 ESSEX COURT	A		1		
		47415	36 CANTERBURY LANE	A		1		
		47416	4 COBBLESTONE	A		N		
		47417	33 CANTERBURY LANE	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47418	33 OAKRIDGE	A		N		
		47419	7 BLENHEIM TERRACE	A		N		
		47420	10 ESSEX COURT	A		1		
		47421	1 ESSEX COURT	A		1		
		47422	15 COPE FARMS RD	A		1		
		47423	7 VIRGINIA LANE	A		N		
		47424	12 COPE FARMS RD	A		1		
		47425	9 SHIPS OAK	A		1		
		47426	7 HARTFIELD LANE	A		1		
		47427	62 COPE FARMS RD	A		1		
		47428	5 COPE FARMS RD	A		1		
		47429	6 SHIPS OAK LANE	A		1		
		47430	12 MALS WAY	A		N		
		47460	36 SPRING LANE	A		3		
		47461	26 BASSWOOD RD	A	Y	1		
		47462	68 BASSWOOD RD	A	Y	1		
		47463	70 BASSWOOD RD	A	Y	1		
		47464	14 BLUEBERRY LN	A	Y	1		
		47465	243 BRICKYARD RD	A	Y	1		
		47466	248 BRICKYARD RD	A	Y	1		
		47467	2 COPE FARMS RD	A	Y	1		
		47468	4 COPE FARMS RD	A	Y	1		
		47469	6 COPE FARMS RD	A	Y	1		
		47470	7 COPE FARMS RD	P	Y	1		
		47471	8 COPE FARMS RD	P	Y	1		
		47472	10 COPE FARMS RD	P	Y	1		
		47473	11 COPE FARMS RD	P	Y	1		
		47474	11 COPE FARMS RD	P	Y	1		
		47475	14 COPE FARMS RD	P	Y	1		
		47476	16 COPE FARMS RD	P	Y	1		
		47477	17 COPE FARMS RD	P	Y	1		
		47478	18 COPE FARMS RD	P	Y	1		
		47479	19 COPE FARMS RD	P	Y	1		
		47480	20 COPE FARMS RD	P	Y	1		
		47481	22 COPE FARMS RD	P	Y	1		
		47482	23 COPE FARMS RD	P	Y	1		
		47483	24 COPE FARMS RD	P	Y	1		
		47484	25 COPE FARMS RD	P	Y	1		
		47485	26 COPE FARMS RD	P	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47486	27 COPE FARMS RD	P	Y	1		
		47487	28 COPE FARMS RD	P	Y	1		
		47488	29 COPE FARMS RD	P	Y	1		
		47489	30 COPE FARMS RD	P	Y	1		
		47490	31 COPE FARMS RD	P	Y	1		
		47491	32 COPE FARMS RD	P	Y	1		
		47492	33 COPE FARMS RD	P	Y	1		
		47493	34 COPE FARMS RD	P	Y	1		
		47494	35 COPE FARMS RD	P	Y	1		
		47495	36 COPE FARMS RD	P	Y	1		
		47496	37 COPE FARMS RD	P	Y	1		
		47497	38 COPE FARMS RD	P	Y	1		
		47498	39 COPE FARMS RD	P	Y	1		
		47499	40 COPE FARMS RD	P	Y	1		
		47500	41 COPE FARMS RD	P	Y	1		
		47501	43 COPE FARMS RD	P	Y	1		
		47502	44 COPE FARMS RD	P	Y	1		
		47503	45 COPE FARMS RD	P	Y	1		
		47504	46 COPE FARMS RD	P	Y	1		
		47505	47 COPE FARMS RD	P	Y	1		
		47506	48 COPE FARMS RD	P	Y	1		
		47507	49 COPE FARMS RD	P	Y	1		
		47508	51 COPE FARMS RD	P	Y	1		
		47509	57 COPE FARMS RD	P	Y	1		
		4751	12 MILL ST, UNIONVIL	A	Y			Y
		47510	59 COPE FARMS RD	P	Y	1		
		47511	60 COPE FARMS RD	P	Y	1		
		47512	61 COPE FARMS RD	P	Y	1		
		47513	63 COPE FARMS RD	P	Y	1		
		47514	64 COPE FARMS RD	P	Y	1		
		47515	65 COPE FARMS RD	P	Y	1		
		47516	66 COPE FARMS RD	P	Y	1		
		47517	67 COPE FARMS RD	P	Y	1		
		47518	68 COPE FARMS RD	P	Y	1		
		47519	69 COPE FARMS RD	P	Y	1		
		4751X	20 SOUTH MAIN ST	I	Y			Y
		47520	70 COPE FARMS RD	P	Y	1		
		47521	75 COPE FARMS RD	P	Y	1		
		47522	77 COPE FARMS RD	P	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47523	78 COPE FARMS RD	P	Y	1		
		47524	79 COPE FARMS RD	P	Y	1		
		47525	81 COPE FARMS RD	P	Y	1		
		47526	14 CROSSWOOD RD	P	Y	1		
		47527	16 CROSSWOOD RD	P	Y	1		
		47528	26 CROSSWOOD RD	P	Y	1		
		47529	27 CROSSWOOD RD	P	Y	1		
		4752A	258 MAIN ST FARMG	A	Y		Y	Y
		4752B	254 MAIN ST FARMG	A	Y			Y
		4753	RT10 PS WATERVILLE	A	Y			Y
		47530	28 CROSSWOOD RD	P	Y	1		
		47531	30 CROSSWOOD RD	P	Y	1		
		47532	32 CROSSWOOD RD	P	Y	1		
		47533	35 CROSSWOOD RD	P	Y	1		
		47534	36 CROSSWOOD RD	P	Y	1		
		47535	37 CROSSWOOD RD	P	Y	1		
		47536	38 CROSSWOOD RD	P	Y	1		
		47537	39 CROSSWOOD RD	P	Y	1		
		47538	40 CROSSWOOD RD	P	Y	1		
		47539	42 CROSSWOOD RD	P	Y	1		
		4753A	3 PHEASANT HILL	A	Y			
		4754	WELLS DRIVE	A	Y			
		47540	44 CROSSWOOD RD	P	Y	1		
		47541	47 CROSSWOOD RD	P	Y	1		
		47542	48 CROSSWOOD RD	P	Y	1		
		47543	3 CUTLER LN	P	Y	1		
		47544	4 CUTLER LN	P	Y	1		
		47545	5 CUTLER LN	P	Y	1		
		47546	6 CUTLER LN	P	Y	1		
		47547	7 CUTLER LN	P	Y	1		
		47548	8 CUTLER LN	P	Y	1		
		47549	10 CUTLER LN	P	Y	1		
		4755	HUCKLEBERRY HILL PS	A	Y			
		47550	11 CUTLER LN	P	Y	1		
		47551	12 CUTLER LN	P	Y	1		
		47552	2 DEEPWOOD RD	P	Y	1		
		47553	3 DEEPWOOD RD	P	Y	1		
		47554	4 DEEPWOOD RD	P	Y	1		
		47555	2 ESSEX CT	P	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47556	3 ESSEX CT	P	Y	1		
		47557	5 ESSEX CT	P	Y	1		
		47558	8 ESSEX CT	P	Y	1		
		47559	11 ESSEX CT	P	Y	1		
		4756	KNOLLWOOD PS	A	Y		Y	
		47560	12 ESSEX CT	P	Y	1		
		47561	14 ESSEX CT	P	Y	1		
		47562	17 FIELDSTONE RUN	P	Y	1		
		47563	23 FIELDSTONE RUN	P	Y	1		
		47564	25 FIELDSTONE RUN	P	Y	1		
		47565	35 FIELDSTONE RUN	P	Y	1		
		47566	39 FIELDSTONE RUN	P	Y	1		
		47567	47 FIELDSTONE RUN	P	Y	1		
		47568	73 FIELDSTONE RUN	P	Y	1		
		47569	95 FIELDSTONE RUN	P	Y	1		
		4757	PONDWOOD PS	I	Y			
		47570	187 GARDEN ST	P	Y	1		
		47571	2 GLENEAGLES DR	P	Y	1		
		47572	3 GLENEAGLES DR	P	Y	1		
		47573	3 GLENMORE DR	P	Y	1		
		47574	4 GLENMORE DR	P	Y	1		
		47575	5 GLENMORE DR	P	Y	1		
		47576	6 GLENMORE DR	P	Y	1		
		47577	7 GLENMORE DR	P	Y	1		
		47578	9 GLENMORE DR	P	Y	1		
		47579	11 GLENMORE DR	P	Y	1		
		4758	14 LITCHFIELD RD	I			Y	
		47580	12 GLENMORE DR	P	Y	1		
		47581	14 GLENMORE DR	P	Y	1		
		47582	14 GLENMORE DR	P	Y	1		
		47583	17 GLENMORE DR	P	Y	1		
		47584	98 HAROLD RD	P	Y	1		
		47585	23 HAROLD RD	P	Y	1		
		47586	45 HAROLD RD	P	Y	1		
		47587	58 HAROLD RD	P	Y	1		
		47588	59 HAROLD RD	P	Y	1		
		47589	60 HAROLD RD	P	Y	1		
		4759	FOREST PARK BLDG 4	A				
		47590	61 HAROLD RD	P	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47591	63 HAROLD RD	P	Y	1		
		47592	64 HAROLD RD	P	Y	1		
		47593	65 HAROLD RD	P	Y	1		
		47594	67 HAROLD RD	P	Y	1		
		47595	71 HAROLD RD	P	Y	1		
		47596	74 HAROLD RD	P	Y	1		
		47597	75 HAROLD RD	P	Y	1		
		47598	77 HAROLD RD	P	Y	1		
		47599	78 HAROLD RD	P	Y	1		
		4760	362 SCOTT SWAMP RD	A	Y			
		47600	79 HAROLD RD	P	Y	1		
		47601	81 HAROLD RD	P	Y	1		
		47602	82 HAROLD RD	P	Y	1		
		47603	83 HAROLD RD	P	Y	1		
		47604	85 HAROLD RD	P	Y	1		
		47605	87 HAROLD RD	P	Y	1		
		47606	93 HAROLD RD	P	Y	1		
		47607	94 HAROLD RD	P	Y	1		
		47608	99 HAROLD RD	P	Y	1		
		47609	100 HAROLD RD	P	Y	1		
		4761	16 SPRING LANE	A	Y	N		
		47610	102 HAROLD RD	P	Y	1		
		47611	103 HAROLD RD	P	Y	1		
		47612	104 HAROLD RD	P	Y	1		
		47613	105 HAROLD RD	P	Y	1		
		47614	106 HAROLD RD	P	Y	1		
		47615	110 HAROLD RD	P	Y	1		
		47616	2 HARTFIELD LN	P	Y	1		
		47617	3 HARTFIELD LN	P	Y	1		
		47618	6 HARTFIELD LN	P	Y	1		
		47619	6 HARTFIELD LN	P	Y	1		
		4762	25 NEW BRITAIN AVE	A	Y			
		47620	7 HARTFIELD LN	P	Y	1		
		47621	8 HARTFIELD LN	P	Y	1		
		47622	9 HARTFIELD LN	P	Y	1		
		47623	2 HORSESHOE LN	P	Y	1		
		47624	23 HYDE RD	P	Y	1		
		47625	2 INDIAN HILL RD	P	Y	1		
		47626	3 INDIAN HILL RD	P	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47627	6 INDIAN HILL RD	P	Y	1		
		47628	12 INDIAN HILL RD	P	Y	1		
		47629	12 INDIAN HILL RD	P	Y	1		
		4763	BUTLER BOOSTER STA	A				
		47630	15 INDIAN HILL RD	P	Y	1		
		47631	18 INDIAN HILL RD	P	Y	1		
		47632	19 INDIAN HILL RD	P	Y	1		
		47633	22 INDIAN HILL RD	P	Y	1		
		47634	23 INDIAN HILL RD	P	Y	1		
		47635	26 INDIAN HILL RD	P	Y	1		
		47636	28 INDIAN HILL RD	P	Y	1		
		47637	31 INDIAN HILL RD	P	Y	1		
		47638	32 INDIAN HILL RD	P	Y	1		
		47639	33 INDIAN HILL RD	P	Y	1		
		4764	544 NEW BRITAIN AVE	A				
		47640	37 INDIAN HILL RD	P	Y	1		
		47641	38 INDIAN HILL RD	P	Y	1		
		47642	40 INDIAN HILL RD	P	Y	1		
		47643	41 INDIAN HILL RD	P	Y	1		
		47644	43 INDIAN HILL RD	P	Y	1		
		47645	44 INDIAN HILL RD	P	Y	1		
		47646	1 LOWELL RD	P	Y	1		
		47647	2 LOWELL RD	P	Y	1		
		47648	3 LOWELL RD	P	Y	1		
		47649	5 LOWELL RD	P	Y	1		
		47650	6 LOWELL RD	P	Y	1		
		47651	363 MAIN ST	P	Y	1		
		47652	367 MAIN ST	P	Y	1		
		47653	412 MAIN ST	P	Y	1		
		47654	15 MAPLEWOOD DR	P	Y	1		
		47655	8 MICHAEL DR	P	Y	1		
		47656	9 MICHAEL DR	P	Y	1		
		47657	11 MICHAEL DR	P	Y	1		
		47658	12 MICHAEL DR	P	Y	1		
		47659	14 MICHAEL DR	P	Y	1		
		47660	15 MICHAEL DR	P	Y	1		
		47661	17 MICHAEL DR	P	Y	1		
		47662	19 MICHAEL DR	P	Y	1		
		47663	20 MICHAEL DR	P	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47664	21 MICHAEL DR	P	Y	1		
		47665	22 MICHAEL DR	P	Y	1		
		47666	25 MICHAEL DR	P	Y	1		
		47667	26 MICHAEL DR	P	Y	1		
		47668	27 MICHAEL DR	P	Y	1		
		47669	28 MICHAEL DR	P	Y	1		
		47670	29 MICHAEL DR	P	Y	1		
		47671	30 MICHAEL DR	P	Y	1		
		47672	33 MICHAEL DR	P	Y	1		
		47673	34 MICHAEL DR	P	Y	1		
		47674	1 ASH CT	P	Y	2		
		47675	2 ASH CT	P	Y	2		
		47676	3 ASH CT	P	Y	2		
		47677	4 ASH CT	P	Y	2		
		47678	5 ASH CT	P	Y	2		
		47679	6 ASH CT	P	Y	2		
		47680	7 ASH CT	P	Y	2		
		47681	8 ASH CT	P	Y	2		
		47682	9 ASH CT	P	Y	2		
		47683	10 ASH CT	P	Y	2		
		47684	11 ASH CT	P	Y	2		
		47685	12 ASH CT	P	Y	2		
		47686	13 ASH CT	P	Y	2		
		47687	14 ASH CT	P	Y	2		
		47688	15 ASH CT	P	Y	2		
		47689	16 ASH CT	P	Y	2		
		47690	17 ASH CT	P	Y	2		
		47691	18 ASH CT	P	Y	2		
		47692	19 ASH CT	P	Y	2		
		47693	20 ASH CT	P	Y	2		
		47694	21 ASH CT	P	Y	2		
		47695	22 ASH CT	P	Y	2		
		47696	1 CARDINAL DR	P	Y	2		
		47697	2 CARDINAL DR	P	Y	2		
		47698	3 CARDINAL DR	P	Y	2		
		47699	4 CARDINAL DR	P	Y	2		
		47700	5 CARDINAL DR	P	Y	2		
		47701	6 CARDINAL DR	P	Y	2		
		47702	7 CARDINAL DR	P	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47703	8 CARDINAL DR	P	Y	2		
		47704	9 CARDINAL DR	P	Y	2		
		47705	10 CARDINAL DR	P	Y	2		
		47706	11 CARDINAL DR	P	Y	2		
		47707	12 CARDINAL DR	P	Y	2		
		47708	13 CARDINAL DR	P	Y	2		
		47709	14 CARDINAL DR	P	Y	2		
		47710	15 CARDINAL DR	P	Y	2		
		47711	16 CARDINAL DR	P	Y	2		
		47712	1 CYPRESS TRL	P	Y	2		
		47713	2 CYPRESS TRL	P	Y	2		
		47714	3 CYPRESS TRL	P	Y	2		
		47715	4 CYPRESS TRL	P	Y	2		
		47716	5 CYPRESS TRL	P	Y	2		
		47717	6 CYPRESS TRL	P	Y	2		
		47718	7 CYPRESS TRL	P	Y	2		
		47719	8 CYPRESS TRL	P	Y	2		
		47720	9 CYPRESS TRL	P	Y	2		
		47721	10 CYPRESS TRL	P	Y	2		
		47722	11 CYPRESS TRL	P	Y	2		
		47723	12 CYPRESS TRL	P	Y	2		
		47724	13 CYPRESS TRL	P	Y	2		
		47725	14 CYPRESS TRL	P	Y	2		
		47726	15 CYPRESS TRL	P	Y	2		
		47727	16 CYPRESS TRL	P	Y	2		
		47728	1 EVERGREEN TRAIL	P	Y	2		
		47729	18 EVERGREEN TRAIL	P	Y	2		
		47730	2 EVERGREEN TRAIL	P	Y	2		
		47731	3 EVERGREEN TRAIL	P	Y	2		
		47732	4 EVERGREEN TRAIL	P	Y	2		
		47733	5 EVERGREEN TRAIL	P	Y	2		
		47734	6 EVERGREEN TRAIL	P	Y	2		
		47735	7 EVERGREEN TRAIL	P	Y	2		
		47736	8 EVERGREEN TRAIL	P	Y	2		
		47737	9 EVERGREEN TRAIL	P	Y	2		
		47738	10 EVERGREEN TRAIL	P	Y	2		
		47739	11 EVERGREEN TRAIL	P	Y	2		
		47740	12 EVERGREEN TRAIL	P	Y	2		
		47741	13 EVERGREEN TRAIL	P	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47742	14 EVERGREEN TRAIL	P	Y	2		
		47743	15 EVERGREEN TRAIL	P	Y	2		
		47744	16 EVERGREEN TRAIL	P	Y	2		
		47745	17 EVERGREEN TRAIL	P	Y	2		
		47746	19 EVERGREEN TRAIL	P	Y	2		
		47747	20 EVERGREEN TRAIL	P	Y	2		
		47748	1 FIELD ROCK RD	P	Y	2		
		47749	2 FIELD ROCK RD	P	Y	2		
		47750	3 FIELD ROCK RD	P	Y	2		
		47751	4 FIELD ROCK RD	P	Y	2		
		47752	5 FIELD ROCK RD	P	Y	2		
		47753	6 FIELD ROCK RD	P	Y	2		
		47754	7 FIELD ROCK RD	P	Y	2		
		47755	8 FIELD ROCK RD	P	Y	2		
		47756	9 FIELD ROCK RD	P	Y	2		
		47757	10 FIELD ROCK RD	P	Y	2		
		47758	11 FIELD ROCK RD	P	Y	2		
		47759	12 FIELD ROCK RD	P	Y	2		
		47760	13 FIELD ROCK RD	P	Y	2		
		47761	14 FIELD ROCK RD	P	Y	2		
		47762	15 FIELD ROCK RD	P	Y	2		
		47763	16 FIELD ROCK RD	P	Y	2		
		47764	17 FIELD ROCK RD	P	Y	2		
		47765	18 FIELD ROCK RD	P	Y	2		
		47766	19 FIELD ROCK RD	P	Y	2		
		47767	20 FIELD ROCK RD	P	Y	2		
		47768	21 FIELD ROCK RD	P	Y	2		
		47769	22 FIELD ROCK RD	P	Y	2		
		47770	23 FIELD ROCK RD	P	Y	2		
		47771	24 FIELD ROCK RD	P	Y	2		
		47772	1 GARDEN PATH	P	Y	2		
		47773	2 GARDEN PATH	P	Y	2		
		47774	3 GARDEN PATH	P	Y	2		
		47775	4 GARDEN PATH	P	Y	2		
		47776	5 GARDEN PATH	P	Y	2		
		47777	6 GARDEN PATH	P	Y	2		
		47778	7 GARDEN PATH	P	Y	2		
		47779	8 GARDEN PATH	P	Y	2		
		47780	9 GARDEN PATH	P	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47781	10 GARDEN PATH	P	Y	2		
		47782	11 GARDEN PATH	P	Y	2		
		47783	12 GARDEN PATH	P	Y	2		
		47784	13 GARDEN PATH	P	Y	2		
		47785	14 GARDEN PATH	P	Y	2		
		47786	15 GARDEN PATH	P	Y	2		
		47787	16 GARDEN PATH	P	Y	2		
		47788	17 GARDEN PATH	P	Y	2		
		47789	18 GARDEN PATH	P	Y	2		
		47790	19 GARDEN PATH	P	Y	2		
		47791	20 GARDEN PATH	P	Y	2		
		47792	21 GARDEN PATH	P	Y	2		
		47793	22 GARDEN PATH	P	Y	2		
		47794	23 GARDEN PATH	P	Y	2		
		47795	24 GARDEN PATH	P	Y	2		
		47796	25 GARDEN PATH	P	Y	2		
		47797	26 GARDEN PATH	P	Y	2		
		47798	27 GARDEN PATH	P	Y	2		
		47799	28 GARDEN PATH	P	Y	2		
		47800	29 GARDEN PATH	P	Y	2		
		47801	30 GARDEN PATH	P	Y	2		
		47802	43 HAROLD RD	P	Y	2		
		47803	19-21 HAROLD RD	P	Y	2		
		47804	33 HAROLD RD A/B	P	Y	2		
		47805	1 LILAC LN	P	Y	2		
		47806	2 LILAC LN	P	Y	2		
		47807	3 LILAC LN	P	Y	2		
		47808	4 LILAC LN	P	Y	2		
		47809	5 LILAC LN	P	Y	2		
		47810	6 LILAC LN	P	Y	2		
		47811	7 LILAC LN	P	Y	2		
		47812	8 LILAC LN	P	Y	2		
		47813	9 LILAC LN	P	Y	2		
		47814	10 LILAC LN	P	Y	2		
		47815	11 LILAC LN	P	Y	2		
		47816	12 LILAC LN	P	Y	2		
		47817	13 LILAC LN	P	Y	2		
		47818	14 LILAC LN	P	Y	2		
		47819	15 LILAC LN	P	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47820	16 LILAC LN	P	Y	2		
		47821	1 LOCUST LN	P	Y	2		
		47822	2 LOCUST LN	P	Y	2		
		47823	3 LOCUST LN	P	Y	2		
		47824	4 LOCUST LN	P	Y	2		
		47825	5 LOCUST LN	P	Y	2		
		47826	6 LOCUST LN	P	Y	2		
		47827	7 LOCUST LN	P	Y	2		
		47828	8 LOCUST LN	P	Y	2		
		47829	9 LOCUST LN	P	Y	2		
		47830	10 LOCUST LN	P	Y	2		
		47831	11 LOCUST LN	P	Y	2		
		47832	12 LOCUST LN	P	Y	2		
		47833	13 LOCUST LN	P	Y	2		
		47834	14 LOCUST LN	P	Y	2		
		47835	15 LOCUST LN	P	Y	2		
		47836	16 LOCUST LN	P	Y	2		
		47837	17 LOCUST LN	P	Y	2		
		47838	18 LOCUST LN	P	Y	2		
		47839	19 LOCUST LN	P	Y	2		
		47840	20 LOCUST LN	P	Y	2		
		47841	21 LOCUST LN	P	Y	2		
		47842	22 LOCUST LN	P	Y	2		
		47843	23 LOCUST LN	P	Y	2		
		47844	24 LOCUST LN	P	Y	2		
		47845	25 LOCUST LN	P	Y	2		
		47846	26 LOCUST LN	P	Y	2		
		47847	27 LOCUST LN	P	Y	2		
		47848	28 LOCUST LN	P	Y	2		
		47849	29 LOCUST LN	P	Y	2		
		47850	30 LOCUST LN	P	Y	2		
		47851	31 LOCUST LN	P	Y	2		
		47852	32 LOCUST LN	P	Y	2		
		47853	33 LOCUST LN	P	Y	2		
		47854	34 LOCUST LN	P	Y	2		
		47855	35 LOCUST LN	P	Y	2		
		47856	36 LOCUST LN	P	Y	2		
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00703	ENTRY POINT - WELLCTSS	3	EP - WELL CTS	A				
00705	ENTRY POINT - WELLP	3	EP - WELL P	A				
00707	ENTRY POINT - WELLS 1, 2, 3, 4 & 5	3	EP - WELLS 1, 2, 3,	A				
00708	ENTRY POINT - FIP WELL #3	3	EP - FIP WELL #3	A				
00709	ENTRY POINT - FIP WELL #4	3	EP - FIP WELL #4	A				
051081	BUTLER ROAD BOOSTER SYSTEM							
1028	PONDWOOD WELL	2	PONDWOOD WELL	A				
10829	FIP WELL #3	2	FIP WELL #3	A				
10830	FIP WELL #4	2	FIP WELL #4	A				
1295	C HOUSE WELL 5	2	C HOUSE WELL 5	A				
1296	C HOUSE WELL 4	2	C HOUSE WELL 4	A				
1297	C HOUSE WELL 3	2	C HOUSE WELL 3	A				
1298	C HOUSE WELL 2	2	C HOUSE WELL 2	A				
1299	C HOUSE WELL 1	2	C HOUSE WELL 1	A				
1452	CT SAND & STONE WELL #1	2	CT. SAND AND STONE W	A				
47028	ANVIL DRIVE TANK							
47030	FARMINGTON TANK							
47032	SOUTHWEST TANK							
48928	INTERCONNECTION - CT0640011 - ROUTE 4							
61402	INTERCONNECTION - CT0640011 - MOUNTAIN							
85	CHARLES HOUSE WELL 4	5	EP - WELL 4	A				
87	CT SAND & STONE WELL #1 TP							
89	PONDWOOD WELL							
979	FIP WELL #3 TREATMENT PLANT							
980	FIP WELL #4 TREATMENT PLANT							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: CLASS 2 DISTRIBUTION SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2022
DUNNE, III, EDWARD P.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2022
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	
Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021
RUOT, DAVID A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2020

Water System Facility: **CHARLES HOUSE WELL 4 (WSF ID: 85)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WINSLOW, KEITH	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2020
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021

Water System Facility: **CT SAND & STONE WELL #1 TP (WSF ID: 87)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMS, GREG	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2022
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2022
DUNNE, III, EDWARD P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022

Water System Facility: **PONDWOOD WELL (WSF ID: 89)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMS, GREG	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2022
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022

Water System Facility: **FIP WELL #3 TREATMENT PLANT (WSF ID: 979)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMS, GREG	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2022
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2022
DUNNE, III, EDWARD P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0520011	CTWC - UNIONVILLE SYSTEM	C	14,693	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
25 NEW BRITAIN AVE			5,877	349	47	46	

Towns Served: AVON, BRISTOL, FARMINGTON, PLAINVILLE

Certified Operator Information

Water System Facility: FIP WELL #4 TREATMENT PLANT (WSF ID: 980)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMS, GREG	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2022
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2022
DUNNE, III, EDWARD P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021

Contact Information

Name		Organization			Job Title	
Mr. Craig J. Patla		Connecticut Water Company			Vp, Service Delivery	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6140				800-391-1924	cpatla@ctwater.com	

Contact Role(s): Legal Contact

Name		Organization			Job Title	
Mr. David Connors		Connecticut Water Company			Director, Service De	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main St				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6141				860-227-4902	dconnors@ctwater.com	

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0529051	CTWC - CHIMNEY HILL	C	227	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MOUNTAIN ROAD			46	1			
Towns Served: FARMINGTON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
301 COLT HIGHWAY (4770)	1/1/19 - 12/31/19	9/1-9/30	Complete		
	1/1/20 - 12/31/20	9/1-9/30			
	1/1/21 - 12/31/21	9/1-9/30			
Lead And Copper (PBCU)		5 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0529051	CTWC - CHIMNEY HILL	C	227	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MOUNTAIN ROAD			46	1			
Towns Served: FARMINGTON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU)	5 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/21	6/1-9/30	

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	CHIMNEY HILL DISTRIB	A	Y			
		4770	301 COLT HIGHWAY	A	Y	N		Y
		4771	4771 10 CHIMNEY HILL	A	Y	N		
		47710	47710 12 CHIMNEY HIL	A	Y	N		
		47711	47711 2 CHIMNEY HILL	A	Y	N		
		47712	47712 14 CHIMNEY HIL	A	Y	N		
		47713	47713 30 CHIMNEY HIL	A	Y	N		
		47715	47715 27 CHIMNEY HIL	A	Y	N		
		47716	1 CHIMNEY HILL	A	Y	N		
		47717	19 CHIMNEY HILL	A	Y	N		
		47718	21 CHIMNEY HILL	A	Y	N		
		47719	23 CHIMNEY HILL	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0529051	CTWC - CHIMNEY HILL	C	227	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MOUNTAIN ROAD			46	1			
Towns Served: FARMINGTON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
		4772	4772 8 CHIMNEY HILL	A	Y	N			
		47720	24 CHIMNEY HILL	A	Y	N			
		47721	25 CHIMNEY HILL	A	Y	N			
		47722	26 CHIMNEY HILL	A	Y	N			
		47723	28N CHIMNEY HILL	A	Y	N			
		47724	3 HEARTHSTONE LN	A	Y	N			
		47725	4 HEARTHSTONE	A	Y	N			
		47726	5 HEARTHSTONE LN	A	Y	N			
		47727	6 HEARTHSTONE LN	A	Y	N			
		47728	7 HEARTHSTONE LN	A	Y	N			
		47729	8 HEARTHSTONE LN	A	Y	N			
		4773	4773 5 CHIMNEY HILL	A	Y	N			
		47730	9 HEARTHSTONE LN	A	Y	N			
		47731	17 HEARTHSTONE LN	A	Y	N			
		47732	18 HEARTHSTONE LN	A	Y	N			
		47733	2 HEARTHSTONE LN	A	Y	N			
		4774	4774 7 CHIMNEY HILL	A	Y	N			
		4775	4775 3 CHIMNEY HILL	A	Y	N			
		4776	4776 16 CHIMNEY HILL	A	Y	N			
		4777	4777 20 CHIMNEY HILL	A	Y	N			
		4778	4778 18 CHIMNEY HILL	A	Y	N			
		4779	4779 22 CHIMNEY HILL	A	Y	N			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
57787	INTERCONNECTION - MDC								

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: SMALL WATER SYSTEM			
			Certification Expiration
Operator Name	Operator Type	Certification(s)	Expiration
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2022 6/30/2020
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2021 6/30/2022
RUOT, DAVID A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2020

Contact Information

Name	Organization	Job Title
Mr. Craig J. Patla	Connecticut Water Company	Vp, Service Delivery
Mailing Address Line One	Mailing Address Line Two	City State Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0529051	CTWC - CHIMNEY HILL	C	227	P	SWP			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
MOUNTAIN ROAD			46	1				
Towns Served: FARMINGTON								
93 West Main Street				Clinton	CT	06413		
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6140				800-391-1924	cpatla@ctwater.com			
Contact Role(s): Legal Contact								
Name			Organization			Job Title		
Mr. David Connors			Connecticut Water Company			Director, Service De		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main St						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6141				860-227-4902	dconnors@ctwater.com			
Contact Role(s): Administrative Contact								
Please note the following:								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule