

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
Asbestos (1094)		2 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28		Complete		
Total Haloacetic Acids (2456)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
DOGHOUSE QUIDNET CT (DH-QC)	1/1/19 - 12/31/19	8/1-8/31	Complete		
	1/1/20 - 12/31/20	8/1-8/31	Complete		
	1/1/21 - 12/31/21	8/1-8/31	Complete		
Total Trihalomethanes (2950)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
DOGHOUSE POLPIS LA (DH-PL)	1/1/19 - 12/31/19	8/1-8/31	Complete		
	1/1/20 - 12/31/20	8/1-8/31	Complete		
	1/1/21 - 12/31/21	8/1-8/31	Complete		
Total Coliform (3100)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPaug HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
Lead And Copper (PBCU)		10 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30		
	1/1/22 - 12/31/24	6/1-9/30		
Physical Parameters (PPS)		2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20		Complete	
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			

Water System Facility: **LOWER PUMPHOUSE ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Uranium (4006)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Combined Radium-226/228 (4010)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: LOWER PUMPHOUSE ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Water System Facility: ENTRY POINT - UPPER (WSF ID: 00702)

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **ENTRY POINT - UPPER (WSF ID: 00702)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/23 - 12/31/25		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
Water System Facility: WELL 2 (WSF ID: 724)			
E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **WELL 3 (WSF ID: 725)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **WELL 4 (WSF ID: 726)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **WELL 5 (WSF ID: 727)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **WELL 5 (WSF ID: 727)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **WELL 4B (WSF ID: 728)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4B (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **WELL 6 (WSF ID: 729)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Water System Facility: LOWER PUMPHOUSE ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2013		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		10/1/2019 - 10/31/2019	
		11/1/2019 - 11/30/2019	
		12/1/2019 - 12/31/2019	
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Water System Facility: ENTRY POINT - UPPER (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2013		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		10/1/2019 - 10/31/2019	
		11/1/2019 - 11/30/2019	
		12/1/2019 - 12/31/2019	
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Chlorine M&R Violation	7/1/19 - 9/30/19	3	11/12/2020		11/22/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DH-MT	DOGHOUSE MOHAWK TR	A	Y	1	Y	
		DH-PL	DOGHOUSE POLPIS LA	A	Y	1		Y
		DH-QC	DOGHOUSE QUIDNET CT	A	Y	1	Y	Y
		DH-WT	DOGHOUSE WAIWINET	A	Y	1		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		SP9	BLDG #17 UNIT #13	A	Y			
		UNIT 13	UNIT 13, BLDG 17	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPaug HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			188				

Towns Served: GUILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UNIT 17	UNIT 117, BLDG 21	A	Y	1		
		UNIT 27	UNIT 27, BLDG 8	A	Y	1		
		UNIT 33	UNIT 33, BLDG 35	A	Y	1		
		UNIT 34	UNIT 34, BLDG 36	A	Y	1	Y	
		UNIT 36	UNIT 36, BLDG 24	A	Y	1	Y	
		UNIT 43	UNIT 43 BLDG 28	A	Y	1		
		UNIT 45	UNIT #45 KITCHEN SIN	A	Y			
		UNIT 48	UNIT 48, BLDG 25	A	Y	1	Y	
		UNIT 49	UNIT 49, BLDG 34	A	Y	1		
		UNIT 50	UNIT 50, BLDG 25	A	Y	1	Y	
		UNIT 54	UNIT 54, BLDG 23	A	Y	1	Y	
		UNIT 56	UNIT 56, BLDG 23	A	Y	1	Y	
		UNIT 7	UNIT 7, BLDG 3	A	Y	1	Y	
		UNIT 74	UNIT 74, BLDG 9	A	Y	1		
		UNIT 76	UNIT 76, BLDG 30	A	Y	1		
		UNIT 80	UNIT 80, BLDG 30	A	Y	1		
		UNIT 84	UNIT 84, BLDG 32	A	Y	1	Y	
		UNIT 97	UNIT 97, BLDG 18	A	Y	1		
		UNIT117	BLDG 21, UNIT 117 UP	A	Y			
		UNIT98	UNIT #98 KITCHEN SIN	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	LOWER PUMPHOUSE ENTRY POINT	3	ENTRY POINT	A				
00702	ENTRY POINT - UPPER	3	ENTRY POINT - UPPER	A				
50065	ATMOSPHERIC TANK - LOWER							
50067	PRESSURE TANK - LOWER							
50069	ATMOSPHERIC TANK - UPPER SYSTEM							
50071	PRESSURE TANK - UPPER SYSTEM							
53224	BOOSTER PUMPING FACILITIES - LOWER							
53232	UPPER PUMPHOUSE BOOSTERS							
58371	UPPER PUMPHOUSE TREATMENT PLANT							
58373	LOWER PUMPHOUSE TREATMENT PLANT							
724	WELL 2	2	WELL 2	A				
725	WELL 3	2	WELL 3	A				
726	WELL 4	2	WELL 4	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM	C	564	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		188					

Towns Served: GUILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
727	WELL 5	2	WELL 5	A				
728	WELL 4B	2	WELL 4B	A				
729	WELL 6	2	WELL 6	A				

Certified Operator Information

Water System Facility: **UPPER PUMPHOUSE TREATMENT PLANT (WSF ID: 58371)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2021

Water System Facility: **LOWER PUMPHOUSE TREATMENT PLANT (WSF ID: 58373)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2021

Contact Information

Name		Organization			Job Title	
Mr. William P. Krygier		Empire Property Mgmt. Corp.			Property Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
625 East Main Street				Branford	CT	06405
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-488-9500		203-488-6290		203-488-6245	maintenance@epmc.co	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0606011	QUONNIPAUG HILLS - SECTION I	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/22	6/1-9/30			
	1/1/23 - 12/31/25	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Uranium (4006)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0606011	QUONNIPAUG HILLS - SECTION I	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9				

Towns Served: GUILFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Combined Radium-226/228 (4010)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/19 - 12/31/21			
	1/1/22 - 12/31/24			
Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20		Complete	
	1/1/21 - 12/31/21			
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Organic Chemicals (VOCS)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20		Complete	
	1/1/21 - 12/31/21			

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Physical Parameters M&R Violation	1/1/19 - 3/31/19	3	5/7/2020		5/17/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0606011	QUONNIPAUG HILLS - SECTION I	C	27	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		9					

Towns Served: GUILFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		QH001	UNIT 1 KITCHEN	A	Y	N	Y	Y
		QH002	UNIT 2 KITCHEN	A	Y	N	Y	Y
		QH003	UNIT 3 KITCHEN	A	Y	N	Y	Y
		QH004	UNIT 4 KITCHEN	A	Y	N	Y	Y
		QH005	UNIT 5 KITCHEN	A	Y	N	Y	Y
		QH006	UNIT 6 KITCHEN	A	Y	N	Y	Y
		QH007	UNIT 7 KITCHEN	A	Y	N	Y	Y
		QH008	UNIT 8 KITCHEN	A	Y	N	Y	Y
		QH009	UNIT 9 KITCHEN	A	Y	N	Y	Y
		QH010	PUMP ROOM	A		N	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
52340	PRESSURE STORAGE							
52342	ATMOSPHERIC STORAGE							
730	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022 6/30/2022
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2022 9/30/2021

Contact Information

Name		Organization			Job Title	
Mr. William P. Krygier		Empire Property Mgmt. Corp.			Property Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
625 East Main Street				Branford	CT	06405
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-488-9500		203-488-6290		203-488-6245	maintenance@epmc.co	
Contact Role(s): Administrative Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0606011	QUONNIPAUG HILLS - SECTION I	C	27	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		9						
Towns Served: GUILFORD								
Name			Organization			Job Title		
Mr. Paul Mei			Quonnipaug Hills Corporation			President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
117 Wauwinet Trail						Guilford	CT	06437
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-457-1938				203-488-9500				
Contact Role(s): Legal Contact								
Name			Organization			Job Title		
625 Partners LLC								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
115 Boston Post Rd						Madison	CT	06443
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s): Owner								
Please note the following:								
<ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule. 								

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		40 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Chlorine Residual (1012)		43 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	11/1/19 - 11/30/19		Complete		
Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20				
	1/1/21 - 12/31/29				
Total Coliform (3100)		3 repeat (RP) per period			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	11/20/19 - 11/25/19		Complete		
Total Coliform (3100)		40 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
KELSEYTOWN PUMP STAT (1045)	7/1/19 - 9/30/19	9/1-9/30	Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		15,728	1,580	38	

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/19 - 12/31/19	12/1-12/31	Complete
	1/1/20 - 3/31/20	3/1-3/31	
	4/1/20 - 6/30/20	6/1-6/30	
	7/1/20 - 9/30/20	9/1-9/30	
WESTBROOK FIRE DEPT (1046)	7/1/19 - 9/30/19	9/1-9/30	Complete
	10/1/19 - 12/31/19	12/1-12/31	Complete
	1/1/20 - 3/31/20	3/1-3/31	
	4/1/20 - 6/30/20	6/1-6/30	
	7/1/20 - 9/30/20	9/1-9/30	
CTWC OFFICE, 93WMAIN (1054)	7/1/19 - 9/30/19	9/1-9/30	Complete
	10/1/19 - 12/31/19	12/1-12/31	Complete
	1/1/20 - 3/31/20	3/1-3/31	
	4/1/20 - 6/30/20	6/1-6/30	
	7/1/20 - 9/30/20	9/1-9/30	
SAYBROOK CONVALESCENT (1067)	7/1/19 - 9/30/19	9/1-9/30	Complete
	10/1/19 - 12/31/19	12/1-12/31	Complete
	1/1/20 - 3/31/20	3/1-3/31	
	4/1/20 - 6/30/20	6/1-6/30	
	7/1/20 - 9/30/20	9/1-9/30	
Lead And Copper (PBCU)		30 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		40 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **CLINTON WELL WTP ENTRY POINT (WSF ID: 00701)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	7/1/19 - 9/30/19		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
Water System Facility: FIVE FIELDS WELL WTP ENTRY POINT (WSF ID: 00702)			
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **FIVE FIELDS WELL WTP ENTRY POINT (WSF ID: 00702)**

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Water System Facility: GUILFORD WELL WTP ENTRY POINT (WSF ID: 00703)			
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **GUILFORD WELL WTP ENTRY POINT (WSF ID: 00703)**

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: **MACKENZIE WTP ENTRY POINT (WSF ID: 00704)**

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **MACKENZIE WTP ENTRY POINT (WSF ID: 00704)**

Inorganic Chemicals (IOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Nitrate And Nitrite (NOX) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-MACKENZIE WTP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: **PINEWOOD WELL WTP ENTRY POINT (WSF ID: 00705)**

Net Gross Alpha (4000) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINEWOOD WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Uranium (4006) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINEWOOD WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-PINEWOOD WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
------------------------------------	-------------------	-------------------	-------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **PINEWOOD WELL WTP ENTRY POINT (WSF ID: 00705)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINEWOOD WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: **SAYBROOK WELL WTP ENTRY POINT (WSF ID: 00707)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **SAYBROOK WELL WTP ENTRY POINT (WSF ID: 00707)**

Man-Made Beta Particle & Photon Emitters (4101) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Tritium (4102) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Strontium-90 (4174) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: **WEISS WELL WTP ENTRY POINT (WSF ID: 00708)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: WEISS WELL WTP ENTRY POINT (WSF ID: 00708)

Uranium (4006)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)			2 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Water System Facility: HOLBROOK WELL WTP ENTRY POINT (WSF ID: 00710)			
Net Gross Alpha (4000)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **HOLBROOK WELL WTP ENTRY POINT (WSF ID: 00710)**

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Out of Service
	1/1/20 - 3/31/20		
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
Water System Facility: MACKENZIE WATER TREATMENT PLANT (WSF ID: 103)			
Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - MACKENZIE TP (5)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **MACKENZIE WATER TREATMENT PLANT (WSF ID: 103)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **CLINTON WELL (WSF ID: 1238)**

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CLINTON WELL (2)	11/19/19 - 11/25/19		Complete

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CLINTON WELL (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **WEISS WELL (WSF ID: 1242)**

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WEISS WELL (2)	11/19/19 - 11/25/19		Complete

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WEISS WELL (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **GUILFORD WELL (WSF ID: 1406)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GUILFORD WELL (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **GUILFORD WELL (WSF ID: 1406)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **HOLBROOK WELL (WSF ID: 1411)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOLBROOK WELL (2)	10/1/19 - 10/31/19		Out of Service
	11/1/19 - 11/30/19		Out of Service
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **SAYBROOK WELL 1 (WSF ID: 1412)**

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SAYBROOK WELL 1 (2)	11/19/19 - 11/25/19		Complete

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SAYBROOK WELL 1 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Total Alkalinity (1927)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
2,4-D (2105)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
KELSEYTOWN RES (1)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20		Complete		
	1/1/21 - 12/31/21				
Total Organic Carbon (2920)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
KELSEYTOWN RES (1)	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
KELSEYTOWN RES (1)	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Monitoring Requirements

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Surface Water Inorganic Chemicals (RIOCI) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
KELSEYTOWN RES (1)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Surface Water Color and Turbidity (RPPS) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
KELSEYTOWN RES (1)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Surface Water Pesticides (RSOC) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
KELSEYTOWN RES (1)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **MACKENZIE WATER TREATMENT PLANT (WSFID: 103)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 10/1/2003		Compliance History:	
		Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	Y
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2004		Compliance History:	
		Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		
Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK							
Water System Facility: MACKENZIE WATER TREATMENT PLANT (WSFID: 103)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH			Daily		
Start Date: 1/1/2004		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L			2		
Start Date: 10/1/2012		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU			186		
Start Date: 10/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020		Y			
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU			186		
Start Date: 10/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020		Y			
		2/1/2020 - 2/29/2020					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: SAYBROOK WELL TREATMENT PLANT (WSFID: 104)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		
Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK							
Water System Facility: CLINTON WELL TREATMENT PLANT (WSFID: 106)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 1/1/2004		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L			Daily		
Start Date: 1/1/2004		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH			Daily		
Start Date: 1/1/2004		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L			2		
Start Date: 10/1/2012		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **WEISS WELL TREATMENT PLANT (WSFID: 108)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2012			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **FIVE FIELDS WELL TREATMENT PLANT (WSFID: 109)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
Offline	12/1/2019 - 12/31/2019	n/a	Y
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
Offline	12/1/2019 - 12/31/2019	n/a	Y
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Water System Facility: **GUILFORD WELL TREATMENT PLANT (WSFID: 110)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **GUILFORD WELL TREATMENT PLANT (WSFID: 110)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2012		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Water System Facility: **PINEWOOD WELL TREATMENT PLANT (WSFID: 111)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 1/1/2004		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		10/1/2019 - 10/31/2019	Y
		11/1/2019 - 11/30/2019	Y
		12/1/2019 - 12/31/2019	Y
		1/1/2020 - 1/31/2020	
		2/1/2020 - 2/29/2020	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: HOLBROOK WELL TREATMENT PLANT (WSFID: 50317)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 6/1/2005		Compliance History:	Monitoring Compliance Status:	
		Monitoring Period	Compliance Status:	
	Offline	10/1/2019 - 10/31/2019	n/a	Y
	Offline	11/1/2019 - 11/30/2019	n/a	Y
	Offline	12/1/2019 - 12/31/2019	n/a	Y
		1/1/2020 - 1/31/2020		
		2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily	
Start Date: 5/1/2013		Compliance History:	Monitoring Compliance Status:	
		Monitoring Period	Compliance Status:	
	Offline	10/1/2019 - 10/31/2019	n/a	Y
	Offline	11/1/2019 - 11/30/2019	n/a	Y
	Offline	12/1/2019 - 12/31/2019	n/a	Y
		1/1/2020 - 1/31/2020		
		2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily	
Start Date: 6/1/2005		Compliance History:	Monitoring Compliance Status:	
		Monitoring Period	Compliance Status:	
	Offline	10/1/2019 - 10/31/2019	n/a	Y
	Offline	11/1/2019 - 11/30/2019	n/a	Y
	Offline	12/1/2019 - 12/31/2019	n/a	Y
		1/1/2020 - 1/31/2020		
		2/1/2020 - 2/29/2020		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
RESPOND TO SANITARY SURVEY	2/7/2020	2/6/2020
WATERSHED SURVEY REPORT	3/1/2020	2/27/2020
CROSS CONNECTION SURVEY REPORT	3/1/2020	
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/7/2020	
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/7/2020	2/6/2020
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/7/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2021	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	1045	KELSEYTOWN PUMP STAT	A	Y			Y
		1046	WESTBROOK FIRE DEPT	A	Y			Y
		1050	GUILFORD HESS 1162 B	I	Y			
		1050A	GUILFORD MOBIL 1164	A	Y			
		1051	GFD TIRE, 655 BPR	A	Y			
		1052	HAMMO FORD, 191 BPR	A	Y			
		1053	HENNY PENNY 646 BPR M	A	Y			
		1054	CTWC OFFICE, 93WMAIN	A	Y			Y
		1055	GLNWD MKT, 153 GLWD	A	Y			
		1056	DUNKN DNTS, 215 BPR	A	Y			
		1057	WBK MOBIL, 779 BPR	A	Y			
		1058	LAGASSE SV, 2051 BPR	A	Y			Y
		1059	SAYBRK BSTR 1651 BPR	A	Y			
		1060	HENNY PENNY 1090 BPR	A	Y			
		1061	CHUCKY STR 685 BPR	A	Y			
		1062	SAYBRK FORD 1 FRD DR	A	Y			
		1063	TOMS SERV	A	Y			
		1064	GRSMN CHV 300 MSX TP	A	Y			
		1065	SACHEM HD TANK	A	Y			
		1066	CLR/PWD RED PIT	A	Y			
		1067	SAYBROOK CONVALESCEN	A	Y			Y
		1069	DISTRIBUTION SYSTEM	A	Y			
		10801	36 WLDWD DR MAD	A			1	
		10802	15 HIGH ST CLN	I				
		10803	125 KELSEYTOWN RD CL	A			2	
		10804	138 N COVE RD OS	A			3	
		10805	110 N COVE RD OS	A			3	
		10806	33 FAIR ST GFD	A			1	
		10807	413 SPNCR PL RD WBK	A			1	
		10808	35 COMMERCE DR CLN	I				
		10809	14 BRKSD LN MAD	A			3	
		10810	34 HFD AVE OS	A			3	
		10811	15 PEARL ST GFD	A			1	
		10812	19 FAIR ST GFD	A			3	
		10813	35 SHERWOOD TER OS	A			1	
		10814	95 FAIR ST GFD	A			1	
		10815	412 SCHOOLSIDE GFD	A			1	
		10816	8 PROSPECT ST MAD	A			3	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10817	25 ELMWOOD ST OSD	A		3		
		10818	23 ARGAIL DR WBK	A		1		
		10819	29 MENNKTSK AVE OS	I				
		10820	164 LIL STNRD BCH WB	A		3		
		10821	857 BPR WBK	A		3		
		10822	28 WILLARD AV OS	A		1		
		10823	26 BASSETT LN MD	A		3		
		10824	33 HIGH ST CLN	A		1		
		10825	43 NECK RD MAD	A		3		
		10826	431 SPNCR PL RD WBK	A		1		
		10827	29 IRON WORKS RD CL	A		1		
		10828	32 STATE ST GFD	A		1		
		10829	49 CHURCH ST GFD	A		3		
		10830	82 HIGHWOODS RD GFD	A		3		
		10831	5 SANDCREEK DR, OS	A	Y	1		
		10832	29 Sherwood Terr, Sb	A	Y			
		10833	138 N Cove Rd, Sbk	A	Y			
		10834	4 AIRLINE RD CLN	A	Y	1		
		10835	12 AIRLINE RD CLN	A	Y	1		
		10836	16 AIRLINE RD CLN	A	Y	1		
		10837	19 BARGATE RD CLN	A	Y	1		
		10838	16 BEACH PARK RD CLN	A	Y	1		
		10839	34 BRICKYARD RD CLN	A	Y	1		
		10840	36 BRICKYARD RD CLN	A	Y	1		
		10841	38 BRICKYARD RD CLN	A	Y	1		
		10842	44 BRICKYARD RD CLN	A	Y	1		
		10843	48 BRICKYARD RD CLN	A	Y	1		
		10844	20 CARRIAGE DR CLN	A	Y	1		
		10845	22 CARRIAGE DR CLN	A	Y	1		
		10846	24 CARRIAGE DR CLN	A	Y	1		
		10847	27 CARRIAGE DR CLN	A	Y	1		
		10848	28 CARRIAGE DR CLN	A	Y	1		
		10849	29 CARRIAGE DR CLN	A	Y	1		
		10850	30 CARRIAGE DR CLN	A	Y	1		
		10851	31 CARRIAGE DR CLN	A	Y	1		
		10852	32 CARRIAGE DR CLN	A	Y	1		
		10853	33 CARRIAGE DR CLN	A	Y	1		
		10854	38 CARRIAGE DR CLN	A	Y	1		
		10855	39 CARRIAGE DR CLN	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10856	40 CARRIAGE DR CLN	A	Y	1		
		10857	42 CARRIAGE DR CLN	A	Y	1		
		10858	27 E SHORE DR CLN	A	Y	1		
		10859	66 E SHORE DR CLN	A	Y	1		
		10860	20 FAIRY DELL RD CLN	A	Y	1		
		10861	22 FAIRY DELL RD CLN	A	Y	1		
		10863	36 FAIRY DELL RD CLN	A	Y	1		
		10864	79 FAIRY DELL RD CLN	A	Y	1		
		10865	80 FAIRY DELL RD CLN	A	Y	1		
		10866	82 FAIRY DELL RD CLN	A	Y	1		
		10867	84 FAIRY DELL RD CLN	A	Y	1		
		10868	57 BPR GFD	A	Y	1		
		10869	2751 BPR GFD	A	Y	1		
		10870	279 BOSTON ST GFD	A	Y	1		
		10871	311 BOSTON ST GFD	A	Y	1		
		10872	313 BOSTON ST GFD	A	Y	1		
		10873	315 BOSTON ST GFD	A	Y	1		
		10874	317 BOSTON ST GFD	A	Y	1		
		10875	31 CHRST PHR LN GFD	A	Y	1		
		10876	46 CHRST PHR LN GFD	A	Y	1		
		10877	53 CHRST PHR LN GFD	A	Y	1		
		10878	67 CHRST PHR LN GFD	A	Y	1		
		10879	47 COACH LAMP LN GFD	A	Y	1		
		10880	454 COLONIAL RD GFD	A	Y	1		
		10881	6 CORNWALL LN GFD	A	Y	1		
		10882	11 CORNWALL LN GFD	A	Y	1		
		10883	20 CORNWALL LN GFD	A	Y	1		
		10884	23 CORNWALL LN GFD	A	Y	1		
		10885	39 CORNWALL LN GFD	A	Y	1		
		10886	41 CORNWALL LN GFD	A	Y	1		
		10887	42 CORNWALL LN GFD	A	Y	1		
		10888	47 CORNWALL LN GFD	A	Y	1		
		10889	51 CORNWALL LN GFD	A	Y	1		
		10890	58 CORNWALL LN GFD	A	Y	1		
		10891	63 CORNWALL LN GFD	A	Y	1		
		10892	70 CORNWALL LN GFD	A	Y	1		
		10893	75 CORNWALL LN GFD	A	Y	1		
		10894	81 CORNWALL LN GFD	A	Y	1		
		10895	92 CORNWALL LN GFD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10896	94 CORNWALL LN GFD	A	Y	1		
		10897	96 CORNWALL LN GFD	A	Y	1		
		10898	99 CORNWALL LN GFD	A	Y	1		
		10899	75 COVENTRY WAY GFD	A	Y	1		
		10900	80 COVENTRY WAY GFD	A	Y	1		
		10901	96 COVENTRY WAY GFD	A	Y	1		
		10902	101 COVENTRY WAY GFD	A	Y	1		
		10903	118 COVENTRY WAY GFD	A	Y	1		
		10904	123 COVENTRY WAY GFD	A	Y	1		
		10905	21 CRABAPLE LN GFD	A	Y	1		
		10906	28 CRABAPLE LN GFD	A	Y	1		
		10907	46 CRABAPLE LN GFD	A	Y	1		
		10908	55 CRABAPLE LN GFD	A	Y	1		
		10909	144 DRIFTWOOD LN GFD	A	Y	1		
		10910	190 DRIFTWOOD LN GFD	A	Y	1		
		10911	218 DRIFTWOOD LN GFD	A	Y	1		
		10912	221 DRIFTWOOD LN GFD	A	Y	1		
		10913	232 DRIFTWOOD LN GFD	A	Y	1		
		10914	240 DRIFTWOOD LN GFD	A	Y	1		
		10915	77 FAIR ST GFD	A	Y	1		
		10916	40 HPMEADOE CIR GFD	A	Y	1		
		10917	17 LNG HLL FRM GFD	A	Y	1		
		10918	22 LNG HLL FRM GFD	A	Y	1		
		10919	23 LNG HLL FRM GFD	A	Y	1		
		10920	25 LNG HLL FRM GFD	A	Y	1		
		10921	26 LNG HLL FRM GFD	A	Y	1		
		10922	27 LNG HLL FRM GFD	A	Y	1		
		10923	28 LNG HLL FRM GFD	A	Y	1		
		10924	29 LNG HLL FRM GFD	A	Y	1		
		10925	30 LNG HLL FRM GFD	A	Y	1		
		10926	31 LNG HLL FRM GFD	A	Y	1		
		10927	32 LNG HLL FRM GFD	A	Y	1		
		10928	33 LNG HLL FRM GFD	A	Y	1		
		10929	34 LNG HLL FRM GFD	A	Y	1		
		10930	35 LNG HLL FRM GFD	A	Y	1		
		10931	38 LNG HLL FRM GFD	A	Y	1		
		10932	40 LNG HLL FRM GFD	A	Y	1		
		10933	41 LNG HLL FRM GFD	A	Y	1		
		10934	42 LNG HLL FRM GFD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10935	35 LNG HLL FRM GFD	A	Y	1		
		10936	44 LNG HLL FRM GFD	A	Y	1		
		10937	45 LNG HLL FRM GFD	A	Y	1		
		10938	46 LNG HLL FRM GFD	A	Y	1		
		10939	47 LNG HLL FRM GFD	A	Y	1		
		10940	48 LNG HLL FRM GFD	A	Y	1		
		10941	49 LNG HLL FRM GFD	A	Y	1		
		10942	54 LNG HLL FRM GFD	A	Y	1		
		10943	1470 LNG HLL FRM GFD	A	Y	1		
		10944	116 MICHAEL DR GFD	A	Y	1		
		10945	118 MICHAEL DR GFD	A	Y	1		
		10946	125 MICHAEL DR GFD	A	Y	1		
		10947	11 MICHELLE LN GFD	A	Y	1		
		10948	20 MICHELLE LN GFD	A	Y	1		
		10949	28 MICHELLE LN GFD	A	Y	1		
		1095	4 APOGEE LANE WBK	A	Y			
		10950	33 MICHELLE LN GFD	A	Y	1		
		10951	47 MICHELLE LN GFD	A	Y	1		
		10952	52 MICHELLE LN GFD	A	Y	1		
		10953	59 MICHELLE LN GFD	A	Y	1		
		10954	71 MICHELLE LN GFD	A	Y	1		
		10955	100 MIRROR LN GFD	A	Y	1		
		10956	149 MIRROR LN GFD	A	Y	1		
		10957	21 MUSTANG DR GFD	A	Y	1		
		10958	30 MUSTANG DR GFD	A	Y	1		
		10959	42 MUSTANG DR GFD	A	Y	1		
		10960	47 MUSTANG DR GFD	A	Y	1		
		10961	59 MUSTANG DR GFD	A	Y	1		
		10962	64 MUSTANG DR GFD	A	Y	1		
		10963	67 MUSTANG DR GFD	A	Y	1		
		10964	75 MUSTANG DR GFD	A	Y	1		
		10965	53 ACORN RD MAD	A	Y	1		
		10966	60 ACORN RD MAD	A	Y	1		
		10967	62 ACORN RD MAD	A	Y	1		
		10968	66 ACORN RD MAD	A	Y	1		
		10969	67 ACORN RD MAD	A	Y	1		
		10970	72 ACORN RD MAD	A	Y	1		
		10971	73 ACORN RD MAD	A	Y	1		
		10972	78 ACORN RD MAD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10973	79 ACORN RD MAD	A	Y	1		
		10974	88 ACORN RD MAD	A	Y	1		
		10975	95 ACORN RD MAD	A		1		
		10976	100 ACORN RD MAD	A	Y	1		
		10977	101 ACORN RD MAD	A	Y	1		
		10978	103 ACORN RD MAD	A	Y	1		
		10979	104 ACORN RD MAD	A	Y	1		
		10980	105 ACORN RD MAD	A	Y	1		
		10981	110 ACORN RD MAD	A	Y	1		
		10982	111 ACORN RD MAD	A	Y	1		
		10983	116 ACORN RD MAD	A	Y	1		
		10984	117 ACORN RD MAD	A	Y	1		
		10985	123 ACORN RD MAD	A	Y	1		
		10986	129 ACORN RD MAD	A	Y	1		
		10987	24 BEACH RD E OS	A	Y	1		
		10988	16 HOMESTEAD ST OS	A	Y	1		
		10989	40 INGHAM HILL RD	A	Y	1		
		10990	44 INGHAM HILL RD OS	A	Y	1		
		10991	66 INGHAM HILL RD OS	A	Y	1		
		10992	45 KNOLLWOOD DR OS	A	Y	1		
		10993	1 N COVE CIR OS	A	Y	1		
		10994	2 N COVE CIR OS	A	Y	1		
		10995	94 N COVE RD OS	A	Y	1		
		10996	132 N COVE RD OS	A	Y	1		
		10997	75 OLD POST RD OS	A	Y	1		
		10998	100 OLD POST RD OS	A	Y	1		
		10999	11 OSPREY RD OS	A	Y	1		
		11000	15 OSPREY RD OS	A	Y	1		
		11001	1 SAND CREEK DR OS	A	Y	1		
		11002	2 SAND CREEK DR OS	A	Y	1		
		11003	3 SAND CREEK DR OS	A	Y	1		
		11004	4 SAND CREEK DR OS	A	Y	1		
		11005	6 SAND CREEK DR OS	A	Y	1		
		11006	4 SCHENKER AVE OS	A	Y	1		
		11007	28 SRS AV A FL PK OS	A	Y	1		
		11008	6 THOMPSON RD OS	A	Y	1		
		11009	8 THOMPSON RD OS	A	Y	1		
		11010	9 THOMPSON RD OS	A	Y	1		
		11011	10 THOMPSON RD OS	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11012	2 THMPSN RD LEFT OS	A	Y	1		
		11013	2 TRAILS END OS	A	Y	1		
		11014	3 TRAILS END OS	A	Y	1		
		11015	5 TRAILS END OS	A	Y	1		
		11016	6 VINCENT AVE OS	A	Y	1		
		11017	12 VINCENT AVE OS	A	Y	1		
		11018	9 WARD PL OS	A		1		
		11019	2 WHITNEY AVE OS	A	Y	1		
		11020	24 WHITNEY AVE OS	A	Y	1		
		11021	8 WINDSOR CT W OS	A	Y	1		
		11022	14 CHPMN BCH RD WBK	A	Y	1		
		11023	28 CHPMN BCH RD WBK	A	Y	1		
		11024	32 ECKFORD AVE WBK	A	Y	1		
		11025	4 ELM AVE WBK	A	Y	1		
		11026	73 HNTRS RDG RD WBK	A	Y	1		
		11027	89 HNTRS RDG RD WBK	A	Y	1		
		11028	94 HNTRS RDG RD WBK	A	Y	1		
		11029	97 HNTRS RDG RD WBK	A	Y	1		
		11030	16 PND MDW RD WBK	A	Y	1		
		11031	273 SPNC PLNS RD WBK	A	Y	1		
		11032	8 FRY DLL RD A CLN	A	Y	2		
		11033	10 FRY DLL RD A CLN	A	Y	2		
		11034	14 FRY DLL RD A CLN	A	Y	2		
		11035	16 FRY DLL RD A CLN	A	Y	2		
		11036	18 FRY DLL RD A CLN	A	Y	2		
		11037	8 FRY DLL RD B CLN	A	Y	2		
		11038	10 FRY DLL RD B CLN	A	Y	2		
		11039	14 FRY DLL RD B CLN	A	Y	2		
		11040	16 FRY DLL RD B CLN	A	Y	2		
		11041	18 FRY DLL RD B CLN	A	Y	2		
		11042	1 BRANTWOOD DR MAD	A		2		
		11043	2 BRANTWOOD DR MAD	A	Y	2		
		11044	3 BRANTWOOD DR MAD	A	Y	2		
		11045	4 BRANTWOOD DR MAD	A		2		
		11046	5 BRANTWOOD DR MAD	A	Y	2		
		11047	6 BRANTWOOD DR MAD	A	Y	2		
		11048	7 BRANTWOOD DR MAD	A	Y	2		
		11049	8 BRANTWOOD DR MAD	A	Y	2		
		11050	9 BRANTWOOD DR MAD	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		15,728	1,580	38	

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
11051		10	BRANTWOOD DR MAD	A	Y	2		
11052		11	BRANTWOOD DR MAD	A	Y	2		
11053		12	BRANTWOOD DR MAD	A	Y	2		
11054		13	BRANTWOOD DR MAD	A	Y	2		
11055		14	BRANTWOOD DR MAD	A	Y	2		
11056		15	BRANTWOOD DR MAD	A	Y	2		
11057		16	BRANTWOOD DR MAD	A	Y	2		
11058		17	BRANTWOOD DR MAD	A	Y	2		
11059		18	BRANTWOOD DR MAD	A	Y	2		
11060		19	BRANTWOOD DR MAD	A	Y	2		
11061		20	BRANTWOOD DR MAD	A	Y	2		
11062		21	BRANTWOOD DR MAD	A	Y	2		
11063		22	BRANTWOOD DR MAD	A	Y	2		
11064		23	BRANTWOOD DR MAD	A	Y	2		
11065		24	BRANTWOOD DR MAD	A	Y	2		
11066		25	BRANTWOOD DR MAD	A	Y	2		
11067		26	BRANTWOOD DR MAD	A	Y	2		
11068		27	BRANTWOOD DR MAD	A	Y	2		
11069		28	BRANTWOOD DR MAD	A	Y	2		
11070		29	BRANTWOOD DR MAD	A	Y	2		
11071		30	BRANTWOOD DR MAD	A	Y	2		
11072		31	BRANTWOOD DR MAD	A	Y	2		
11073		32	BRANTWOOD DR MAD	A	Y	2		
11074		33	BRANTWOOD DR MAD	A	Y	2		
11075		34	BRANTWOOD DR MAD	A	Y	2		
11076		35	BRANTWOOD DR MAD	A	Y	2		
11077		36	BRANTWOOD DR MAD	A		2		
11078		37	BRANTWOOD DR MAD	A	Y	2		
11079		38	BRANTWOOD DR MAD	A	Y	2		
11080		39	BRANTWOOD DR MAD	A	Y	2		
11081		40	BRANTWOOD DR MAD	A	Y	2		
11082		41	BRANTWOOD DR MAD	A	Y	2		
11083		42	BRANTWOOD DR MAD	A	Y	2		
11084		43	BRANTWOOD DR MAD	A	Y	2		
11085		44	BRANTWOOD DR MAD	A	Y	2		
11086		45	BRANTWOOD DR MAD	A	Y	2		
11087		46	BRANTWOOD DR MAD	A	Y	2		
11088		47	BRANTWOOD DR MAD	A	Y	2		
11089		48	BRANTWOOD DR MAD	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11090	49 BRANTWOOD DR MAD	A	Y	2		
		11091	50 BRANTWOOD DR MAD	A	Y	2		
		11092	51 BRANTWOOD DR MAD	A	Y	2		
		11093	52 BRANTWOOD DR MAD	A	Y	2		
		11094	1 ESTERLY FARMS MAD	A	Y	2		
		11095	2 ESTERLY FARMS MAD	A	Y	2		
		11096	3 ESTERLY FARMS MAD	A	Y	2		
		11097	25 SUNSET RD 10C OS	A	Y	2		
		11098	25 SUNSET RD 11C OS	A	Y	2		
		11099	25 SUNSET RD 12C OS	A	Y	2		
		11100	25 SUNSET RD 13C OS	A	Y	2		
		11101	25 SUNSET RD 14C OS	A	Y	2		
		11102	25 SUNSET RD 16D OS	A	Y	2		
		11103	25 SUNSET RD 17D OS	A	Y	2		
		11104	25 SUNSET RD 18D OS	A	Y	2		
		11105	25 SUNSET RD 19D OS	A	Y	2		
		11106	25 SUNSET RD 1A OS	A	Y	2		
		11107	25 SUNSET RD 20D OS	A	Y	2		
		11108	25 SUNSET RD 2A OS	A	Y	2		
		11109	25 SUNSET RD 3A OS	A	Y	2		
		11110	25 SUNSET RD 4A OS	A	Y	2		
		11111	25 SUNSET RD 5A OS	A	Y	2		
		11112	25 SUNSET RD 6B OS	A	Y	2		
		11113	25 SUNSET RD 7B OS	A	Y	2		
		11114	25 SUNSET RD 8B OS	A	Y	2		
		11115	25 SUNSET RD 9B OS	A	Y	2		
		11116	47 BROADWAY S 1 WBK	A	Y	2		
		11117	45 BROADWAY S 2 WBK	A	Y	2		
		11118	47 BROADWAY S 2 WBK	A	Y	2		
		11119	45 BROADWAY S RT WBK	A	Y	2		
		11120	OBED SAMPLE STATION	A	Y			
		11121	FORD SAMPLE STATION	A	Y			
		11122	OBPR SAMPLE STATION	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	CLINTON WELL WTP ENTRY POINT	3	EP-CLINTON WELL TP	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00702	FIVE FIELDS WELL WTP ENTRY POINT	3	EP-FIVE FIELDS WELL	A				
00703	GUILFORD WELL WTP ENTRY POINT	3	EP-GUILFORD WELL TP	A				
00704	MACKENZIE WTP ENTRY POINT	3	EP-MACKENZIE WTP	A				
00705	PINEWOOD WELL WTP ENTRY POINT	3	EP-PINEWOOD WELL TP	A				
00707	SAYBROOK WELL WTP ENTRY POINT	3	EP-SAYBROOK WELL TP	A				
00708	WEISS WELL WTP ENTRY POINT	3	EP-WEISS WELL TP	A				
00710	HOLBROOK WELL WTP ENTRY POINT	3	EP - HOLBROOK WELL W	A				
103	MACKENZIE WATER TREATMENT PLANT	3	EP - MACKENZIE WTP	A				
		5	CFE - MACKENZIE TP	A				
104	SAYBROOK WELL TREATMENT PLANT	3	EP SAYBROOK WELL TP	A				
106	CLINTON WELL TREATMENT PLANT	3	EP - CLINTON WELL TP	A				
108	WEISS WELL TREATMENT PLANT	3	EP WEISS WELL TP	A				
109	FIVE FIELDS WELL TREATMENT PLANT	3	EP - FIVE FIELDS TP	A				
110	GUILFORD WELL TREATMENT PLANT	3	EP -GUILFORD WELL TP	A				
111	PINEWOOD WELL TREATMENT PLANT	3	EP-PINEWOOD WELL TP	A				
1238	CLINTON WELL	2	CLINTON WELL	A				
1242	WEISS WELL	2	WEISS WELL	A				
1406	GUILFORD WELL	2	GUILFORD WELL	A				
1409	PINEWOOD WELL 2	2	PINEWOOD WELL 2	A				
1411	HOLBROOK WELL	2	HOLBROOK WELL	A				
1412	SAYBROOK WELL 1	2	SAYBROOK WELL 1	A				
1963	FIVE FIELDS WELL 2A	2	FIVE FIELD WELL NEW	A				
2081	KILLINGWORTH RESERVOIR	1	RESERVOIR	A				
2082	KELSEYTOWN RESERVOIR	1	KELSEYTOWN RES	A				
30036	KELSYTOWN RESERVOIR							
49761	INTERCONNECTION - CT0930011 - RWA							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Rule Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
50317	HOLBROOK WELL TREATMENT PLANT						
50321	LONG HILL PUMP STATION						
50323	SAYBROOK PUMP STATION						
50325	BISHOP (LONG HILL) STORAGE TANK						
50329	OBED HEIGHTS TANK						
50331	SACHEMS HEAD TANK						
52049	MACKENZIE CLEARWELL 1						
52051	MACKENZIE CLEARWELL 2						
52057	KELSEYTOWN PUMP STATION						
52059	MACKENZIE PUMP STATION						
57299	PEQUOT TANK						
61727	RIDGE ROAD TANK						
61731	INTERCONNECTION CT0261031 TO CT0680011						

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<i>Facility Classification:</i> CLASS 2 DISTRIBUTION SYSTEM				<i>Certification Expiration</i>
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>		
JARISH, KEVIN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2021	
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022	
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022	
MIEZEJESKI, WALTER B.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021	
HAUSMAN, BRENT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021	

Water System Facility: MACKENZIE WATER TREATMENT PLANT (WSF ID: 103)

<i>Facility Classification:</i> CLASS 4 TREATMENT PLANT				<i>Certification Expiration</i>
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>		
SCHAFFER, KRISTEN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2021	
ANDREWS, PAUL M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2021	
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020	
GOTTSCHALL, KIMBERLY A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2021	
CIMINO, ANTHONY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2021	

Water System Facility: SAYBROOK WELL TREATMENT PLANT (WSF ID: 104)

<i>Facility Classification:</i> CLASS 1 TREATMENT PLANT				<i>Certification Expiration</i>
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>		
FUNK, CHRISTOPHER B.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Certified Operator Information

Water System Facility: SAYBROOK WELL TREATMENT PLANT (WSF ID: 104)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022

Water System Facility: CLINTON WELL TREATMENT PLANT (WSF ID: 106)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FUNK, CHRISTOPHER B.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022

Water System Facility: WEISS WELL TREATMENT PLANT (WSF ID: 108)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FUNK, CHRISTOPHER B.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022

Water System Facility: FIVE FIELDS WELL TREATMENT PLANT (WSF ID: 109)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FUNK, CHRISTOPHER B.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022

Water System Facility: GUILFORD WELL TREATMENT PLANT (WSF ID: 110)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020
FUNK, CHRISTOPHER B.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022

Water System Facility: PINWOOD WELL TREATMENT PLANT (WSF ID: 111)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FUNK, CHRISTOPHER B.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022

Water System Facility: HOLBROOK WELL TREATMENT PLANT (WSF ID: 50317)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FUNK, CHRISTOPHER B.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM	C	33,197	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,728	1,580	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Contact Information

Name			Organization			Job Title			
Mr. Craig J. Patla			Connecticut Water Company			Vp, Service Delivery			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main Street						Clinton		CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-664-6140				800-391-1924	cpatla@ctwater.com				

Contact Role(s): **Legal Contact**

Name			Organization			Job Title			
Mr. David Connors			Connecticut Water Company			Director, Service De			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main St						Clinton		CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-664-6141				860-227-4902	dconnors@ctwater.com				

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule