

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730021	JEWETT CITY WATER CO-HILL-N-DALE	C	146	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20			
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
Asbestos (1094)		1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20			
	1/1/21 - 12/31/29			
Total Coliform (3100)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20			
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
3 STRNAD ROAD (JCWC002)	1/1/19 - 12/31/19	7/1-7/31	Complete	
	1/1/20 - 12/31/20	7/1-7/31		
	1/1/21 - 12/31/21	7/1-7/31		
Lead And Copper (PBCU)		5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730021	JEWETT CITY WATER CO-HILL-N-DALE	C	146	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730021	JEWETT CITY WATER CO-HILL-N-DALE	C	146	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		

Water System Facility: WELL #2 (WSF ID: 515)

E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: WELL #1 (WSF ID: 516)

E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730021	JEWETT CITY WATER CO-HILL-N-DALE	C	146	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **WELL #1 (WSF ID: 516)**

E. Coli (3014)	1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
	<i>Collection Period</i>
	<i>Compliance Status</i>
	7/1/20 - 7/31/20
	8/1/20 - 8/31/20
	9/1/20 - 9/30/20

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019		
	11/1/2019 - 11/30/2019		
	12/1/2019 - 12/31/2019		
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019		
	11/1/2019 - 11/30/2019		
	12/1/2019 - 12/31/2019		
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	3	H-N-D	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
		JCW001	33 STRNAD RD.	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730021	JEWETT CITY WATER CO-HILL-N-DALE	C	146	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LISBON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		JCWC001	33 STRNAD ROAD	A	Y			
		JCWC002	3 STRNAD ROAD	A				Y
		JCWC003	23 KENYON ROAD	A		1		
		JCWC004	3 KENYON ROAD	A		1		
		JCWC005	13 KENYON ROAD	A		1		
		JCWC006	10 KENYON ROAD	A		3		
		JCWC007	20 KENYON ROAD	A		3		
		JCWC008	10 STRNAD ROAD	A		3		
		JCWC009	11 STRNAD ROAD	A		3		
		JCWC010	14 STRNAD ROAD	A		3		
		JCWC011	15 STRNAD ROAD	A		3		
		JCWC012	18 STRNAD ROAD	A		3		
		JCWC013	20 STRNAD ROAD	A		3		
		JCWC014	21 STRNAD ROAD	A		3		
		JCWC015	25 STRNAD ROAD	A		3		
		JCWC016	30 STRNAD ROAD	A		3		
		JCWC017	32 STRNAD ROAD	A		3		
		JCWC018	9 STRNAD ROAD	A			Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
132	HILL-N-DALE TREATMENT STATION							
51177	ATMOSPHERIC TANK							
51179	HYDROPNEUMATIC TANK							
515	WELL #2	2	WELL #2	A				
516	WELL #1	2	WELL #1	A				

Certified Operator Information

Water System Facility: HILL-N-DALE TREATMENT STATION (WSF ID: 132)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
VIOLETTE, JOHN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2020
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2020
ROUSSEY, ALFRED E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022
SHERWOOD, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2020
LEARNED, JAMES W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
ENGLE, ROGER D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730021	JEWETT CITY WATER CO-HILL-N-DALE	C	146	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		24					

Towns Served: LISBON

Certified Operator Information

Water System Facility: **HILL-N-DALE TREATMENT STATION (WSF ID: 132)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020
FILLION, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2021 3/31/2022
LEVASSEUR, NICHOLAS P.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2020 9/30/2021

Contact Information

Name		Organization			Job Title		
Mr. Jonathan S. Avery		The Hazardville Water Company			President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
281 Hazard Avenue					Enfield	CT	06082
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-749-0779		860-749-5381		860-376-2963	javery@hazardvillewater.com		

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title		
Mr. Robert Sherwood		Hazardville Water Company					
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
281 Hazard Avenue					Enfield	CT	06082
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-749-0779		860-749-5381		860-460-0632	bsherwood@hazardvillewater.com		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730031	LISBON MOBILE HOMES	C	155	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			63				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30			
	1/1/22 - 12/31/24	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730031	LISBON MOBILE HOMES	C	155	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			63				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Water System Facility: WELL #1 (WSF ID: 521)			
E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730031	LISBON MOBILE HOMES	C	155	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			63				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **WELL #1 (WSF ID: 521)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	4
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019		
	11/1/2019 - 11/30/2019		
	12/1/2019 - 12/31/2019		
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	
CROSS CONNECTION EXEMPTION	3/1/2024	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
E. Coli M&R Violation	7/1/19 - 7/31/19	3	12/25/2020		1/4/2021	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LT1	LOT 1	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0730031	LISBON MOBILE HOMES	C	155	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		63					

Towns Served: LISBON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LT1/2	LOT 1/2	A	Y	N		
		LT2	LOT2	A	Y	N		
		LT64	LOT64	A	Y	N		
		LT66	LOT 66	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
51581	BLADDER TANKS							
521	WELL #1	2	WELL #1	A				
535	LISBON MOBILE HOMES PUMPHOUSE							

Certified Operator Information

Water System Facility: LISBON MOBILE HOMES PUMPHOUSE (WSF ID: 535)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LALIBERTY, ROYCE L.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020

Contact Information

Name		Organization			Job Title	
Mr. Austin Shapiro		Lisbon Mhp, LLC				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Lisbon Mhp, LLC		31550 Northwestern Highway 220		Farmington Hills	MI	48334
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
248-864-0066						

Contact Role(s): **Administrative Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731011	TUNNEL HILL MOBILE HOME PARK	C	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			29				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30			
	1/1/22 - 12/31/24	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per six years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete		
	1/1/20 - 12/31/25				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731011	TUNNEL HILL MOBILE HOME PARK	C	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		29					

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Uranium (4006)				1 routine (RT) per six years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/14 - 12/31/19		Complete
		1/1/20 - 12/31/25		
Combined Radium-226/228 (4010)				1 routine (RT) per six years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/14 - 12/31/19		Complete
		1/1/20 - 12/31/25		
Gross Beta Particle Activity (4100)				1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/17 - 12/31/19		Complete
		1/1/20 - 12/31/22		
		1/1/23 - 12/31/25		
Man-Made Beta Particle & Photon Emitters (4101)				1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/17 - 12/31/19		Complete
		1/1/20 - 12/31/22		
		1/1/23 - 12/31/25		
Tritium (4102)				1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/17 - 12/31/19		Complete
		1/1/20 - 12/31/22		
		1/1/23 - 12/31/25		
Strontium-90 (4174)				1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/17 - 12/31/19		Complete
		1/1/20 - 12/31/22		
		1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)				1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/17 - 12/31/19		Complete
		1/1/20 - 12/31/22		
		1/1/23 - 12/31/25		
Nitrate And Nitrite (NOX)				1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)		1/1/19 - 12/31/19		Complete
		1/1/20 - 12/31/20		
		1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)				1 (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731011	TUNNEL HILL MOBILE HOME PARK	C	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			29				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19	1/1-12/31	Waiver
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	
CROSS CONNECTION EXEMPTION	3/1/2022	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		THC10	KITCHEN TAP	A	Y	3		
		THC13	KITCHEN TAP	A	Y	3		
		THC18	KITCHEN TAP	A	Y	3		
		THLOT	LOT #THC13 KITCHEN	A	Y			
		THLOT10	LOT #THC10 KITCHEN S	A	Y			
		THLOT11	KITCHEN TAP	A	Y	3		
		THLOT12	LOT #12 KITCHEN	A	Y	3		
		THLOT14	KITCHEN TAP	A	Y	3		
		THLOT16	KITCHEN TAP	A	Y	3		
		THLOT17	KITCHEN TAP	A	Y	3		
		THLOT18	LOT 18 KITCHEN	A	Y	3		
		THLOT20	LOT 20	A	Y	3		
		THLOT21	LOT 21	A	Y	3		
		THLOT22	KITCHEN TAP	A	Y	3		
		THLOT23	LOT # 23 KITCHEN	A	Y	3		
		THLOT25	LOT 25	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731011	TUNNEL HILL MOBILE HOME PARK	C	40	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		29					

Towns Served: LISBON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		THLOT26	KITCHEN TAP	A	Y	3		
		THLOT6	KITCHEN TAP	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
51283	WELL-X-TROL							
528	WELL #1	2	WELL #1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
MELLOR, KEVIN	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR CONDITIONAL	6/30/2020
DEMPSEY, BRYAN S.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2020

Contact Information

Name		Organization			Job Title	
Mr. Kevin Mellor		Pleasure Valley M.H.P.			Operator #2	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
225 Bundy Hill Road				Lisbon	CT	06351
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-887-9542		860-887-5945		860-887-9542	pvmhomes@aol.com	

Contact Role(s): **Administrative Contact, Legal Contact**

Name		Organization			Job Title	
Mr. Arthur R. Mellor		Pleasure Valley Mhp				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
225 Bundy Hill Road				Lisbon	CT	06351
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-887-9542		860-887-5945		860-376-4481	PVMHOMES@AOL.COM	

Contact Role(s): **Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731021	ROUND HILL LLC - WELL# 1&2	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
329 RIVER RD - BOTH BUILDINGS			12				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Lead And Copper (PBCU)		5 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/20	6/1-9/30			
	1/1/21 - 12/31/21	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Water System Facility: ENTRY POINT - WELL #1 (NORTH) (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL #1 (NORTH) (3)	1/1/17 - 12/31/19		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731021	ROUND HILL LLC - WELL# 1&2	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
329 RIVER RD - BOTH BUILDINGS			12				
Towns Served: LISBON							

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL #1 (NORTH) (WSF ID: 00700)							
Net Gross Alpha (4000)			1 routine (RT) per three years				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
Uranium (4006)			1 routine (RT) per three years				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL #1 (NORTH) (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
Combined Radium-226/228 (4010)			1 routine (RT) per three years				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL #1 (NORTH) (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
Inorganic Chemicals (IOCS)			1 routine (RT) per three years				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL #1 (NORTH) (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
Nitrate And Nitrite (NOX)			1 routine (RT) per year				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL #1 (NORTH) (3)		1/1/19 - 12/31/19				Complete	
		1/1/20 - 12/31/20					
		1/1/21 - 12/31/21					
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)			1 routine (RT) per three years				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL #1 (NORTH) (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
Organic Chemicals (VOCS)			1 routine (RT) per year				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL #1 (NORTH) (3)		1/1/19 - 12/31/19				Complete	
		1/1/20 - 12/31/20					
		1/1/21 - 12/31/21					
Water System Facility: ENTRY POINT - WELL #2 (WEST) (WSF ID: 00701)							
Inorganic Chemicals (IOCS)			1 routine (RT) per three years				
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL #2 (WEST) (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731021	ROUND HILL LLC - WELL# 1&2	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
329 RIVER RD - BOTH BUILDINGS			12				

Towns Served: LISBON

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL #2 (WEST) (WSF ID: 00701)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 (WEST) (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 (WEST) (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 (WEST) (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 (WEST) (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	APT. #11 BATHROOM SI	A	Y			
		4-1	DISTRIBUTION SYSTEM	A	Y			
		4-2	OUTSIDE TAP	A	Y			
		4-3	Apt. #4	A	Y			
		4-4	Apt. #9	A	Y			
		4-5	Apt #2	A	Y			
				DOWNSTREAM	WITHIN 5 SERVICE CON	A		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELL #1 (NORTH)	3	EP - WELL #1 (NORTH)	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0731021	ROUND HILL LLC - WELL# 1&2	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
329 RIVER RD - BOTH BUILDINGS			12				
Towns Served: LISBON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00701	ENTRY POINT - WELL #2 (WEST)	3	EP - WELL #2 (WEST)	A				
1847	WELL #2	2	WELL #2	A				
520	WELL #1	2	WELL #1	A				
59693	WELL #2 TREATMENT PLANT (WEST)							

Certified Operator Information

Water System Facility: WELL #2 TREATMENT PLANT (WEST) (WSF ID: 59693)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
NAPIERATA, KYLE	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021
LAFRAMBOISE, PAUL F.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021

Contact Information

Name		Organization			Job Title		
Mr. Kyle Napierata		La Framboise Water Svc			Certified Operator		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
647 Thompson Road		P.O. Box 303			Thompson	CT	06277
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-923-9543		860-923-9971		860-508-1330	kyle@thewaterexperts.com		

Contact Role(s): Administrative Contact							
Name		Organization			Job Title		
Mr. Andrew Soulor		329 River LLC			Owner		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
130 Mackin Drive					Griswold	CT	06351
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-705-2388					acsoulor@yahoo.com		

Contact Role(s): **Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule