

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20			
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
Asbestos (1094)		1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		Complete	
	1/1/21 - 12/31/29			
Total Coliform (3100)		50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete	
	11/1/19 - 11/30/19		Complete	
	12/1/19 - 12/31/19		Complete	
	1/1/20 - 1/31/20		Complete	
	2/1/20 - 2/29/20		Complete	
	3/1/20 - 3/31/20			
	4/1/20 - 4/30/20			
	5/1/20 - 5/31/20			
	6/1/20 - 6/30/20			
	7/1/20 - 7/31/20			
	8/1/20 - 8/31/20			
	9/1/20 - 9/30/20			
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
2279 MT VERNON RD (SMP0004)	7/1/19 - 9/30/19	8/1-8/31	Complete	
	10/1/19 - 12/31/19	11/1-11/30	Complete	
	1/1/20 - 3/31/20	2/1-2/28	Complete	
	4/1/20 - 6/30/20	5/1-5/31		
252 MARION AVENUE (SWD0003)	7/1/20 - 9/30/20	8/1-8/31		
	7/1/19 - 9/30/19	8/1-8/31	Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
6 CARTER LANE (SWD0021)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
2321 MERIDEN WTBY RD (SWD0022)	7/1/19 - 9/30/19	8/1-8/31	Complete
	10/1/19 - 12/31/19	11/1-11/30	Complete
	1/1/20 - 3/31/20	2/1-2/28	Complete
	4/1/20 - 6/30/20	5/1-5/31	
	7/1/20 - 9/30/20	8/1-8/31	
Lead And Copper (PBCU)		30 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		50 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		
Water System Facility: SOUTHINGTON FP - ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **SOUTHINGTON FP - ENTRY POINT (WSF ID: 00700)**

	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Uranium (4006)			
EP - SOUTHINGTON FP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Nitrate And Nitrite (NOX)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SOUTHINGTON FP (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
Water System Facility: ENTRY POINT - WELL 1A (WSF ID: 00701)			
Net Gross Alpha (4000)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1A (WSF ID: 00701)

	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Uranium (4006)			
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)			
	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Gross Beta Particle Activity (4100)			
	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Man-Made Beta Particle & Photon Emitters (4101)			
	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Tritium (4102)			
	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Strontium-90 (4174)			
	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)			
	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)			
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)			
	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1A (WSF ID: 00701)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSF ID: 00702)

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/20 - 12/31/22		Complete
	1/1/23 - 12/31/25		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Organic Chemicals (VOCS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 2A (3)	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00703)

Nitrate (1040) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00703)

	1 routine (RT) per quarter		
Nitrate (1040)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
	7/1/20 - 9/30/20		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00703)

Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSF ID: 00704)

Metolachlor (2045)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/19 - 12/31/19		Complete
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSF ID: 00704)

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 7 & 7A (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: ENTRY POINT - WELL 8 (WSF ID: 00705)

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 8 (WSF ID: 00705)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: ENTRY POINT - WELL 9 (WSF ID: 00706)

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/18 - 12/31/20		Complete
	1/1/21 - 12/31/23		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 9 (WSF ID: 00706)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Water System Facility: WELL 8 (WSF ID: 1170)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 8 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		
	2/1/20 - 2/29/20		
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: WELL 7 (WSF ID: 1171)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 7 (2)	1/1/20 - 1/31/20		
	2/1/20 - 2/29/20		
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: WELL 1A (WSF ID: 1172)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1A (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **WELL 1A (WSF ID: 1172)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **WELL 3 (WSF ID: 1173)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **WELL 9 (WSF ID: 1451)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 9 (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: **SOUTHINGTON RESERVOIR #1 (WSF ID: 2235)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **SOUTHINGTON RESERVOIR #1 (WSF ID: 2235)**

Total Alkalinity (1927)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SOUTHINGTON RESERVOIR #1 (1)	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Total Organic Carbon (2920)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SOUTHINGTON RESERVOIR #1 (1)	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SOUTHINGTON RESERVOIR #1 (1)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SOUTHINGTON RESERVOIR #1 (1)	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Surface Water Pesticides (RSOC)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SOUTHINGTON RESERVOIR #1 (1)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
Water System Facility: SOUTHINGTON RESERVOIR #3 (WSF ID: 2237)					
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SOUTHINGTON RESERVOIR #3 (1)	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SOUTHINGTON RESERVOIR #3 (1)	1/1/19 - 12/31/19		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: SOUTHINGTON RESERVOIR #3 (WSF ID: 2237)

Surface Water Inorganic Chemicals (RIOCI) **1 routine (RT) per year**
Sampling Point (Sampling Point ID) *Monitoring Period* *Collection Period* *Compliance Status*

	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Surface Water Color and Turbidity (RPPS) **1 routine (RT) per quarter**
Sampling Point (Sampling Point ID) *Monitoring Period* *Collection Period* *Compliance Status*

SOUTHINGTON RESERVOIR #3 (1)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Surface Water Pesticides (RSOC) **1 routine (RT) per year**
Sampling Point (Sampling Point ID) *Monitoring Period* *Collection Period* *Compliance Status*

SOUTHINGTON RESERVOIR #3 (1)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

Water System Facility: SOUTHINGTON FILTER PLANT (WSF ID: 310)

Total Organic Carbon (2920) **1 routine (RT) per month**
Sampling Point (Sampling Point ID) *Monitoring Period* *Collection Period* *Compliance Status*

EP - SOUTHINGTON FP (5)	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: WELL 7A (WSF ID: 60726)

E. Coli (3014) **1 routine (RT) per month**
Sampling Point (Sampling Point ID) *Monitoring Period* *Collection Period* *Compliance Status*

WELL 7A (2)	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Water System Facility: WELL 2A (WSF ID: 61740)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Monitoring Requirements

Water System Facility: **WELL 2A (WSF ID: 61740)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2A (2)	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **SOUTHINGTON FP - ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily	
Start Date: 7/1/2003		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		10/1/2019 - 10/31/2019	Y	
	Offline	11/1/2019 - 11/30/2019	n/a	Y
	Offline	12/1/2019 - 12/31/2019	n/a	Y
		1/1/2020 - 1/31/2020		
		2/1/2020 - 2/29/2020		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily	
Start Date: 7/1/2003		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		10/1/2019 - 10/31/2019	Y	
	Offline	11/1/2019 - 11/30/2019	n/a	Y
	Offline	12/1/2019 - 12/31/2019	n/a	Y
		1/1/2020 - 1/31/2020		
		2/1/2020 - 2/29/2020		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2	
Start Date: 7/1/2003		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		10/1/2019 - 10/31/2019	Y	
	Offline	11/1/2019 - 11/30/2019	n/a	Y
	Offline	12/1/2019 - 12/31/2019	n/a	Y
		1/1/2020 - 1/31/2020		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	
Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT							
Water System Facility: SOUTHINGTON FP - ENTRY POINT (WSFID: 00700)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L			2		
Start Date: 7/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		2/1/2020 - 2/29/2020					
Water System Facility: ENTRY POINT - WELL 1A (WSFID: 00701)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.53 MG/L			Daily		
Start Date: 6/1/2010		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L			Daily		
Start Date: 7/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSFID: 00702)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 1/1/2020		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 0.7 MG/L			Daily		
Start Date: 1/1/2020		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3.0 MG/L	2
Start Date: 1/1/2020			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Water System Facility: ENTRY POINT - WELL 3 (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 10/1/2017			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	
	12/1/2019 - 12/31/2019	Y	
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 0.8 MG/L	Daily
Start Date: 10/1/2017			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019	Y	
	11/1/2019 - 11/30/2019	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	
Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT							
Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSFID: 00704)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 0.8 MG/L			Daily		
Start Date: 10/1/2017		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L			2		
Start Date: 10/1/2017		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Water System Facility: ENTRY POINT - WELL 8 (WSFID: 00705)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 5/1/2005		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L			Daily		
Start Date: 7/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L			2		
Start Date: 1/1/2002		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	
Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT							
Water System Facility: ENTRY POINT - WELL 8 (WSFID: 00705)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L			2		
Start Date: 1/1/2002		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Water System Facility: ENTRY POINT - WELL 9 (WSFID: 00706)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 5/1/2005		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L			Daily		
Start Date: 1/1/2004		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L			2		
Start Date: 10/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					
Water System Facility: SOUTHINGTON FILTER PLANT (WSFID: 310)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L			Daily		
Start Date: 1/1/2002		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		10/1/2019 - 10/31/2019		Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility: **SOUTHINGTON FILTER PLANT (WSFID: 310)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
	Offline	11/1/2019 - 11/30/2019	n/a
	Offline	12/1/2019 - 12/31/2019	n/a
	Offline	1/1/2020 - 1/31/2020	n/a
		2/1/2020 - 2/29/2020	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		10/1/2019 - 10/31/2019	Y
	Offline	11/1/2019 - 11/30/2019	n/a
	Offline	12/1/2019 - 12/31/2019	n/a
	Offline	1/1/2020 - 1/31/2020	n/a
		2/1/2020 - 2/29/2020	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		10/1/2019 - 10/31/2019	Y
	Offline	11/1/2019 - 11/30/2019	n/a
	Offline	12/1/2019 - 12/31/2019	n/a
	Offline	1/1/2020 - 1/31/2020	n/a
		2/1/2020 - 2/29/2020	Y

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	12/6/2019	
WATERSHED SURVEY REPORT	3/1/2020	12/12/2019
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		4-1	FLANDERS SCHOOL	A	Y			
		4-2	HATTON SCHOOL	A	Y			
		4-3	KELLEY SCHOOL	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		4-4	JW MUNICIPAL CENTER	A	Y			
		4-5	SOUTH END SCHOOL	A	Y			
		4-6	STRONG SCHOOL	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		S-15	WELL 3 RAW/HOBART ST	A	Y			
		SMP0004	2279 MT VERNON RD	A	Y			Y
		SMP004	2279 MT. VERNON RD	A	Y			
		SWD0001	200 EXECUTIVE BLVD	I	Y			
		SWD0002	570 MAIN STREET	I	Y			
		SWD0003	252 MARION AVENUE	A	Y			Y
		SWD0004	1237 MARION AVENUE	A	Y			Y
		SWD0005	1156 M.W.T.	A	Y			
		SWD0006	65 AMATO CIRCLE	I	Y			
		SWD0007	88 BERLIN STREET	A	Y			
		SWD0008	460 PLEASANT STREET	I	Y			
		SWD0009	408 QUEEN STREET	A	Y			
		SWD0010	50 RIVER STREET	A	Y			
		SWD0011	246 REDSTONE STREET	A	Y			
		SWD0012	FILTER PLANT	A				
		SWD0013	ST DOMINIC'S CHURCH	A				
		SWD0014	FLANDERS SCHOOL	A			Y	
		SWD0015	DEPAULO SCHOOL	A				
		SWD0016	TRUCK STOP	A				
		SWD0017	LAKE COMPOUNCE PARK	A				
		SWD0018	388 PLEASANT STREET	A	Y			
		SWD0019	620 MAIN STREET	I	Y			
		SWD0020	1131 WEST STREET	A	Y			
		SWD0021	6 CARTER LANE	A	Y			Y
		SWD0022	2321 MERIDEN WTBY RD	A	Y			
		SWD0A01	KELLEY SCHOOL	A			Y	
		SWD0A02	HATTON SCHOOL	A			Y	
		SWD0A03	SOUTH END SCHOOL	A			Y	
		SWD0A04	JW MUNICIPAL CENTER	A			Y	
		SWD0A05	STRONG SCHOOL	A			Y	
		SWDLC01	29 AMANDA LANE	I	Y	1		
		SWDLC02	37 AMANDA LANE	A	Y	1		
		SWDLC03	48 AMANDA LANE	I	Y	1		
		SWDLC04	54 AMATO CIRCLE	I	Y	1		
		SWDLC05	64 AMATO CIRCLE	I	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SWDLC06	65 AMATO CIRCLE	I	Y	1		
		SWDLC07	289 ANNEISE AVENUE	A	Y	1		
		SWDLC08	93 BISHOP AVENUE	A	Y	1		
		SWDLC09	27 BRIGHTWOOD LANE	A	Y	1		
		SWDLC10	73 BRIGHTWOOD LANE	I	Y	1		
		SWDLC11	93 BUCKLAND STREET	A	Y	1		
		SWDLC12	163 BUTTERNUT LANE	A	Y	1		
		SWDLC13	29 CANTERBURY LANE	A	Y	1		
		SWDLC14	130 CICCOLELLA COURT	A	Y	1		
		SWDLC15	140 CREST ROAD	A	Y	1		
		SWDLC16	54 DAYTON DRIVE	A	Y	1		
		SWDLC17	197 DECKERT DRIVE	I	Y	1		
		SWDLC18	73 DEERBROOKE CRICLE	I	Y	1		
		SWDLC19	93 DOE MEADOW COURT	I	Y	1		
		SWDLC20	105 DOE MEADOW COURT	A	Y	1		
		SWDLC21	54GALLANT DRIVE	A	Y	1		
		SWDLC22	87 GREAT PINE PATH	A	Y	1		
		SWDLC23	28 GREENWOOD DRIVE	I	Y	1		
		SWDLC24	50 GREENWOOD DRIVE	I	Y	1		
		SWDLC25	6 GREYSTONE DRIVE	I	Y	1		
		SWDLC26	20 GREYSTONE DRIVE	I	Y	1		
		SWDLC27	32 GREYSTOE DRIVE	I	Y	1		
		SWDLC28	50 GREYSTONE DRIVE	A	Y	1		
		SWDLC29	51 GREYSTONE DRIVE	A	Y	1		
		SWDLC30	78 GREYSTONE DRIVE	A	Y	1		
		SWDLC31	105 GREYSTONE DRIVE	I	Y	1		
		SWDLC32	461 HART STREET	A	Y	1		
		SWDLC33	82 HOLLY HILL DRIVE	A	Y	1		
		SWDLC34	96 HOLLY HILL DRIVE	A	Y	1		
		SWDLC35	139 HUCKLEBERRY LANE	A	Y	1		
		SWDLC36	192 LEPAGE DRIVE	A	Y	1		
		SWDLC37	24 MARK DRIVE	A	Y	1		
		SWDLC38	50 MARK DRIVE	I	Y	1		
		SWDLC39	580 MOUNT VERNON RD	A	Y	1		
		SWDLC40	10 NUNZIO DRIVE	I	Y	1		
		SWDLC41	50 NUNZIO DRIVE	A	Y	1		
		SWDLC42	64 NUNZIO DRIVE	I	Y	1		
		SWDLC43	65 NUNZIO DRIVE	I	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SWDLC44	74 NUNZIO DRIVE	A	Y	1		
		SWDLC45	75 NUNZIO DRIVE	I	Y	1		
		SWDLC46	85 NUNZIO DRIVE	A	Y	1		
		SWDLC47	95 NUNZIO DRIVE	I	Y	1		
		SWDLC48	105 NUNZIO DRIVE	I	Y	1		
		SWDLC49	110 NUNZIO DRIVE	I	Y	1		
		SWDLC50	120 NUNZIO DRIVE	A	Y	1		
		SWDLC51	57 ROXBURY ROAD	I	Y	1		
		SWDLC52	57 ROXBURY ROAD	A	Y	1		
		SWDLC53	21 ROYAL OAK DRIVE	I	Y	1		
		SWDLC54	20 SUNSET RIDGE	I	Y	1		
		SWDLC55	96 WOODBERRY HILL DR	A	Y	1		
		SWDLC56	50 NUNZIO DRIVE	I		1		
		SWDLC57	74 NUNZIO DRIVE	A		1		
		SWDLC58	85 NUNZIO DRIVE	I		1		
		SWDLC59	95 NUNZIO DRIVE	I		1		
		SWDLC60	110 NUNZIO DRIVE	I		1		
		SWDLC61	120 NUNZIO DRIVE	I		1		
		SWDLC62	21 BELLEVIEW AVE	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	SOUTHINGTON FP - ENTRY POINT	3	EP - SOUTHINGTON FP	A				
00701	ENTRY POINT - WELL 1A	3	EP - WELL 1A	A				
00702	ENTRY POINT - WELLS 2 & 2A	3	EP - WELLS 2 & 2A	A				
00703	ENTRY POINT - WELL 3	3	EP - WELL 3	A				
00704	ENTRY POINT - WELLS 7 & 7A	3	ENTRY POINT - WELLS	A				
00705	ENTRY POINT - WELL 8	3	EP - WELL 8	A				
00706	ENTRY POINT - WELL 9	3	EP - WELL 9	A				
1170	WELL 8	2	WELL 8	A				
1171	WELL 7	2	WELL 7	A				
1172	WELL 1A	2	WELL 1A	A				
1173	WELL 3	2	WELL 3	A				
1451	WELL 9	2	WELL 9	A				
2235	SOUTHINGTON RESERVOIR #1	1	SOUTHINGTON RESERVOI	A				
2236	SOUTHINGTON RESERVOIR #2	1	SOUTHINGTON RESERVOI	A				
2237	SOUTHINGTON RESERVOIR #3	1	SOUTHINGTON RESERVOI	A				
262	WELL #1A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
30082	RESERVOIR #3 INTAKE							
30084	RESERVOIR #1 INTAKE							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
310	SOUTHINGTON FILTER PLANT	5	EP - SOUTHINGTON FP	A				
492	WELLS 2 & 2A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
493	WELL #3 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
494	WELL 7 & 7A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
495	WELL #8 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
496	WELL #9 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
50876	MILL STREET TANK #1							
50878	MILL STREET TANK #2							
50880	SOUTHINGTON FILTER PLANT STORAGE TANK							
50882	WEST QUEEN STREET TANK #1							
50884	WEST QUEEN STREET TANK #2							
50886	VILLAGE GATE STORAGE TANK							
54003	WEST QUEEN STREET BOOSTER STATION							
54005	SOUTHEAST PUMPING STATION							
58145	MARIONDALE DR TANK (NEW)							
60726	WELL 7A	2	WELL 7A	A				
61043	INTERCONNECTION - CT0930011 - RWA							
61740	WELL 2A	2	WELL 2A	A				
XX704	ENTRY POINT - WELL 7	3X	EP - WELL 7	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CASARELLA, WILLIAM M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2022
GEIS, JAMES D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2022
FONTAINE, BARRY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2022
MASCIANGIOLI, JOHN J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
BEHARRY, JOSEPH P.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2022

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Certified Operator Information

Water System Facility: WELL #1A TREATMENT STATION (WSF ID: 262)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SYLVESTER, ALBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2022 6/30/2022
MARINGOLA, WILLIAM J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
CASARELLA, WILLIAM M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022 12/31/2022

Water System Facility: SOUTHINGTON FILTER PLANT (WSF ID: 310)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SYLVESTER, ALBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
GEIS, JAMES D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022 12/31/2022
MARINGOLA, WILLIAM J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
CASARELLA, WILLIAM M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022 12/31/2022

Water System Facility: WELLS 2 & 2A TREATMENT STATION (WSF ID: 492)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SYLVESTER, ALBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2022 6/30/2022
MARINGOLA, WILLIAM J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
CASARELLA, WILLIAM M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2022 6/30/2022

Water System Facility: WELL #3 TREATMENT STATION (WSF ID: 493)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SYLVESTER, ALBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2022 6/30/2022
MARINGOLA, WILLIAM J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
CASARELLA, WILLIAM M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022 12/31/2022

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Certified Operator Information

Water System Facility: WELL 7 & 7A TREATMENT STATION (WSF ID: 494)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SYLVESTER, ALBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2022 6/30/2022
MARINGOLA, WILLIAM J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
CASARELLA, WILLIAM M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022 12/31/2022

Water System Facility: WELL #8 TREATMENT STATION (WSF ID: 495)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SYLVESTER, ALBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
GEIS, JAMES D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022 12/31/2022
MARINGOLA, WILLIAM J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
CASARELLA, WILLIAM M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2022 12/31/2022

Water System Facility: WELL #9 TREATMENT STATION (WSF ID: 496)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SYLVESTER, ALBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
GEIS, JAMES D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2022 6/30/2022
MARINGOLA, WILLIAM J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
CASARELLA, WILLIAM M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2022 6/30/2022

Contact Information

Name		Organization			Job Title	
Mr. William M. Casarella		Southington Water Works Dept			Treatment Foreman	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
605 West Queen St		PO Box 111		Southington	CT	06489
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-628-5593	110	860-621-0491		860-621-2429	bcasarella@southingtonwater.org	
Contact Role(s): Administrative Contact, Legal Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310011	SOUTHINGTON WATER DEPARTMENT	C	43,069	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,665	

Towns Served: CHESHIRE, SOUTHINGTON, WOLCOTT

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			41				

Towns Served: SOUTHINGTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30			
	1/1/22 - 12/31/24	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Net Gross Alpha (4000)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Uranium (4006)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Combined Radium-226/228 (4010)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/21				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			41				

Towns Served: SOUTHINGTON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	KITCHEN	A	Y			
		AVV WH	WELL HOUSE	P	Y			
		AVV1	LOT #1	P				
		AVV10	LOT #10	P				
		AVV11	LOT #11	P				
		AVV12	LOT #12	P				
		AVV13	LOT #13	P				
		AVV14	LOT #14	P				
		AVV15	LOT #15	P	Y	1		
		AVV16	LOT #16	P	Y	3		
		AVV17	LOT #17	P				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		41					

Towns Served: SOUTHINGTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		AVV18	LOT #18	P				
		AVV19	LOT #19	P				
		AVV2	LOT #2	P				
		AVV20	LOT #20	P	Y	3		
		AVV21	LOT #21	P				
		AVV22	LOT #22	P	Y	1		
		AVV23	LOT #23	P				
		AVV24	LOT #24	P				
		AVV25	LOT #25	P	Y	1		
		AVV26	LOT #26	P				
		AVV27	LOT #27	P	Y	3		
		AVV28	LOT #28	P				
		AVV29	LOT #29	P				
		AVV3	LOT #3	P				
		AVV30	LOT #30	P				
		AVV31	LOT #31	P	Y	1		
		AVV32	LOT #32	P				
		AVV33	LOT #33	P	Y	3		
		AVV34	LOT #34	P	Y	1		
		AVV35	LOT #35	P				
		AVV36	LOT #36	P				
		AVV37	LOT #37	P				
		AVV38	LOT #38	P				
		AVV39	LOT #39	P				
		AVV4	LOT #4	P	Y	3		
		AVV40	LOT #40	P				
		AVV5	LOT #5	P				
		AVV6	LOT#6	P				
		AVV7	LOT #7	P				
		AVV8	LOT #8	P				
		AVV9	LOT #9	P				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1037	WELL 1	2	WELL 1	A				
45852	4 - WELL RITE BLADDER TANK							

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		41					

Towns Served: SOUTHINGTON

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HELMING, TRAVIS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2022
BOLTE, LUTZ	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2020

Contact Information

Name		Organization			Job Title	
Mr. Corey Davis		Pyramid Real Estate Group				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
20 Summer Street				Stamford	CT	06901
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-348-8566					corey@pyramidregroup.com	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.