

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490011	HOPKINS SUPPLY	NTNC	77	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
HOPKINS RD						9	
Towns Served: WARREN							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
Total Coliform (3100)		2 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/22	6/1-9/30			
	1/1/23 - 12/31/25	6/1-9/30			
Physical Parameters (PPS)		2 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490011	HOPKINS SUPPLY	NTNC	77	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
HOPKINS RD						9	
Towns Served: WARREN							

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 9/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	10/1/2019 - 10/31/2019		
	11/1/2019 - 11/30/2019		
	12/1/2019 - 12/31/2019		
	1/1/2020 - 1/31/2020		
	2/1/2020 - 2/29/2020		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2013	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		HS-04	AFTER STORAGE TANK	A				
		HS-05	WINERY TASTING SINK	A	Y	1		
		HS-06	INN TASTING SINK	A	Y	1		
		HS-07	HOPKINS KITCHEN SINK	A		1		
		HS-08	BORDEN KITCHEN SINK	A		1		
		HS-09	KING KITCHEN SINK	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490011	HOPKINS SUPPLY	NTNC	77	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
HOPKINS RD						9	
Towns Served: WARREN							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10643	WELL	2	WELL	A				
1541	WATER TREATMENT							
50420	ATMOSPHERIC STORAGE							
50422	PRESSURE STORAGE							

Certified Operator Information

Water System Facility: WATER TREATMENT (WSF ID: 1541)			
Facility Classification: CLASS 1 TREATMENT PLANT			
			Certification Expiration
Operator Name	Operator Type	Certification(s)	
FOSSLAND, TORRENCE J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2020

Contact Information

Name		Organization			Job Title		
Ms. Beth P. Schober		Hopkins Inn			President		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
22 Hopkins Road					New Preston	CT	06777
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-868-7295		860-868-7464		860-868-2506	befra@snet.net		

Contact Role(s): Administrative Contact, Legal Contact							
Name		Organization			Job Title		
Mr. William L. Hopkins		Hopkins Brothers LLC					
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
25 Hopkins Road					Warren	CT	06777
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-868-7954							

- Contact Role(s): **Owner**
- Please note the following:**
- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 - If a Collection Period is specified, all water quality samples must be collected during the specified period.
 - Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490102	WARREN ELEMENTARY SCHOOL	NTNC	140	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 SACKETT HILL ROAD				2			
Towns Served: WARREN							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete		
	1/1/20 - 12/31/28				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/22	6/1-9/30			
	1/1/23 - 12/31/25	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: ENTRY POINT (WSF ID: 00700)					
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490102	WARREN ELEMENTARY SCHOOL	NTNC	140	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 SACKETT HILL ROAD				2			
Towns Served: WARREN							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)			
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WARREN001	KITCHEN SINK 1	A	Y	2		
		WARREN002	KITCHEN SINK 2	A	Y	2		
		WARREN003	KITCHEN SINK 3	A	Y	2		
		WARREN004	GIRLS LAV AT KITCHEN	A	Y	2		
		WARREN005	BOYS LAV AT KITCHEN	A	Y	2		
		WARREN006	ROOM 29	A	Y	2		
		WARREN007	ROOM 25 NURSE	A	Y	2		
		WARREN008	GIRLS LAV NEAR GYM	A	Y	2		
		WARREN009	BOYS LAV NEAR GYM	A	Y	2		
		WARREN010	ART ROOM RM 10	A	Y	2		
		WARREN011	ROOM 13	A	Y	2		
		WARREN012	ROOM 15	A	Y	2		
		WARREN013	ROOM 14 SINK 1	A	Y	2		
		WARREN014	ROOM 14 SINK 2	A	Y	2		
		WARREN015	ROOM 12 SINK 1	A	Y	2		
		WARREN016	ROOM 12 SINK 2	A	Y	2		
		WARREN017	ROOM 17	A	Y	2		
		WARREN018	ROOM 19	A	Y	2		
		WARREN019	ROOM 16	A	Y	2	Y	
		WARREN020	GIRLS LAVATORY	A	Y	2	Y	
		WARREN021	BOYS LAVATORY	A	Y	2	Y	
		WARREN022	ROOM 39 LIBRARY	A	Y	2		
		WARREN023	PUMP ROOM	A	Y	2		
00700	ENTRY POINT	3	ENTRY POINT	A				
		WARREN023	PUMP ROOM	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490102	WARREN ELEMENTARY SCHOOL	NTNC	140	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
21 SACKETT HILL ROAD				2			
Towns Served: WARREN							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
52442	WELL #2	2	WELL #2	A				
52444	WELL #3	2	WELL #3	A				
52446	ATMOSPHERIC STORAGE TANKS (4)							
52448	BLADDER TANK							
52450	PUMP STATION							
54021	WARREN ELEM. SCHOOL TREATMENT SYSTEM							

Certified Operator Information

Water System Facility: WARREN ELEM. SCHOOL TREATMENT SYSTEM (WSF ID: 54021)			
Facility Classification:			
Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020 6/30/2020
GIORDANO, DAVID S.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2020 6/30/2020

Contact Information

Name		Organization			Job Title		
Town of Warren							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
50 Cemetery Rd					Warren	CT	06754
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-868-7881		860-868-7746					

Contact Role(s): Owner							
Name		Organization			Job Title		
Mr. Scott Yuschak		Regional School District #6			Maintenance Tech		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
98 Wamogo Road					Litchfield	CT	06759
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-567-7400		860-567-6652		860-567-7400	syuschak@rsd6.org		

Contact Role(s): Administrative Contact, Legal Contact

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490024	WARREN CONGREGATIONAL CHURCH	NTNC	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
6 SACKETT HILL ROAD				1			
Towns Served: WARREN							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		

Total Coliform (3100) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Lead And Copper (PBCU) **5 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete
	1/1/20 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/21	6/1-9/30	

Physical Parameters (PPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		Complete
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		

Pesticides, Herbicides and PCBs-Phase II (SOC2) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490024	WARREN CONGREGATIONAL CHURCH	NTNC	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
6 SACKETT HILL ROAD				1			
Towns Served: WARREN							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Organic Chemicals (VOCS)			1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WARREN001	MAIN KIT-HAND SINK	A	Y	2	Y	
		WARREN002	MAIN KIT-ISLAND SINK	A	Y	2	Y	
		WARREN003	CHURCH BATHROOM	A	Y	3	Y	
		WARREN004	PARSONAGE	A	Y	3	Y	
		WARREN005	ACADEMY BLD	A	Y	3	Y	
00700	ENTRY POINT	3	ENTRY POINT	A				
1733	WARREN CONGREGATIONAL CHURCH TRT PLANT							
51335	PRESSURE STORAGE							
55081	WELL #1A	2	WELL #1A	A				

Certified Operator Information

Water System Facility: WARREN CONGREGATIONAL CHURCH TRT PLANT (WSF ID: 1733)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Expiration</i>
LEMAY, REALE D.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2022
KILBOURN, ERIC M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2022

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1490024	WARREN CONGREGATIONAL CHURCH	NTNC	54	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
6 SACKETT HILL ROAD				1			
Towns Served: WARREN							

Contact Information

Name			Organization			Job Title			
Mr. Carl Hetzel			Warren Congregational Church			Moderator			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
6 Sackett Hill Road						Warren		CT	06754
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-868-7106		860-868-1067		860-619-8009	carlpamh@yahoo.com				

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule