

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600031</b>	<b>WOODHAVEN APARTMENTS</b>	C	489	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
80 CISAR ROAD			131				
Towns Served: WILLINGTON							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	9/24/19 - 9/29/19		Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/22	6/1-9/30			
	1/1/23 - 12/31/25	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600031</b>	<b>WOODHAVEN APARTMENTS</b>	C	489	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
80 CISAR ROAD			131				

Towns Served: WILLINGTON

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate (1040)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/19 - 9/30/19		Complete
	10/1/19 - 12/31/19		Complete
	1/1/20 - 3/31/20		
	4/1/20 - 6/30/20		
	7/1/20 - 9/30/20		
<b>Nitrite (1041)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600031</b>	<b>WOODHAVEN APARTMENTS</b>	C	489	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
80 CISAR ROAD			131				
Towns Served: WILLINGTON							

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

Water System Facility: **WELL 1 (WSF ID: 199)**

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 1 (2)	9/23/19 - 9/29/19		Complete		

Water System Facility: **WELL 2 (WSF ID: 200)**

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 2 (2)	9/23/19 - 9/29/19		Complete		

Water System Facility: **WELL 3 (WSF ID: 201)**

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 3 (2)	9/23/19 - 9/29/19		Complete		

Water System Facility: **WELL 4 (WSF ID: 202)**

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 4 (2)	9/23/19 - 9/29/19		Complete		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2019	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	10KIT	BLDG 100 OFFICE SINK	A	Y	N	Y	Y
		17KIT	BLDG 100 #17 SINK	A	Y	N	Y	Y
		22KIT	BLDG 100 #22 SINK	A	Y	N	Y	Y
		37KIT	BLDG 200 #37 SINK	A	Y	N	Y	Y
		4	GENERIC DISTRIBUTION	A	Y			
		4KIT	BLDG 100 #4 SINK	A	Y	N	Y	Y
		90KIT	BLDG 300 #90 SINK	A	Y	N	Y	Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LD RM 1	BLDG 100 LAUNDRY RM	A	Y	N		Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600031</b>	<b>WOODHAVEN APARTMENTS</b>	C	489	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
80 CISAR ROAD			131				
Towns Served: WILLINGTON							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LD RM 2	BLDG 200 LAUNDRY RM	A	Y	N	Y	Y
		LD RM 3	BLDG 300 LAUNDRY RM	A	Y	N	Y	Y
		LD RM 4	BLDG 400 LAUNDRY RM	A	Y	N	Y	Y
		LDRM1	BLDG 100 LAUNDRY RM	A	Y	N	Y	Y
		LDRM2	BLDG 200 LAUNDRY RM	A	Y	N	Y	Y
		LDRM3	BLDG 300 LAUNDRY RM	A	Y	N	Y	Y
		LDRM4	BLDG 400 LAUNDRY RM	A	Y	N	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
199	WELL 1	2	WELL 1	A				
200	WELL 2	2	WELL 2	A				
201	WELL 3	2	WELL 3	A				
202	WELL 4	2	WELL 4	A				
60005	ATMOSHPERIC TANK							
60007	PUMP HOUSE							

## Certified Operator Information

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification:</b> SMALL WATER SYSTEM			
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	<b>Certification Expiration</b>
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2020

## Contact Information

Name		Organization			Job Title	
<b>Mr. Kirk S. Lucas</b>		Glk Realty, LLC			Manager	
Mailing Address Line One			Mailing Address Line Two		City	State
50 Founders Plaza, Suite 101					East Hartford	CT
Zip Code						
06108						
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-568-4400				860-568-4400	kirk.glk@snet.net	

**Contact Role(s):** Administrative Contact, Legal Contact, Owner

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600041</b>	<b>WALDEN APARTMENTS</b>	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
70 PINNEY HILL ROAD			110				
Towns Served: WILLINGTON							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/20	6/1-9/30	Complete		
	1/1/21 - 12/31/21	6/1-9/30	Complete		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20		Complete		
	5/1/20 - 5/31/20		Complete		
	6/1/20 - 6/30/20		Complete		
	7/1/20 - 7/31/20		Complete		
	8/1/20 - 8/31/20		Complete		
	9/1/20 - 9/30/20		Complete		
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600041</b>	<b>WALDEN APARTMENTS</b>	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
70 PINNEY HILL ROAD			110				
Towns Served: WILLINGTON							

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600041</b>	<b>WALDEN APARTMENTS</b>	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
70 PINNEY HILL ROAD			110				
Towns Served: WILLINGTON							

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2024	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	15 KIT	BLDG 1 #15 KIT SINK	A	Y			
		25 KIT	BLDG 1 #25 KIT SINK	A	Y	3		
		3 KIT	BLDG 1 #3 KIT SINK	A	Y	3		
		4	GENERIC DISTRIBUTION	A	Y			
		6 KIT	BLDG 1 #6 KIT SINK	A	Y	3		
		76 KIT	BLDG 2 #76 KIT SINK	A	Y	3		
		98KIT	BLDG 2 #98 KIT SINK	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		KITSK	BLDG 1 #15 KIT SINK	A	Y	3		
		LD RM 3	BLDG 2 LAUNDRY RM 3	A	Y	3		
		LDRM#1	LAUNDRY ROOM	A	Y			
		LDRM1	BLDG 1 LAUNDRY RM 1	A	Y	3		
		LDRM2	BLDG 1 LAUNDRY RM 2	A	Y	3		
		MAIN OFF	OFFICE BATHROOM SINK	A	Y			
		MAIN OFFICE	REST ROOM SINK	A	Y			
		MAINOFF	REST ROOM SINK	A	Y	3		
		SHOP SINK	BLDG1MNT RM	A	Y			
		SHOPSINK	BLDG 1 MNT RM	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		00700	ENTRY POINT	3	ENTRY POINT	A		
195	WELL 6	2	WELL 6	A				
196	WELL 5	2	WELL 5	A				
197	WELL 3	2	WELL 3	A				
225	WELL 7	2	WELL 7	A				
50152	ATMOSPHERIC TANK							
50156	WELL 8	2	WELL 8	A				
59410	TREATMENT PLANT							
59412	BOOSTER STATION							
59414	BLADDER TANK							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600041</b>	<b>WALDEN APARTMENTS</b>	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
70 PINNEY HILL ROAD			110				
Towns Served: WILLINGTON							

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 59410)**

### Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2022
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022 6/30/2020

## Contact Information

Name		Organization		Job Title		
<b>Mr. Kirk S. Lucas</b>		Glk Realty, LLC		Manager		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
50 Founders Plaza, Suite 101				East Hartford	CT	06108
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-568-4400				860-568-4400	kirk.glk@snet.net	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600051</b>	<b>RIDGEVIEW HEIGHTS</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
456 TOLLAND TURNPIKE			48				
Towns Served: WILLINGTON							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
<b>Chlorine Residual (1012)</b>		<b>4 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 1/31/20		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
UNIT 11A (RIDHE001)	1/1/19 - 12/31/19	9/1-9/30			
	1/1/20 - 12/31/20	9/1-9/30			
	1/1/21 - 12/31/21	9/1-9/30			
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
UNIT 21A (RIDHE013)	1/1/19 - 12/31/19	9/1-9/30	Complete		
	1/1/20 - 12/31/20	9/1-9/30			
	1/1/21 - 12/31/21	9/1-9/30			
<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/14/20 - 1/19/20		Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600051</b>	<b>RIDGEVIEW HEIGHTS</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
456 TOLLAND TURNPIKE			48				
Towns Served: WILLINGTON							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				

<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 12/31/19		Complete		
	1/1/20 - 6/30/20				
	7/1/20 - 12/31/20				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20				
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				

<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600051</b>	<b>RIDGEVIEW HEIGHTS</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
456 TOLLAND TURNPIKE			48				
Towns Served: WILLINGTON							

## Monitoring Requirements

Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>							
<b>Combined Radium-226/228 (4010)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
<b>Inorganic Chemicals (IOCS)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/18 - 12/31/20				Complete	
		1/1/21 - 12/31/23					
<b>Nitrate And Nitrite (NOX)</b>				<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/19 - 12/31/19				Complete	
		1/1/20 - 12/31/20					
		1/1/21 - 12/31/21					
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
<b>Organic Chemicals (VOCS)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
ENTRY POINT (3)		1/1/18 - 12/31/20				Complete	
		1/1/21 - 12/31/23					

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: <b>TREATMENT PLANT (WSFID: 60285)</b>							
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>			<b>Samples Req/Month</b>		
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.3 MG/L			Daily		
<b>Start Date:</b> 9/1/2016		<b>Compliance History:</b>		<b>Operating Limit</b>	<b>Monitoring</b>		
		<b>Monitoring Period</b>		<b>Compliance Status:</b>	<b>Compliance Status:</b>		
		10/1/2019 - 10/31/2019		Y			
		11/1/2019 - 11/30/2019		Y			
		12/1/2019 - 12/31/2019		Y			
		1/1/2020 - 1/31/2020					
		2/1/2020 - 2/29/2020					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600051</b>	<b>RIDGEVIEW HEIGHTS</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
456 TOLLAND TURNPIKE			48				
Towns Served: WILLINGTON							

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	3/1/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2019	
LEAD PUBLIC EDUCATION REPORT TO STATE	3/10/2019	
CCTS 1: PWS TO RECOMMEND OCCT	6/30/2019	
SWTS 1: PWS TO RECOMMEND SOWT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	9/30/2019	9/13/2019
LEAD PUBLIC EDUCATION REPORT TO STATE	9/30/2019	9/13/2019
LEAD PUBLIC EDUCATION REPORT TO STATE	10/31/2019	11/3/2019
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	10/31/2019	10/30/2019
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	11/30/2019	11/14/2019
LEAD PUBLIC EDUCATION REPORT TO STATE	11/30/2019	11/14/2019
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	12/31/2019	12/15/2019
LEAD PUBLIC EDUCATION REPORT TO STATE	12/31/2019	12/15/2019
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	1/31/2020	1/14/2020
LEAD PUBLIC EDUCATION REPORT TO STATE	1/31/2020	1/14/2020
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	2/29/2020	2/19/2020
LEAD PUBLIC EDUCATION REPORT TO STATE	2/29/2020	2/19/2020
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/30/2020	
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	3/31/2020	
LEAD PUBLIC EDUCATION REPORT TO STATE	3/31/2020	
SUBMIT CCR TO THE DEPARTMENT	7/1/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	12/31/2020	
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	12/31/2020	

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
E. Coli	10/1/17 - 10/31/17	3	3/16/2019		3/26/2019	
Lead and Copper TT Violation	7/1/19 -	2	9/12/2019		9/22/2019	
Total Trihalomethanes M&R Violation	1/1/18 - 12/31/18	3	2/13/2020		2/23/2020	
Nitrate And Nitrite M&R Violation	1/1/18 - 12/31/18	3	2/13/2020		2/23/2020	
Chlorine M&R Violation	12/1/17 - 12/31/17	3	3/25/2020		4/4/2020	
Chlorine M&R Violation	1/1/18 - 1/31/18	3	3/25/2020		4/4/2020	
Chlorine M&R Violation	2/1/18 - 2/28/18	3	3/25/2020		4/4/2020	
Chlorine M&R Violation	3/1/18 - 3/31/18	3	3/25/2020		4/4/2020	
Chlorine M&R Violation	12/1/18 - 12/31/18	3	3/25/2020		4/4/2020	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600051</b>	<b>RIDGEVIEW HEIGHTS</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
456 TOLLAND TURNPIKE		48					
Towns Served: WILLINGTON							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		RIDH020	RV	A	Y			
		RIDHE001	UNIT 11A	A	Y	N	Y	Y
		RIDHE002	UNIT 11B	A	Y	N	Y	Y
		RIDHE003	UNIT 12A	A	Y	N	Y	Y
		RIDHE004	UNIT 12B	A	Y	N	Y	Y
		RIDHE005	UNIT 13A	A	Y	N	Y	Y
		RIDHE006	UNIT 13B	A	Y	N	Y	Y
		RIDHE007	UNIT 14A	A	Y	N	Y	Y
		RIDHE008	UNIT 14B	A	Y	N	Y	Y
		RIDHE009	UNIT 15A	A	Y	N	Y	Y
		RIDHE010	UNIT 15B	A	Y	N	Y	Y
		RIDHE011	UNIT 16A	A	Y	N	Y	Y
		RIDHE012	UNIT 16B	A	Y	N	Y	Y
		RIDHE013	UNIT 21A	A	Y	N	Y	Y
		RIDHE014	UNIT 21B	A	Y	N	Y	Y
		RIDHE015	UNIT 22A	A	Y	N	Y	Y
		RIDHE016	UNIT 22B	A	Y	N	Y	Y
		RIDHE017	UNIT 23A	A	Y	N	Y	Y
		RIDHE018	UNIT 23B	A	Y	N	Y	Y
		RIDHE019	UNIT 24A	A	Y	N	Y	Y
		RIDHE020	UNIT 24B	A	Y	N	Y	Y
		RIDHE021	UNIT 25A	A	Y	N	Y	Y
		RIDHE022	UNIT 25B	A	Y	N	Y	Y
		RIDHE023	UNIT 26A	A	Y	N	Y	Y
		RIDHE024	UNIT 26B	A	Y	N	Y	Y
		RIDHE025	UNIT 31A	A	Y	N	Y	Y
		RIDHE026	UNIT 31B	A	Y	N	Y	Y
		RIDHE027	UNIT 32A	A	Y	N	Y	Y
		RIDHE028	UNIT 32B	A	Y	N	Y	Y
		RIDHE029	UNIT 33A	A	Y	N	Y	Y
		RIDHE030	UNIT 33B	A	Y	N	Y	Y
		RIDHE031	UNIT 34A	A	Y	N	Y	Y
		RIDHE032	UNIT 34B	A	Y	N	Y	Y
		RIDHE033	UNIT 35A	A	Y	N	Y	Y
		RIDHE034	UNIT 35B	A	Y	N	Y	Y
		RIDHE035	UNIT 36A	A	Y	N	Y	Y
		RIDHE036	UNIT 36B	A	Y	N	Y	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600051</b>	<b>RIDGEVIEW HEIGHTS</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
456 TOLLAND TURNPIKE		48					
Towns Served: WILLINGTON							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		RIDHE037	UNIT 41A	A	Y	N	Y	
		RIDHE038	UNIT 41B	A	Y	N	Y	
		RIDHE039	UNIT 42A	A	Y	N	Y	
		RIDHE040	UNIT 42B	A	Y	N	Y	
		RIDHE041	UNIT 43A	A	Y	N	Y	
		RIDHE042	UNIT 43B	A	Y	N	Y	
		RIDHE043	UNIT 44A	A	Y	N	Y	
		RIDHE044	UNIT 44B	A	Y	N	Y	
		RIDHE045	UNIT 45A	A	Y	N	Y	
		RIDHE046	UNIT 45B	A	Y	N	Y	
		RIDHE047	UNIT 46A	A	Y	N	Y	
		RIDHE048	UNIT 46B	A	Y	N	Y	
		RIDHE049	BLDG 1 LAUNDRY SP	A	Y		Y	
		RIDHE050	BLDG 2 LAUNDRY SP	A	Y		Y	
		RIDHE051	BLDG 3 LAUNDRY SP	A	Y		Y	
		RIDHE052	BLDG 4 LAUNDRY SP	A	Y		Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
272	WELL 2	2	WELL 2	A				
273	WELL 3	2	WELL 3	A				
275	WELL 1	2	WELL 1	A				
56028	HYDROPNEUMATIC STORAGE TANK							
60285	TREATMENT PLANT							

### Certified Operator Information

Water System Facility: <b>TREATMENT PLANT (WSF ID: 60285)</b>			
Facility Classification: CLASS 1 TREATMENT PLANT			
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	<b>Certification Expiration</b>
KLOBUKOWSKI, STEVEN J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022 6/30/2020

### Contact Information

Name		Organization			Job Title		
Mr. Yitzchock Rabinowitz		Willington Property Group LLC			Owner		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
61 Interstate Ln					Waterbury	CT	06705
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-573-9870	101	203-575-2078			yr@axelagroup.com		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1600051</b>	<b>RIDGEVIEW HEIGHTS</b>	<b>C</b>	<b>96</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
456 TOLLAND TURNPIKE		48						
Towns Served: WILLINGTON								
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>								
Name			Organization			Job Title		
<b>Mr. Kyle Mayer</b>			Axela Management			Property Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
61 Interstate Lane						Waterbury	CT	06705
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-919-8966					kmayer@axelamanagement.com			
Contact Role(s): <b>Legal Contact</b>								
<b>Please note the following:</b>								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1600061	NORTH WILLINGTON VILLAGE CONDO ASSOC.	C	66	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			27				

Towns Served: WILLINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/19 - 12/31/21	6/1-9/30			
	1/1/22 - 12/31/24	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20				
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1600061	NORTH WILLINGTON VILLAGE CONDO ASSOC.	C	66	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			27				

Towns Served: WILLINGTON

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	
CROSS CONNECTION EXEMPTION	3/1/2024	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NWC001	B 10 UNITS 8, 10	A	Y	2		
		NWC002	B 8 UNITS 16, 18	A	Y	2		
		NWC003	B 9 UNITS 12, 14	A	Y	2		
		NWC004	B 1 UNITS 60, 62	A	Y	2		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600061</b>	<b>NORTH WILLINGTON VILLAGE CONDO ASSOC.</b>	C	66	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			27				

Towns Served: WILLINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		NWC005	B 2 UNITS 58 TO 58	A	Y	2		
		NWC006	B 11 UNIT 7	A	Y	2	Y	
		NWC007	B 7 UNITS 24, 26	A	Y	2		
		NWC008	B 6 UNITS 28 TO 34	A	Y	2		
		NWC009	B 5 UNITS 36, 38	A	Y	2		
		NWC010	B 4 UNITS 40 TO 46	A	Y	2		
		NWC011	B 3 UNITS 48, 50	A	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1749	WELL 2	2	WELL 2	A				
486	TREATMENT PLANT							
60659	ATMOSPHERIC TANK							
61322	PRESSURE STORAGE							

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2021

Water System Facility: **TREATMENT PLANT (WSF ID: 486)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2021
SYME, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2022

### Contact Information

Name		Organization			Job Title	
<b>Ms. Cynthia L. Carrier</b>		North Willington Village Condo			President	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
63 Schofield Rd, Unit 8				Willington	CT	06279
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-684-6194					cindylou902@gmail.com	
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1600061</b>	<b>NORTH WILLINGTON VILLAGE CONDO ASSOC.</b>	<b>C</b>	<b>66</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			27					
Towns Served: WILLINGTON								
Name			Organization			Job Title		
<b>Condo Realty LLC</b>								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
169 Main Street						Manchester	CT	06042
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s):		<b>Owner</b>						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600071</b>	<b>DEER PARK APARTMENTS</b>	C	125	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 RUBY ROAD			45				

Towns Served: WILLINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete		
	1/1/20 - 12/31/22	6/1-9/30			
	1/1/23 - 12/31/25	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
<b>Water System Facility: ENTRY POINT - WELL 2 (WSF ID: 00701)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELL 2 (3)	1/1/17 - 12/31/19		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600071</b>	<b>DEER PARK APARTMENTS</b>	C	125	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 RUBY ROAD			45				
Towns Served: WILLINGTON							

## Monitoring Requirements

<b>Water System Facility: ENTRY POINT - WELL 2 (WSF ID: 00701)</b>							
<b>Inorganic Chemicals (IOCS)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
<b>Nitrate And Nitrite (NOX)</b>				<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL 2 (3)		1/1/19 - 12/31/19				Complete	
		1/1/20 - 12/31/20				Complete	
		1/1/21 - 12/31/21					
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>				<b>1 routine (RT) per six years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL 2 (3)		1/1/14 - 12/31/19				Complete	
		1/1/20 - 12/31/25					
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>				<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL 2 (3)		1/1/17 - 12/31/19				Complete	
		1/1/20 - 12/31/22					
		1/1/23 - 12/31/25					
<b>Organic Chemicals (VOCS)</b>				<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>		<i>Collection Period</i>		<i>Compliance Status</i>	
EP - WELL 2 (3)		1/1/19 - 12/31/19				Complete	
		1/1/20 - 12/31/20				Complete	
		1/1/21 - 12/31/21					

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
RESPOND TO SANITARY SURVEY	1/19/2020	
CROSS CONNECTION EXEMPTION	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	APT #9 KITCHEN SINK	A	Y	2		
		4-10	APT #39	A	Y	2		
		4-11	LAUNDRY ROOM	A	Y	2		
		4-2	APT #3 KITCHEN SINK	A	Y	2	Y	Y
		4-3	APT #33 KITCHEN SINK	A	Y	2		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600071</b>	<b>DEER PARK APARTMENTS</b>	<b>C</b>	<b>125</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 RUBY ROAD			45				
Towns Served: WILLINGTON							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		4-4	APT #28 KITCHEN SINK	A	Y	2		
		4-5	APT #37 KITCHEN SINK	A	Y	2		
		4-6	APT #9	A	Y	2		
		4-7	APT #21	A	Y	2		
		4-8	APT #25	A	Y	2		
		4-9	APT #35	A	Y	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELL 2	3	EP - WELL 2	A				
58159	WELL 2	2	WELL 2	A				
58161	PUMP STATION							
60436	ATMOSPHERIC STORAGE TANK							

### Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
Facility Classification: SMALL WATER SYSTEM			
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	<b>Certification Expiration</b>
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021
LAFRAMBOISE, JEFFREY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020

### Contact Information

Name		Organization			Job Title		
<b>Mr. William Gajewski</b>		Gajewski Realty					
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 1123					Sturbridge	MA	01566
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
508-764-1474			774-200-0078		mgmt@orchardacresapartments.com		
Contact Role(s): <b>Owner</b>							
Name		Organization			Job Title		
<b>Mr. Thomas Gajewski</b>		Gajewski Realty			Co-President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
Gajewski Realty Trust		28 Healy Road			Dudley	MA	01571
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
			774-200-0852		mgmt@orchardacresapartments.com		
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
<b>CT1600071</b>	<b>DEER PARK APARTMENTS</b>	<b>C</b>	<b>125</b>	<b>P</b>	<b>GW</b>	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 RUBY ROAD		45				
Towns Served: WILLINGTON						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1600081	CEDAR RIDGE APARTMENTS	C	300	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			100				

Towns Served: MANSFIELD, WILLINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30			
	1/1/22 - 12/31/24	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: <b>ENTRY POINT - WELLS 5 &amp; 6 (WSF ID: 00700)</b>					
<b>Di(2-Ethylhexyl) - Phthalate (2039)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 5 & 6 (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
	1/1/21 - 12/31/21				
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 5 & 6 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 5 & 6 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 5 & 6 (3)	1/1/17 - 12/31/19		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600081</b>	<b>CEDAR RIDGE APARTMENTS</b>	C	300	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			100				

Towns Served: MANSFIELD, WILLINGTON

### Monitoring Requirements

**Water System Facility: ENTRY POINT - WELLS 5 & 6 (WSF ID: 00700)**

<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 5 & 6 (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 5 & 6 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 5 & 6 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 5 & 6 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 5 & 6 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

**Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00701)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELL 3 (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELL 3 (3)	1/1/19 - 12/31/21		Complete
	1/1/22 - 12/31/24		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELL 3 (3)	1/1/19 - 12/31/21		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600081</b>	<b>CEDAR RIDGE APARTMENTS</b>	C	300	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			100				

Towns Served: MANSFIELD, WILLINGTON

## Monitoring Requirements

<b>Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00701)</b>			
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/22 - 12/31/24		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELL 3 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELL 3 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELL 3 (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
	1/1/21 - 12/31/21		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	7/1/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Combined Radium-226/228 M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	
Uranium M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	
Net Gross Alpha M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	
Pesticides, Herbicides and PCBs - Phase M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	
Organic Chemicals M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	

## Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Samplina Point</i>	<i>Samplina Point</i>	<i>Total Coliform</i>	<i>Lead and Copper</i>	<i>Stage</i>
---------------------	------------------------------	-----------------------	-----------------------	-----------------------	------------------------	--------------

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600081</b>	<b>CEDAR RIDGE APARTMENTS</b>	<b>C</b>	<b>300</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			100				

Towns Served: MANSFIELD, WILLINGTON

Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y		
		CB001	C BOILER	A	Y	2	
		CDR001	CEDAR RIDGE OFFICE	A	Y	2	
		DB001	D BOILER	A	Y	2	
	DOWNSTREAM		WITHIN 5 SERVICE CON	A			
		EB001	E BOILER	A	Y	2	
		FB001	F BOILER	A	Y	2	
	UPSTREAM		WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT - WELLS 5 & 6	3	EP - WELLS 5 & 6	A			
00701	ENTRY POINT - WELL 3	3	ENTRY POINT - WELL 3	A			
205	WELL 6	2	WELL 6	A			
206	WELL 5	2	WELL 5	A			
228	WELL 3	2	WELL 3	A			
350	WELL #3 PUMPHOUSE						
51041	ATMOSPHERIC STORAGE						
51043	PRESSURE STORAGE 1						
51045	PRESSURE STORAGE 2						

## Certified Operator Information

Water System Facility: **WELL #3 PUMPHOUSE (WSF ID: 350)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KLOBUKOWSKI, STEVEN J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2022
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020

## Contact Information

Name		Organization			Job Title		
<b>Uconn Cedar LLC</b>							
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
160 Greentree Drive, Suite 101,					Dover	DE	19904
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
248-432-3200		248-432-3201					
Contact Role(s): <b>Owner</b>							
Name		Organization			Job Title		
<b>Mr. Yitzchock Rabinowitz</b>		Willington Property Group LLC			Owner		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
61 Interstate Ln					Waterbury	CT	06705
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-573-9870	101	203-575-2078			yr@axelagroup.com		
Contact Role(s): <b>Legal Contact, Owner</b>							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1600081</b>	<b>CEDAR RIDGE APARTMENTS</b>	<b>C</b>	<b>300</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			100					
Towns Served: MANSFIELD, WILLINGTON								
Name			Organization			Job Title		
<b>Mr. Martin Brousseau</b>			Landmark Properties			Maintenance Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
43 Burt Latham Rd						Wilmington	CT	06279
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-941-6005					martin.brousseau@storrstudentliving.com			
Contact Role(s): <b>Administrative Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600101</b>	<b>NATURAL PARK APARTMENTS, LLC</b>	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			20				

Towns Served: WILLINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	11/15/19 - 11/20/19		Complete		
	1/7/20 - 1/12/20		Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 12/31/19		Complete		
	1/1/20 - 6/30/20				
	7/1/20 - 12/31/20				
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete		
	11/1/19 - 11/30/19		Complete		
	12/1/19 - 12/31/19		Complete		
	1/1/20 - 1/31/20		Complete		
	2/1/20 - 2/29/20		Complete		
	3/1/20 - 3/31/20		Complete		
	4/1/20 - 4/30/20				
	5/1/20 - 5/31/20				
	6/1/20 - 6/30/20				
	7/1/20 - 7/31/20				
	8/1/20 - 8/31/20				
	9/1/20 - 9/30/20				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600101</b>	<b>NATURAL PARK APARTMENTS, LLC</b>	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			20				

Towns Served: WILLINGTON

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per six years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete		
	1/1/20 - 12/31/25				
<b>Uranium (4006)</b>		<b>1 routine (RT) per six years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete		
	1/1/20 - 12/31/25				
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per six years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/14 - 12/31/19		Complete		
	1/1/20 - 12/31/25				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/21		Complete		
	1/1/22 - 12/31/24				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20		Complete		
	1/1/21 - 12/31/21				
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
Water System Facility: <b>WELL 1 (WSF ID: 279)</b>					
<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 1 (2)	11/14/19 - 11/20/19		Complete		
	1/6/20 - 1/12/20		Complete		
Water System Facility: <b>WELL 2 (WSF ID: 295)</b>					
<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 2 (2)	11/14/19 - 11/20/19		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600101</b>	<b>NATURAL PARK APARTMENTS, LLC</b>	C	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			20				

Towns Served: WILLINGTON

## Monitoring Requirements

Water System Facility: **WELL 2 (WSF ID: 295)**

<b>E. Coli (3014)</b>	<b>1 triggered (TG) per period</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
	<i>Collection Period</i>
	<i>Compliance Status</i>
	1/6/20 - 1/12/20
	Complete

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	9/30/2019	3/20/2019
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	10/28/2019	10/1/2019
LEAD PUBLIC EDUCATION REPORT TO STATE	10/28/2019	10/1/2019
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	11/28/2019	11/4/2019
LEAD PUBLIC EDUCATION REPORT TO STATE	11/28/2019	11/4/2019
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	12/28/2019	12/5/2019
LEAD PUBLIC EDUCATION REPORT TO STATE	12/28/2019	12/5/2019
RESPOND TO SANITARY SURVEY	1/19/2020	
LEAD PUBLIC EDUCATION REPORT TO STATE	1/28/2020	1/6/2020
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	1/28/2020	1/6/2020
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	2/28/2020	2/6/2020
LEAD PUBLIC EDUCATION REPORT TO STATE	2/28/2020	2/6/2020
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	3/28/2020	
LEAD PUBLIC EDUCATION REPORT TO STATE	3/28/2020	
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	4/18/2020	
CCTS 5: PWS OCCT INSTALLATION	4/24/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	
CROSS CONNECTION EXEMPTION	3/1/2024	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NPA003	APARTMENT 2	A	Y	3	Y	Y
		NPA004	APARTMENT 5	A	Y	3		
		NPA005	APARTMENT 8	A	Y	3		
		NPA006	APARTMENT 11	A	Y	3		
		NPA007	APARTMENT 15	A	Y	3		
		NPA008	APARTMENT 18	A	Y	3		
		NPA009	APARTMENT 6	A	Y	3		
		NPA010	APARTMENT 12	A	Y	3		
		NPA011	APARTMENT 14	A	Y	3		Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1600101</b>	<b>NATURAL PARK APARTMENTS, LLC</b>	<b>C</b>	<b>60</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		20					

Towns Served: WILLINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		NPA012	APARTMENT 20	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
279	WELL 1	2	WELL 1	A				
295	WELL 2	2	WELL 2	A				
36582	TREATMENT PLANT							
51792	ATMOSPHERIC STORAGE TANK							
51793	HYDROPNEUMATIC STORAGE TANK							
51795	BOOSTER PUMPING FACILITIES							

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, JEFFREY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020

Water System Facility: **TREATMENT PLANT (WSF ID: 36582)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021

### Contact Information

Name		Organization			Job Title			
<b>Mr. Steven King</b>		Natural Park Apartments, LLC			Owner/Manager			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 296			Tolland			CT	06084	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
			860-933-8798	860-487-4326	stevenking551222@gmail.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1606111	WILLINGTON RIDGE CONDOS - SYSTEM #1	C	102	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: WILLINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30			
	1/1/22 - 12/31/24	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
Water System Facility: <b>ENTRY POINT-WELL 1 (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1606111	WILLINGTON RIDGE CONDOS - SYSTEM #1	C	102	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: WILLINGTON

## Monitoring Requirements

Water System Facility: ENTRY POINT-WELL 1 (WSF ID: 00700)				
<b>Inorganic Chemicals (IOCS)</b>			<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20		Complete	
	1/1/21 - 12/31/21			
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>			<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
<b>Organic Chemicals (VOCS)</b>			<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION EXEMPTION	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW020-1A	KITCHEN	A	Y	2	Y	Y
		MW020-1BBR	1B D BROCKLEHURST BA	A	Y	2		
		MW020-1BK	UNIT 1B KITCHEN	A	Y	2		
		MW020-1CK	UNIT 1C KITCHEN	A	Y	2		
		MW020-1DK	1D J NISSEN KITCHEN	A	Y	2		
		MW020-1FK	UNIT 1F KITCHEN	A	Y	2		
		MW020-2AK	2A E MODEAN KITCHEN	A	Y	2		
		MW020-2BK	UNIT 2B KITCHEN	A	Y	2		
		MW020-2CK	UNIT 2C KITCHEN	A	Y	2		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1606111</b>	<b>WILLINGTON RIDGE CONDOS - SYSTEM #1</b>	<b>C</b>	<b>102</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		11					

Towns Served: WILLINGTON

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MW020-2DBR	2D G GRENIER BATHROO	A	Y	2		
		MW020-2EK	UNIT 2E KITCHEN	A	Y	2		
		MW020-2FK	UNIT 2F KITCHEN	A	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT-WELL 1	3	ENTRY POINT	A				
226	LOWER WELL 1	2	LOWER WELL 1	A				
48452	INTERCONNECTION - CT1606211 - SYSTEM #2							

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021
LAFRAMBOISE, JEFFREY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020

## Contact Information

Name		Organization			Job Title		
<b>Ms. Alayna Szkrybalo</b>		Willington Ridge Condos			Office Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 1221					Glastonbury	CT	06033
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-659-3802				860-429-4507	Email@kpmmanagementllc.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Name		Organization			Job Title		
<b>Mr. Richard Phipps</b>		Willington Ridge Condos					
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
33 Baxter Road		Unit 3 G			Willington	CT	06279
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-753-0494					rick.phipps@gerberscientific.com		

Contact Role(s): **Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1609111	CTWC - RIVERSEDGE DIVISION	C	179	P	GWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			49				

Towns Served: WILLINGTON

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete	
	10/1/19 - 10/31/19		Complete	
	1/1/20 - 3/31/20			
	4/1/20 - 6/30/20			
	7/1/20 - 9/30/20			
<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	11/1/19 - 11/6/19		Complete	
<b>Total Coliform (3100)</b>		<b>3 temporary routine (TR) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	11/1/19 - 11/30/19		Complete	
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/19	6/1-9/30	Complete	
	1/1/20 - 12/31/20	6/1-9/30		
	1/1/21 - 12/31/21	6/1-9/30		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete	
	10/1/19 - 12/31/19		Complete	
	1/1/20 - 3/31/20			
	4/1/20 - 6/30/20			
	7/1/20 - 9/30/20			

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2010	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2011	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2011	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/30/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2013	
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609111</b>	<b>CTWC - RIVERSEDGE DIVISION</b>	<b>C</b>	<b>179</b>	<b>P</b>	<b>GWP</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			49				

Towns Served: WILLINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		RIVE001	UNIT 1006	A	Y	N		
		RIVE002	UNIT 1020	A	Y	N		
		RIVE003	UNIT 1028	A	Y	N		
		RIVE004	UNIT 1008	A	Y	N		
		RIVE005	UNIT 1018	A	Y	N		
		RIVE006	UNIT 1034	A	Y	N		
		RIVE007	UNIT 1015	A	Y	N		
		RIVE008	118 RIVER RD	A		N		
		RIVE009	119 RIVER RD	A		3		
		RIVE010	121 RIVER RD	A		3		
		RIVE011	131 RIVER RD	A		N		
		RIVE012	137 RIVER RD	A		3		
		RIVE013	145 RIVER RD	A		3		
		RIVE014	10 DEPOT RD 1001	A		N		
		RIVE015	10 DEPOT RD 1002	A		N		
		RIVE016	10 DEPOT RD 1003	A		N		
		RIVE017	10 DEPOT RD 1004	A		N		
		RIVE018	10 DEPOT RD 1005	A		N		
		RIVE019	10 DEPOT RD 1007	A		N		
		RIVE020	10 DEPOT RD 1009	A		N		
		RIVE021	10 DEPOT RD 1010	A		N		
		RIVE022	10 DEPOT RD 1011	A		N		
		RIVE023	10 DEPOT RD 1012	A		N		
		RIVE024	10 DEPOT RD 1013	A		N		
		RIVE025	10 DEPOT RD 1014	A		N		
		RIVE026	10 DEPOT RD 1015	A		N		
		RIVE027	10 DEPOT RD 1016	A		N		
		RIVE028	10 DEPOT RD 1017	A		N		
		RIVE029	10 DEPOT RD 1019	A		N		
		RIVE030	10 DEPOT RD 1021	A		N		
		RIVE031	10 DEPOT RD 1022	A		N		
		RIVE032	10 DEPOT RD 1023	A		N		
		RIVE033	10 DEPOT RD 1024	A		N		
		RIVE034	10 DEPOT RD 1025	A		N		
		RIVE035	10 DEPOT RD 1026	A		N		
		RIVE036	10 DEPOT RD 1027	A		N		
		RIVE037	10 DEPOT RD 1029	A		N		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609111</b>	<b>CTWC - RIVERSEGE DIVISION</b>	<b>C</b>	<b>179</b>	<b>P</b>	<b>GWP</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		49					

Towns Served: WILLINGTON

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		RIVE038	10 DEPOT RD 1030	A		N		
		RIVE039	10 DEPOT RD 1031	A		N		
		RIVE040	10 DEPOT RD 1032	A		N		
		RIVE041	10 DEPOT RD 1033	A		N		
		RIVE042	10 DEPOT RD 1034	A		N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				

51606 INTERCONNECTION -  
CT1423011 - TOLLAND

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
GREEN, III, CLIFFORD	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2023
LABIANCA, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021

## Contact Information

Name			Organization			Job Title		
<b>Mr. Stephen Lamont</b>			Rivers Edge Apartments			Partner		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
40 West Street			Suite 10			Vernon	CT	06066
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-875-0000		860-875-5082		860-872-7539	steve@leelamont.com / www.leelamont.com			

Contact Role(s): **Owner**

Name			Organization			Job Title		
<b>Mr. Craig J. Patla</b>			Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6140				800-391-1924	cpatla@ctwater.com			

Contact Role(s): **Legal Contact**

Name			Organization			Job Title		
<b>Mr. David Connors</b>			Connecticut Water Company			Director, Service De		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main St						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6141				860-227-4902	dconnors@ctwater.com			

Contact Role(s): **Administrative Contact**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
<b>CT1609111</b>	<b>CTWC - RIVERSEdge DIVISION</b>	<b>C</b>	<b>179</b>	<b>P</b>	<b>GWP</b>	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
	49					

Towns Served: WILLINGTON

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1606211	WILLINGTON RIDGE CONDOS - SYSTEM #2	C	102	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			23				

Towns Served: WILLINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/22				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				
<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	9/24/19 - 9/29/19		Complete		
<b>Total Coliform (3100)</b>		<b>3 temporary routine (TR) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/21	6/1-9/30			
	1/1/22 - 12/31/24	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/19 - 9/30/19		Complete		
	10/1/19 - 12/31/19		Complete		
	1/1/20 - 3/31/20		Complete		
	4/1/20 - 6/30/20				
	7/1/20 - 9/30/20				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
	1/1/23 - 12/31/25				
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1606211	WILLINGTON RIDGE CONDOS - SYSTEM #2	C	102	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			23				

Towns Served: WILLINGTON

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		Complete
	1/1/21 - 12/31/21		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
	1/1/23 - 12/31/25		

Water System Facility: WELL #2 (WSF ID: 227)

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW (2)	9/23/19 - 9/29/19		Complete

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION EXEMPTION	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1606211</b>	<b>WILLINGTON RIDGE CONDOS - SYSTEM #2</b>	<b>C</b>	<b>102</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		23					

Towns Served: WILLINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW020-3A	KITCHEN	A	Y	2	Y	Y
		MW020-3B	3B S DALEY	A	Y	2		
		MW020-4DK	4D R NEIDERWERTER KI	A	Y	2		
		MW020-4F	4F KITCHEN	A	Y	2		
		MW020-5B	5B KITCHEN	A	Y	2		
		MW020-5DK	5D R SLEDJESKI KI	A	Y	2		
		MW020-5F	5F KITCHEN	A	Y	2		
		MW020-6C	BATHROOM SINK 6C	A	Y	2		
		MW020-6FBR	6F C DION BATHROOM S	A	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
227	WELL #2	2	RAW	A				
57687	ATMOSPHERIC STORAGE TANK							
57689	HYDROPNEUMATIC TANK							
57691	BOOSTER PUMPS							

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2021
LAFRAMBOISE, JEFFREY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2020

### Contact Information

Name			Organization			Job Title		
<b>Ms. Alayna Szkrybalo</b>			Willington Ridge Condos			Office Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 1221						Glastonbury	CT	06033
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-659-3802				860-429-4507	Email@kpmmanagementllc.com			
Contact Role(s): <b>Administrative Contact</b>								

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1606211</b>	<b>WILLINGTON RIDGE CONDOS - SYSTEM #2</b>	<b>C</b>	<b>102</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			23					
Towns Served: WILLINGTON								
Name			Organization			Job Title		
<b>Mr. Richard Phipps</b>			Willington Ridge Condos					
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
33 Baxter Road			Unit 3 G			Willington	CT	06279
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-753-0494					rick.phipps@gerberscientific.com			
Contact Role(s): <b>Legal Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609141</b>	<b>WILLINGTON SENIOR CENTER &amp; HOUSING</b>	C	32	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
60 OLD FARMS ROAD			1				
Towns Served: WILLINGTON							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Asbestos (1094) 1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		

**Total Coliform (3100) 1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

**Lead And Copper (PBCU) 5 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	Complete
	1/1/20 - 12/31/22	6/1-9/30	
	1/1/23 - 12/31/25	6/1-9/30	

**Physical Parameters (PPS) 1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/19 - 10/31/19		Complete
	11/1/19 - 11/30/19		Complete
	12/1/19 - 12/31/19		Complete
	1/1/20 - 1/31/20		Complete
	2/1/20 - 2/29/20		Complete
	3/1/20 - 3/31/20		Complete
	4/1/20 - 4/30/20		
	5/1/20 - 5/31/20		
	6/1/20 - 6/30/20		
	7/1/20 - 7/31/20		
	8/1/20 - 8/31/20		
	9/1/20 - 9/30/20		

**Water System Facility: WILLINGTON SENIOR CENTER TREATMENT PLANT (WSF ID: 00700)**

**Inorganic Chemicals (IOCS) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
---	--------------------------	--------------------------	--------------------------

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609141</b>	<b>WILLINGTON SENIOR CENTER &amp; HOUSING</b>	C	32	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
60 OLD FARMS ROAD			1				

Towns Served: WILLINGTON

## Monitoring Requirements

Water System Facility: **WILLINGTON SENIOR CENTER TREATMENT PLANT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
TREATMENT PLANT ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
TREATMENT PLANT ENTRY POINT (3)	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			
	1/1/21 - 12/31/21			
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
TREATMENT PLANT ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
TREATMENT PLANT ENTRY POINT (3)	1/1/17 - 12/31/19		Complete	
	1/1/20 - 12/31/22			
	1/1/23 - 12/31/25			
Organic Chemicals (VOCS)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
TREATMENT PLANT ENTRY POINT (3)	1/1/19 - 12/31/19		Complete	
	1/1/20 - 12/31/20			
	1/1/21 - 12/31/21			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **WILLINGTON SENIOR CENTER TREATMENT PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily	
<b>Start Date:</b> 9/1/2010		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		10/1/2019 - 10/31/2019		
		11/1/2019 - 11/30/2019		
		12/1/2019 - 12/31/2019		
		1/1/2020 - 1/31/2020		
		2/1/2020 - 2/29/2020		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	6/30/2010	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609141</b>	<b>WILLINGTON SENIOR CENTER &amp; HOUSING</b>	C	32	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
60 OLD FARMS ROAD			1				
Towns Served: WILLINGTON							

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2020	
SUBMIT CCR CERTIFICATION FORM	8/9/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WSC001	APARTMENT 1	A	Y	2		
		WSC002	APARTMENT 2	A	Y	2		
		WSC003	APARTMENT 3	A	Y	2		
		WSC004	APARTMENT 4	A	Y	2		
		WSC005	APARTMENT 5	A	Y	2		
		WSC006	APARTMENT 6	A	Y	2		
		WSC007	APARTMENT 7	A	Y	2		
		WSC008	APARTMENT 8	A	Y	2		
		WSC009	APARTMENT 9	A	Y	2		
		WSC010	APARTMENT 10	A	Y	2		
		WSC011	APARTMENT 11	A	Y	2		
		WSC012	APARTMENT 12	A	Y	2		
		WSC013	APARTMENT 13	A	Y	2		
		WSC014	APARTMENT 14	A	Y	2		
		WSC015	APARTMENT 15	A	Y	2		
		WSC016	APARTMENT 16	A	Y	2		
		WSC017	APARTMENT 17	A	Y	2		
		WSC018	APARTMENT 18	A	Y	2		
		WSC019	APARTMENT 19	A	Y	2		
		WSC020	APARTMENT 20	A	Y	2		
		WSC021	APARTMENT 21	A	Y	2		
		WSC022	APARTMENT 22	A	Y	2		
		WSC023	APARTMENT 23	A	Y	2		
		WSC024	APARTMENT 24	A	Y	2		
		WSC025	APARTMENT 25	A	Y	2		
		WSC026	APARTMENT 26	A	Y	2		
		WSC027	APARTMENT 27	A	Y	2		
		WSC028	APARTMENT 28	A	Y	2		
		WSC029	APARTMENT 29	A	Y	2		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1609141</b>	<b>WILLINGTON SENIOR CENTER &amp; HOUSING</b>	<b>C</b>	<b>32</b>	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
60 OLD FARMS ROAD			1				
Towns Served: WILLINGTON							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		WSC030	APARTMENT 30	A	Y	2		
		WSC031	APARTMENT 31	A	Y	2		
		WSC032	APARTMENT 32	A	Y	2		
		WSC033	UPPER LAUNDRY	A	Y	2		
		WSC034	MN LEVEL LAUNDRY	A	Y	2		
		WSC035	LOWER KITCHENETTE	A	Y	2		
		WSC036	MENS BATHROOM	A	Y	2		
		WSC037	WOMENS BATHROOM	A	Y	2		
		WSC038	UNISEX BATHROOM	A	Y	2		
00700	WILLINGTON SENIOR CENTER TREATMENT PLANT	3	TREATMENT PLANT ENTR	A				
53862	WELL 1	2	WELL 1	A				
53864	WELL 2	2	WELL 2	A				
53866	WELL 3	2	WELL 3	A				
53868	WELL 4	2	WELL 4	A				
53874	ATMOSPHERIC TANK							
53876	PRESSURE TANKS							
53878	PUMP STATION							

## Certified Operator Information

<b>Water System Facility:</b> WILLINGTON SENIOR CENTER TREATMENT PLANT (WSF ID: 00700)			
<b>Facility Classification:</b> CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2021
HARKINS, STUART A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2022
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2022

## Contact Information

Name		Organization			Job Title		
<b>Ms. Christina Beebe Mailhos</b>		Town of Willington			First Selectman		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
Town Office Building		40 Old Farms Road			Willington	CT	06279
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-487-3100		860-487-3103			cmailhos@willingtonct.org		
<b>Contact Role(s):</b> Administrative Contact, Legal Contact, Owner							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
<b>CT1609141</b>	<b>WILLINGTON SENIOR CENTER &amp; HOUSING</b>	<b>C</b>	<b>32</b>	<b>L</b>	<b>GW</b>	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
60 OLD FARMS ROAD		<b>1</b>				
Towns Served: WILLINGTON						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**